



State of New Jersey

MIKIE SHERRILL
Governor

DEPARTMENT OF ENVIRONMENTAL PROTECTION

ED POTOSNAK
Acting Commissioner

DR. DALE G. CALDWELL
Lt. Governor

AIR, ENERGY AND MATERIALS SUSTAINABILITY
Division of Air Quality and Radiation Protection
Bureau of Stationary Sources
401 E. State Street, 2nd floor, P.O. Box 420, Mail Code 401-02
Trenton, NJ 08625-0420

Air Pollution Control Operating Permit Administrative Amendment

Permit Activity Number: BOP260001

Program Interest Number: 07736

Mailing Address	Plant Location
RICHARD MERKER FACILITY MANAGER REORLD ESSEX CO 183 RAYMOND BLVD Newark, NJ 07105	REORLD ESSEX COMPANY 183 Raymond Blvd Newark Essex County

Initial Operating Permit Approval Date: July 8, 2004
Operating Permit Approval Date: February 18, 2026
Operating Permit Expiration Date: October 27, 2018 (Operating under Application Shield)

AUTHORITY AND APPLICABILITY

The New Jersey Department of Environmental Protection (Department) approves and issues this Air Pollution Control Operating Permit under the authority of Chapter 106, P.L. 1967 (N.J.S.A. 26:2C-9.2). This permit is issued in accordance with the air pollution control permit provisions promulgated at Title V of the Federal Clean Air Act, 40 CFR 70, Air Pollution Control Act codified at N.J.S.A. 26:2C and New Jersey State regulations promulgated at N.J.A.C. 7:27-22.

The Department approves this operating permit based on the evaluation of the certified information provided in the permit application that all equipment and air pollution control devices regulated in this permit comply with all applicable State and Federal regulations. The facility shall be operated in accordance with the conditions of this permit. This operating permit supersedes any previous Air Pollution Control Operating Permits issued to this facility by the Department including any general operating permits, renewals, significant modifications, minor modifications, seven-day notice changes or administrative amendments to the permit.

Changes made through this permit activity are provided in the Reason for Application.

PERMIT SHIELD

Equipment at the facility referenced by this modification **is not covered** by the permit shield, pursuant to the provisions of N.J.A.C. 7:27-22.17.

COMPLIANCE SCHEDULES

This operating permit does not include compliance schedules as part of the approved compliance plan.

COMPLIANCE CERTIFICATIONS AND DEVIATION REPORTS

The permittee shall submit to the Department and to United States Environmental Protection Agency (US EPA) periodic compliance certifications, in accordance with N.J.A.C. 7:27-22.19. **The annual compliance certification** is due to the Department and EPA within 60 days after the end of each calendar year during which this permit was in effect. **Semi-annual deviation reports** relating to compliance testing and monitoring are due to the Department within 30 days after the end of the semi-annual period. The schedule and additional details for these submittals are available in Subject Item - FC, of the Facility Specific Requirements of this permit.

ACCESSING PERMITS

The facility's current approved operating permit and any previously issued permits (e.g. superseded, expired, or terminated) are available for download in PDF format at: <https://dep.nj.gov/boss>. After accessing the website, click on "Approved Operating Permits" listed under "Reports" and then type in the Program Interest (PI) Number as instructed on the screen. If needed, the RADIUS file for your permit, containing Facility Specific Requirements (Compliance Plan), Inventories and Compliance Schedules can be obtained by contacting the Helpline number given below. RADIUS software, instructions, and help are available at the Department's website at <https://dep.nj.gov/boss>.

HELPLINE

The Operating Permit Helpline is available for any questions at (609) 633-8248 from 9:00 AM to 4:00 PM Monday to Friday.

RENEWING YOUR OPERATING PERMIT AND APPLICATION SHIELD

The permittee is responsible for submitting a timely and administratively complete operating permit renewal application pursuant to N.J.A.C. 7:27-22.30. Only applications which are timely and administratively complete are eligible for an application shield. The details on the contents of the renewal application, submittal schedule, and application shield are available in Section B - General Provisions and Authorities of this permit.

COMPLIANCE ASSURANCE MONITORING

Facilities that are subject to Compliance Assurance Monitoring (CAM), pursuant to 40 CFR 64, shall develop a CAM Plan for modified equipment as well as existing sources. The rule and guidance on how to prepare a CAM Plan can be found at EPA's website: <https://www.epa.gov/air-emissions-monitoring-knowledge-base/compliance-assurance-monitoring>. In addition, CAM Plans must be included as part of the permit renewal application. Facilities that do not submit a CAM Plan may have their permit applications denied, pursuant to N.J.A.C. 7:27-22.3.

ADMINISTRATIVE HEARING REQUEST

If, in your judgment, the Department is imposing any unreasonable condition of approval, you may contest the Department's decision and request an adjudicatory hearing pursuant to N.J.S.A. 52:14B-1 et seq. and N.J.A.C. 7:27-22.32(a). All requests for an adjudicatory hearing must be received in writing by the Department within 20 calendar days of the date you receive this letter. The request must contain the information specified in N.J.A.C. 7:27-1.32 and the information on the [NJ04 - Administrative Hearing Request Checklist and Tracking Form](https://dep.nj.gov/wp-content/uploads/boss/applications-and-forms/administrative-hearing-request-checklist-and-tracking-form.pdf) available at <https://dep.nj.gov/wp-content/uploads/boss/applications-and-forms/administrative-hearing-request-checklist-and-tracking-form.pdf>.

If you have any questions regarding this permit approval, please call Ted Chleboski at (609) 940-5485.

Approved by:

A handwritten signature in black ink that reads "Joel Leon". The signature is written in a cursive style with a period at the end.

Joel Leon

Enclosure

CC: Neha Sareen, United States Environmental Protection Agency, Region 2

Facility Name: REWORLD ESSEX COMPANY
Program Interest Number: 07736
Permit Activity Number: BOP260001

TABLE OF CONTENTS

<u>Section A</u>	POLLUTANT EMISSIONS SUMMARY
<u>Section B</u>	GENERAL PROVISIONS AND AUTHORITIES
<u>Section C</u>	STATE-ONLY APPLICABLE REQUIREMENTS
<u>Section D</u>	FACILITY SPECIFIC REQUIREMENTS AND INVENTORIES

- FACILITY SPECIFIC REQUIREMENTS – PAGE INDEX
- REASON FOR APPLICATION
- FACILITY SPECIFIC REQUIREMENTS (COMPLIANCE PLAN)
- FACILITY PROFILE (ADMINISTRATIVE INFORMATION)
- INSIGNIFICANT SOURCE EMISSIONS
- EQUIPMENT INVENTORY
- EQUIPMENT DETAILS
- CONTROL DEVICE INVENTORY
- CONTROL DEVICE DETAILS
- EMISSION POINT INVENTORY
- EMISSION UNIT / BATCH PROCESS INVENTORY
- SUBJECT ITEM GROUP INVENTORY

Section A

Facility Name: REWORLD ESSEX COMPANY

Program Interest Number: 07736

Permit Activity Number: BOP260001

POLLUTANT EMISSIONS SUMMARY

Table 1: Total emissions from all Significant Source Operations¹ at the facility.

Facility's Potential Emissions from all Significant Source Operations (tons per year)										
Source Categories	VOC (total)	NO _x	CO	SO ₂	TSP (total)	PM ₁₀ (total)	PM _{2.5} ² (total)	Pb	HAPs* (total)	CO ₂ e ³
Emission Units Summary	83.1	1256	1658	996	57	207	203	0.44	299	
Batch Process Summary	NA	NA	NA	NA	NA	NA	NA	NA	NA	
Group Summary	NA	NA	NA	NA	NA	NA	NA	NA	NA	
Total Emissions	83.1	1256	1658	996	57	207	203	0.44	299	378,000

Table 2: Estimate of total emissions from all Insignificant Source Operations¹ and total emissions from Non-Source Fugitives at the facility.

Emissions from all Insignificant Source Operations and Non-Source Fugitive Emissions (tons per year)									
Source Categories	VOC (total)	NO _x	CO	SO ₂	TSP (total)	PM ₁₀ (total)	PM _{2.5} ² (total)	Pb	HAPs (total)
Insignificant Source Operations	NA	NA	NA	NA	NA	NA	NA	NA	NA
Non-Source Fugitive Emissions	NA	NA	NA	NA	NA	NA	NA	NA	NA

VOC: Volatile Organic Compounds

NO_x: Nitrogen Oxides

CO: Carbon Monoxide

SO₂: Sulfur Dioxide

N/A: Indicates the pollutant is not emitted or is emitted below the reporting threshold specified in N.J.A.C. 7:27-22, Appendix, Table A and N.J.A.C. 7:27-17.9(a).

TSP: Total Suspended Particulates

Other: Any other air contaminant regulated under the Federal CAA

PM₁₀: Particulates under 10 microns

PM_{2.5}: Particulates under 2.5 microns

Pb: Lead

HAPs: Hazardous Air Pollutants

CO₂e: Carbon Dioxide equivalent

*Emissions of individual HAPs are provided in Table 3 on the next page.

Emissions of "Other" air contaminants are provided in Table 4 on the next page.

¹ Significant Source Operations and Insignificant Source Operations are defined at N.J.A.C. 7:27-22.1.

² PM_{2.5} has been included in air permitting rules as of December 9, 2017. Consequently, PM_{2.5} totals in this section may not be up to date. The Department is in the process of updating these limits during each permit modification, and the entire permit will be updated at the time of permit renewal.

³ Total CO₂e emissions for the facility.

Section A

Facility Name: REWORLD ESSEX COMPANY

Program Interest Number: 07736

Permit Activity Number: BOP260001

POLLUTANT EMISSIONS SUMMARY

Table 3: Summary of Hazardous Air Pollutants (HAP) Emissions from Significant Source Operations ⁴:

HAP	TPY
Arsenic	0.044
Beryllium	0.003
Cadmium	0.044
Chromium	0.143
Dioxin/Furans	0.00013
TCDD (2,3,7,)	0.000119
Hydrogen Chloride	284
Hydrogen Fluoride	10.8
Lead	0.44
Mercury	0.12
Nicke	0.039
Polycyclic Organic Matter	3.81

Table 4: Summary of “Other” air contaminants emissions from Significant Source Operations:

Other Air Contaminant	TPY
Ammonia	133

⁴ Do not sum the values below for the purpose of establishing a total HAP potential to emit. See previous page for the allowable total HAP emissions.

Section B

Facility Name: REWORLD ESSEX COMPANY

Program Interest Number: 07736

Permit Activity Number: BOP260001

GENERAL PROVISIONS AND AUTHORITIES

1. No permittee shall allow any air contaminant, including an air contaminant detectable by the sense of smell, to be present in the outdoor atmosphere in a quantity and duration which is, or tends to be, injurious to human health or welfare, animal or plant life or property, or which would unreasonably interfere with the enjoyment of life or property. This shall not include an air contaminant that occurs only in areas over which the permittee has exclusive use or occupancy. Requirements relative only to nuisance situations, including odors, are not considered federally enforceable. [N.J.A.C. 7:27-22.16(g)8]
2. Any deviation from operating permit requirements which results in a release of air contaminants shall be reported to the Department as follows:
 - a. If the air contaminants are released in a quantity or concentration which poses a potential threat to public health, welfare or the environment or which might reasonably result in citizen complaints, the permittee shall report the release to the Department:
 - i. Immediately on the Department hotline at 1-(877) 927-6337, pursuant to N.J.S.A. 26:2C-19(e); and
 - ii. As part of the compliance certification required in N.J.A.C. 7:27-22.19(f). However, if the deviation is identified through source emissions testing, it shall be reported through the source emissions testing and monitoring procedures at N.J.A.C. 7:27-22.18(e)3; or
 - b. If the air contaminants are released in a quantity or concentration which poses no potential threat to public health, welfare or the environment and which will not likely result in citizen complaints, the permittee shall report the release to the Department as part of the compliance certification required in N.J.A.C. 7:27-22.19(f), except for deviations identified by source emissions testing reports, which shall be reported through the procedures at N.J.A.C. 7:27-22.18(e)3; or
 - c. If the air contaminants are released in a quantity or concentration which poses no potential threat to public health, welfare, or the environment and which will not likely result in citizen complaints, and the permittee intends to assert an affirmative defense, consistent with General Provision #10 below, the violation shall be reported by 5:00 PM of the second full calendar day following the occurrence, or of becoming aware of the occurrence.
3. The permittee shall comply with all conditions of the operating permit including the approved compliance plan. Any non-compliance with a permit condition constitutes a violation of the New Jersey Air Pollution Control Act N.J.S.A. 26:2C-1 et seq., or the CAA, 42 U.S.C. §7401 et seq., or both, and is grounds for enforcement action; for termination, revocation and reissuance, or for modification of the operating permit; or for denial of an application for a renewal of the operating permit. [N.J.A.C. 7:27-22.16(g)1]
4. It shall not be a defense for the permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of its operating permit. [N.J.A.C. 7:27-22.16(g)2]
5. This operating permit may be modified, terminated, or revoked for cause by the EPA pursuant to 40 CFR 70.7(g) and revoked or reopened and modified for cause by the Department pursuant to N.J.A.C. 7:27-22.25. [N.J.A.C. 7:27-22.16(g)3]

6. The permittee shall furnish to the Department, within a reasonable time, any information that the Department may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating this operating permit; or to determine compliance with the operating permit. [N.J.A.C. 7:27-22.16(g)4]
7. The filing of an application for a modification of an operating permit, or of a notice of planned changes or anticipated non-compliance, does not stay any operating permit condition. [N.J.A.C. 7:27-22.16(g)5]
8. The operating permit does not convey any property rights of any sort, or any exclusive privilege. [N.J.A.C. 7:27-22.16(g)6]
9. Upon request, the permittee shall furnish to the Department copies of records required by the operating permit to be kept. [N.J.A.C. 7:27-22.16(g)7]
10. The permittee may not assert an affirmative defense to penalty liability for non-compliance with a provision or condition of the operating permit that is based on any federally delegated regulation, including but not limited to NSPS, NESHAP, or MACT. An affirmative defense to penalty liability for non-compliance with a provision or condition of the operating permit may be asserted by a permittee if:
 - a. The provision or condition of the operating permit is based solely on State or local law; and
 - b. The affirmative defense is asserted and established as required by N.J.S.A. 26:2C-19.1 through 19.5.
11. In the event of a challenge to any part of this operating permit, all other parts of the permit shall continue to be valid. [N.J.A.C. 7:27-22.16(f)]
12. Each owner and each operator of any facility, source operation, or activity to which this permit applies is responsible for ensuring compliance with all requirements of N.J.A.C. 7:27-22. If the owner and operator are separate persons, or if there is more than one owner or operator, each owner and each operator is jointly and severally liable for any fees due under N.J.A.C. 7:27-22, and for any penalties for violation of N.J.A.C. 7:27-22. [N.J.A.C. 7:27-22.3]
13. The permittee shall ensure that no air contaminant is emitted from any significant source operation at a rate, calculated as the potential to emit, that exceeds the applicable threshold for reporting emissions set forth in the Appendix to N.J.A.C. 7:27-22 or 7:27-17.9(a), unless emission of the air contaminant is authorized by this operating permit. [N.J.A.C. 7:27-22.3(c)]
14. Consistent with the provisions of N.J.A.C. 7:27-22.3(e), the permittee shall ensure that all requirements of this operating permit are met. In the event that there are multiple emission limitations, monitoring, recordkeeping, and/or reporting requirements for a given source operation, the facility must comply with all requirements, including the most stringent.
15. Consistent with the provisions of N.J.A.C. 7:27-22.3(s), Except as otherwise provided in this subchapter, the submittal of any information or application by a permittee including, but not limited to, an application or notice for any change to the operating permit, including any administrative amendment, any minor or significant modification, renewal, a notice of a seven-day notice change, a notice of past or anticipated noncompliance, does not stay any operating permit condition, nor relieve a permittee from the obligation to obtain other necessary permits and to comply with all applicable Federal, State, and local requirements.
16. Applicable requirements derived from an existing or terminated consent decree with EPA will not be changed without advance consultation by the Department with EPA. N.J.A.C. 7:27-22.3(uu).
17. Unless specifically exempted from permitting, temporary mobile equipment for short-term activities may be periodically used at major facilities, on site for up to 90 days if the requirements listed below, (a) through (h) are satisfied.
 - a. The permittee will ensure that the temporary mobile equipment will not be installed permanently or used permanently on site.

- b. The permittee will ensure that the temporary mobile equipment will not circumvent any State or Federal rules and regulations, even for a short period of time, and the subject equipment will comply with all applicable performance standards.
 - c. The permittee cannot use temporary mobile equipment unless the owner or operator of the subject equipment has obtained and maintains an approved Air Pollution Control Permit, issued pursuant to N.J.A.C. 7:27-8 or 22, prior to bringing the temporary mobile equipment to operate at the major facility.
 - d. The permittee is responsible for ensuring the temporary mobile equipment's compliance with the terms and conditions specified in its approved Air Pollution Control Permit when the temporary mobile equipment operates on the property of the permittee.
 - e. The permittee will ensure that temporary mobile equipment utilized for short-term activities will not operate on site for more than a total of 90 days during any calendar year.
 - f. The permittee will keep on site a list of temporary mobile equipment being used at the facility with the start date, end date, and record of the emissions from all such equipment (amount and type of each air contaminant) no later than 30 days after the temporary mobile equipment completed its job in accordance with N.J.A.C. 7:27-22.19(i)3.
 - g. Emissions from the temporary mobile equipment must be included in the emission netting analysis required of the permittee by N.J.A.C. 7:27-18.7. This information is maintained on site by the permittee and provided to the Department upon request in accordance with existing applicable requirements in the FC Section of its Title V permit.
 - h. Where short-term activities (employing temporary mobile equipment) will reoccur on at least an annual basis, the permittee is required to include such activities (and the associated equipment) within one year of the first use, in its Title V permit through the appropriate modification procedures.
18. Consistent with the provisions of N.J.A.C. 7:27-22.9(c), the permittee shall use monitoring of operating parameters, where required by the compliance plan, as a surrogate for direct emissions testing or monitoring, to demonstrate compliance with applicable requirements.
19. The permittee is responsible for submitting timely and administratively complete operating permit applications:
- Administrative Amendments [N.J.A.C. 7:27-22.20(c)];
 - Seven-Day Notice changes [N.J.A.C. 7:27-22.22(e)];
 - Minor Modifications [N.J.A.C. 7:27-22.23(e)];
 - Significant Modifications [N.J.A.C. 7:27-22.24(e)]; and
 - Renewals [N.J.A.C. 7:27-22.30(b)].
20. The operating permit renewal application consists of a RADIUS application and the application attachment available at the Department's website <https://dep.nj.gov/boss/applications-and-forms/> (Attachment to the RADIUS Operating Permit Renewal Application). Both the RADIUS application and the Application Attachment, along with any other supporting documents must be submitted using the Department's Portal at: <https://njdeponline.com/>. The application is considered timely if it is received at least 12 months before the expiration date of the operating permit. To be deemed administratively complete, the renewal application shall include all information required by the application form for the renewal and the information required pursuant to N.J.A.C. 7:27-22.30(d). However, consistent with N.J.A.C. 7:27-22.30(c), the permittee is encouraged to submit the renewal application at least 15 months prior to expiration of the operating permit, so that any deficiencies can be identified and addressed to ensure that the application is administratively complete by the renewal deadline. Only renewal applications which are timely and administratively complete are eligible for an application shield.
21. For all source emissions testing performed at the facility, the phrase "worst case conditions without creating an unsafe condition" used in the enclosed compliance plan is consistent with EPA's National Stack

Testing Guidance, dated April 27, 2009, where all source emission testing performed at the facility shall be under the representative (normal) conditions that:

- a. Represent the range of combined process and control measure conditions under which the facility expects to operate (regardless of the frequency of the conditions); and
 - b. Are likely to most challenge the emissions control measures of the facility with regard to meeting the applicable emission standards, but without creating an unsafe condition.
22. Consistent with EPA's National Stack Testing Guidance and Technical Manual 1004, a facility may not stop an ongoing stack test because it would have failed the test unless the facility also ceases operation of the equipment in question to correct the issue. Stopping an ongoing stack test in these instances will be considered credible evidence of emissions non-compliance.
 23. Each permittee shall maintain records of all source emissions testing or monitoring performed at the facility and required by the operating permit in accordance with N.J.A.C. 7:27-22.19. Records shall be maintained, for at least five years from the date of each sample, measurement, or report. Each permittee shall maintain all other records required by this operating permit for a period of five years from the date each record is made. At a minimum, source emission testing or monitoring records shall contain the information specified at N.J.A.C. 7:27-22.19(b). [N.J.A.C. 7:27-22.19(a) and N.J.A.C. 7:27-22.19(b)]
 24. A Permittee may seek the approval of the Department for a delay in testing required pursuant to this permit by submitting a written request to the appropriate Regional Enforcement Office in accordance with N.J.A.C. 7:27-22.18(k). A Permittee may also seek advanced approval for a longer period for submittal of a source emissions test report required by the permit by submitting a request to the Department's Regional Enforcement Office in accordance with N.J.A.C. 7:27-22.19. [N.J.A.C. 7:27-22.18(k) and N.J.A.C. 7:27-22.19]
 25. Any emission limit values in an operating permit shall be interpreted to be followed by inherent trailing zeros (0) in the decimal portion of the limit to three significant figures (e.g. a printed limit of "1 lb/hr" means a limit of "1.00 lb/hr") except for concentration limits less than 10 parts per million (ppm). For such concentration limits, the emission limit shall be interpreted to be followed by inherent trailing zeros (0) in the decimal portion of the limit to two significant figures (e.g. a printed limit of "1 ppm" means a limit of "1.0 ppm").
 26. Testing every five years shall be defined as no later than the end of the 60th month after the first required and each subsequent stack test was completed for the new or modified source.

Section C

Facility Name: REWORLD ESSEX COMPANY

Program Interest Number: 07736

Permit Activity Number: BOP260001

STATE-ONLY APPLICABLE REQUIREMENTS

N.J.A.C. 7:27-22.16(b)5 requires the Department to specifically designate as not being federally enforceable any permit conditions based only on applicable State requirements. The applicable State requirements to which this provision applies are listed in the table titled “State-Only Applicable Requirements.”

STATE-ONLY APPLICABLE REQUIREMENTS

The following applicable requirements are not federally enforceable:

<u>SECTION</u>	<u>SUBJECT ITEM</u>	<u>ITEM #</u>	<u>REF. #</u>
B	---	1	---
B	---	10b	---
D	FC	---	3
D	FC	---	9

Section D

Facility Name: REWORLD ESSEX COMPANY

Program Interest Number: 07736

Permit Activity Number: BOP260001

FACILITY SPECIFIC REQUIREMENTS AND INVENTORIES

FACILITY SPECIFIC REQUIREMENTS PAGE INDEX

Subject Item and Name **Page Number**

Facility (FC):

FC	1
----	---

Insignificant Sources (IS):

IS NJID	IS Description	
IS1	No. 2 Fuel Oil Tanks (<10,000 Gallons Capacity)	7
IS2	Fuel Oil Tank (>10,000 Gallons Capacity)	8

Groups (GR):

GR NJID	GR Designation	GR Description	
GR1	NSPS Sub A	Equipment Subject to Federal NSPS Requirements	9

U NJID	U Designation	U Description	
U1	MWC #1,#2,#3	MWC #1, 2, 3 Municipal Waste Combustors (E1, E2, and E3)	16
U6	Silo A	Lime Storage Silo A (E4)	60
U7	Silo B	Lime Storage Silo B (E5)	60
U8	Silo C	Lime Storage Silo C (E6)	60
U9	Slaker A	Lime Slaker Vent A (E9)	61
U10	Slaker B	Lime Slaker Vent B (E10)	61
U11	Carbon Silo	Activated Carbon Storage Silo (E14)	62
U12	Flyash Cond	Flyash Conditioning Room (E12,E13)	63
U13	Em Generator	7.4 MMBtu/hr, 740 KW Diesel Engine-Driven Emergency Generator (E7)	64
U14	Em FW Pump	1.59 MMBtu/hr Emergency Diesel Engine-Driven Fire Pump (E8)	68
U15	Ash Convey	Ash and Metals Recovery System (E16, E17, E21- E30)	72

BOP260001

New Jersey Department of Environmental Protection

Reason for Application

Permit Modified	BOP250001
Description of Modification	This Administrative Amendment application is submitted to update the Responsible Official information.

New Jersey Department of Environmental Protection

Facility Specific Requirements

FC

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
1	General Provisions: The permittee shall comply with all applicable provisions of N.J.A.C. 7:27-1. [N.J.A.C. 7:27-1]	None.	None.	None.
2	Control and Prohibition of Open Burning: The permittee is prohibited from open burning of rubbish, garbage, trade waste, buildings, structures, leaves, other plant life and salvage. Open burning of infested plant life or dangerous material may only be performed with a permit from the Department. [N.J.A.C. 7:27- 2]	None.	None.	Obtain an approved permit: Prior to occurrence of event (prior to open burning). [N.J.A.C. 7:27- 2]
3	Prohibition of Air Pollution: The permittee shall not emit into the outdoor atmosphere substances in quantities that result in air pollution as defined at N.J.A.C. 7:27-5.1. [N.J.A.C. 7:27- 5]	None.	None.	None.
4	Prevention and Control of Air Pollution Control Emergencies: Any person responsible for the operation of a source of air contamination set forth in Table 1 of N.J.A.C. 7:27-12 is required to prepare a written Standby Plan, consistent with good industrial practice and safe operating procedures, and be prepared for reducing the emission of air contaminants during periods of an air pollution alert, warning, or emergency. Any person who operates a source not set forth in Table 1 of N.J.A.C. 7:27-12 is not required to prepare such a plan unless requested by the Department in writing. [N.J.A.C. 7:27-12]	None.	None.	Comply with the requirement: Upon occurrence of event. Upon proclamation by the Governor of an air pollution alert, warning, or emergency, the permittee shall put the Standby Plan into effect. In addition, the permittee shall ensure that all of the applicable emission reduction objectives of N.J.A.C. 7:27-12.4, Table I, II, and III are complied with whenever there is an air pollution alert, warning, or emergency. [N.J.A.C. 7:27-12]
5	Emission Offset Rules: The permittee shall comply with all applicable provisions of Emission Offset Rules. [N.J.A.C. 7:27-18]	None.	None.	None.
6	Emission Statements: The permittee shall comply with all the applicable provisions of N.J.A.C. 7:27-21. [N.J.A.C. 7:27-21]	None.	None.	None.
7	Compliance Certification: The permittee shall submit an annual Compliance Certification for each applicable requirement, pursuant to N.J.A.C. 7:27-22.19(f). [N.J.A.C. 7:27-22]	None.	None.	<p>Submit an Annual Compliance Certification: Annually to the Department and to EPA within 60 days after the end of each calendar year during which this permit was in effect. The Compliance Certification shall be certified pursuant to N.J.A.C. 7:27-1.39 by the responsible official and submitted electronically through the NJDEP online web portal. The certification should be printed for submission to EPA.</p> <p>The NJDEP online web portal can be accessed at: http://www.state.nj.us/dep/online/. The Compliance Certification forms and instructions for submitting to EPA are available by selecting Documents and Forms and then Periodic Compliance Certification. [N.J.A.C. 7:27-22]</p>

New Jersey Department of Environmental Protection

Facility Specific Requirements

FC

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
8	Prevention of Air Pollution from Consumer Products and Architectural Coatings: The permittee shall comply with all applicable provisions of N.J.A.C. 7:27-24 and [N.J.A.C. 7:27-23]	None.	None.	None.
9	Any operation of equipment which causes off-property effects, including odors, or which might reasonably result in citizen's complaints shall be reported to the Department to the extent required by the Air Pollution Control Act, N.J.S.A. 26:2C-19(e). [N.J.S.A. 26: 2C-19(e)]	Other: Observation of plant operations. [N.J.S.A. 26: 2C-19(e)].	Other: Maintain a copy of all information submitted to the Department. [N.J.S.A. 26: 2C-19(e)].	Notify by phone: Upon occurrence of event. A person who causes a release of air contaminants in a quantity or concentration which poses a potential threat to public health, welfare or the environment or which might reasonably result in citizen complaints shall immediately notify the Department. Such notification shall be made by calling the Environmental Action Hotline at (877) 927-6337. [N.J.S.A. 26: 2C-19(e)]
10	Prevention of Significant Deterioration: The permittee shall comply with all applicable provisions of Prevention of Significant Deterioration (PSD). [40 CFR 52.21]	None.	None.	None.
11	The permittee shall comply with all applicable provisions of National Emission Standards for Hazardous Air Pollutants (NESHAPS) for Asbestos, Subpart M. [40 CFR 61]	Other: Comply with 40 CFR 61.145 and 61.150 when conducting any renovation or demolition activities at the facility. [40 CFR 61].	Other: Comply with 40 CFR 61.153 when conducting any renovation or demolition activities at the facility. [40 CFR 61].	Comply with the requirement: Upon occurrence of event. The permittee shall comply with 40 CFR 61.153 when conducting any renovation or demolition activities at the facility. [40 CFR 61]
12	Protection of Stratospheric Ozone:1) If the permittee manufactures, transforms, destroys, imports, or exports a Class I or Class II substance, the permittee is subject to all the requirements as specified at 40 CFR 82, Subpart A; 2) If the permittee performs a service on motor "fleet" vehicles when this service involves an ozone depleting substance refrigerant (or regulated substance) in the motor vehicle air conditioner (MVAC), the permittee is subject to all the applicable requirements as specified at 40 CFR 82, Subpart B. 3) The permittee shall comply with the standards for labeling of products containing or manufactured with ozone depleting substances pursuant to 40 CFR 82, Subpart E. 4) The permittee shall comply with the standards for recycling and emission reductions of Class I and Class II refrigerants or a regulated substitute substance during the service, maintenance, repair, and disposal of appliances pursuant to 40 CFR 82, Subpart F, except as provided for motor vehicle air conditioners (MVACs) in Subpart B. 5) The permittee shall be allowed to switch from any ozone depleting substance to any alternative that is listed in the Significant New Alternative Program (SNAP) promulgated pursuant to 40 CFR 82, Subpart G. [40 CFR 82]	Other: Comply with 40 CFR 82 Subparts A, B, E, F, and G. [40 CFR 82].	Other: Comply with 40 CFR 82 Subparts A, B, E, F, and G. [40 CFR 82].	Comply with the requirement: Upon occurrence of event. The permittee shall comply with 40 CFR 82 Subparts A, B, E, F, and G. [40 CFR 82]

New Jersey Department of Environmental Protection

Facility Specific Requirements

FC

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
13	<p>Deviation Reports: The permittee shall submit to the Department a certified six-month Deviation Report relating to testing and monitoring required by the operating permit. [N.J.A.C. 7:27-22.19(d)3], [N.J.A.C.7:27-22.19(e)], and [N.J.A.C. 7:27-22.19(c)]</p>	None.	<p>Other: The permittee shall maintain deviation reports for a period of five years from the date each report is submitted to the Department. [N.J.A.C. 7:27-22.19(a)] and [N.J.A.C. 7:27-22.19(e)].</p>	<p>Submit a report: As per the approved schedule. The six-month deviation reports for the period from January 1 through June 30 shall be submitted by July 30 of the same calendar year, and for the period from July 1 through December 31, shall be submitted by January 30 of the following calendar year.</p> <p>The annual compliance certification required by N.J.A.C.7:27-22.19(f) may also be considered as your six-month Deviation Report for the period from July 1 – December 31, if submitted by January 30 of the following calendar year.</p> <p>The reports shall be certified pursuant to N.J.A.C. 7:27-1.39 by the responsible official and submitted electronically through the NJDEP online web portal.</p> <p>The NJDEP online web portal can be accessed at: http://www.state.nj.us/dep/online/ . The Compliance Certification forms are available by selecting Documents and Forms and then Periodic Compliance Certification. [N.J.A.C. 7:27-22]</p>
14	<p>Used Oil Combustion: No person shall combust used oil except as authorized pursuant to N.J.A.C. 7:27-20. [N.J.A.C. 7:27-20.2]</p>	None.	None.	<p>Comply with the requirement: Prior to occurrence of event (prior to burning used oil) either register with the Department pursuant to N.J.A.C. 7:27-20.3 or obtain a permit issued by the Department pursuant to N.J.A.C. 7:27-8 or 7:27-22, whichever is applicable. [N.J.A.C. 7:27-20.2(d)]</p>
15	<p>Prevention of Accidental Releases: Facilities producing, processing, handling or storing a chemical, listed in the tables of 40 CFR Part 68.130, and present in a process in a quantity greater than the listed Threshold Quantity, shall comply with all applicable provisions of 40 CFR 68. [40 CFR 68]</p>	Other: Comply with 40 CFR 68. [40 CFR 68].	Other: Comply with 40 CFR 68. [40 CFR 68].	<p>Other (provide description): Other. Comply with 40 CFR 68 as described in the Applicable Requirement. [40 CFR 68]</p>
16	<p>The Department and its authorized representatives shall have the right to enter and inspect any activity subject to N.J.A.C. 7:27-22, or portion thereof, pursuant to N.J.A.C. 7:27-1.31. [N.J.A.C. 7:27-22.16(g)9]</p>	None.	None.	None.
17	<p>The permittee shall pay fees to the Department pursuant to N.J.A.C. 7:27. [N.J.A.C. 7:27-22.16(g)10]</p>	None.	None.	None.

New Jersey Department of Environmental Protection

Facility Specific Requirements

FC

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
18	<p>Each permittee shall meet all requirements of the approved source emissions testing and monitoring protocol during the term of the operating permit.</p> <p>Whenever the permittee makes a replacement, modification, change or repair of a certified CEMS or COMS that may significantly affect the ability of the system to accurately measure or record data, the permittee must recertify the CEMS or COMS in accordance with Section V.B. and Appendix E of Technical Manual 1005.</p> <p>The permittee is responsible for any downtime associated with the replacement, modification, change or repair of the CEMS or COMS. [N.J.A.C. 7:27-22.18(j)]</p>	None.	None.	<p>Comply with the requirement: Upon occurrence of event. The permittee is responsible for contacting the Emission Measurement Section to determine the need for recertification and/or to initiate the recertification process. [N.J.A.C. 7:27-22.18(j)]</p>
19	<p>Each process monitor must be operated at all times when the associated process equipment is operating except during service outage time not to exceed 24 hours per calendar quarter. [N.J.A.C. 7:27-22.16(a)]</p>	None.	<p>Recordkeeping by manual logging of parameter or storing data in a computer data system upon occurrence of event. The permittee must keep a service log to document any outage. [N.J.A.C. 7:27-22.16(o)]</p>	None.
20	<p>Continuous recording for process monitors must be at a sufficient frequency and resolution to be able to document compliance or non-compliance in accordance with Technical Manual 1005 for CEMS (TM1005(B)(3). [N.J.A.C. 7:27-22.16(a)]</p>	None.	None.	None.
21	<p>If an operating permit has expired, the conditions of the operating permit, including the requirements for stack testing, remain enforceable until the operating permit is reissued. [N.J.A.C. 7:27-22.30(j)] and [N.J.A.C. 7:27-22.16(a)]</p>	None.	None.	None.

New Jersey Department of Environmental Protection

Facility Specific Requirements

IS1 No. 2 Fuel Oil Tanks (<10,000 Gallons Capacity)

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
1	Sulfur Content in Fuel <= 2,000 ppmw (0.2 % by weight) for Zone 4 (Essex County). Effective through June 30, 2014. [N.J.A.C. 7:27- 9.2(b)]	Sulfur Content in Fuel: Monitored by review of fuel delivery records per delivery showing fuel sulfur content. [N.J.A.C. 7:27-22.16(o)]	Sulfur Content in Fuel: Recordkeeping by invoices / bills of lading / certificate of analysis per delivery showing fuel sulfur content. [N.J.A.C. 7:27-22.16(o)]	None.
2	Sulfur Content in Fuel <= 500 ppmw (0.05% by weight). Effective July 1, 2014 through June 30, 2016. [N.J.A.C. 7:27- 9.2(b)]	Sulfur Content in Fuel: Monitored by review of fuel delivery records per delivery showing fuel sulfur content. [N.J.A.C. 7:27-22.16(o)]	Sulfur Content in Fuel: Recordkeeping by invoices / bills of lading / certificate of analysis per delivery showing fuel sulfur content. [N.J.A.C. 7:27-22.16(o)]	None.
3	Sulfur Content in Fuel <= 15 ppmw (0.0015% by weight). Effective July 1, 2016. [N.J.A.C. 7:27- 9.2(b)]	Sulfur Content in Fuel: Monitored by review of fuel delivery records per delivery showing fuel sulfur content. [N.J.A.C. 7:27-22.16(o)]	Sulfur Content in Fuel: Recordkeeping by invoices / bills of lading / certificate of analysis per delivery showing fuel sulfur content. [N.J.A.C. 7:27-22.16(o)]	None.
4	Fuel stored in New Jersey that met the applicable maximum sulfur content standard of Tables 1A or 1B of N.J.A.C. 7:27-9.2 at the time it was stored in New Jersey may be used in New Jersey after the operative date of the applicable standard in Table 1B. [N.J.A.C. 7:27- 9.2 (b)]	None.	None.	None.
5	The vapor pressure of the liquid, excluding the vapor pressure of water, shall be less than 0.02 psia at the liquid's actual temperature or at 70 degrees F, whichever is higher. [N.J.A.C. 7:27-22.1]	None.	None.	None.

New Jersey Department of Environmental Protection

Facility Specific Requirements

IS2 Fuel Oil Tank (>10,000 Gallons Capacity)

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
1	Sulfur Content in Fuel <= 2,000 ppmw (0.2 % by weight) for Zone 4 (Essex County). Effective through June 30, 2014. [N.J.A.C. 7:27- 9.2(b)]	Sulfur Content in Fuel: Monitored by review of fuel delivery records per delivery showing fuel sulfur content. [N.J.A.C. 7:27-22.16(o)]	Sulfur Content in Fuel: Recordkeeping by invoices / bills of lading / certificate of analysis per delivery showing fuel sulfur content. [N.J.A.C. 7:27-22.16(o)]	None.
2	Sulfur Content in Fuel <= 500 ppmw (0.05% by weight). Effective July 1, 2014 through June 30, 2016. [N.J.A.C. 7:27- 9.2(b)]	Sulfur Content in Fuel: Monitored by review of fuel delivery records per delivery showing fuel sulfur content. [N.J.A.C. 7:27-22.16(o)]	Sulfur Content in Fuel: Recordkeeping by invoices / bills of lading / certificate of analysis per delivery showing fuel sulfur content. [N.J.A.C. 7:27-22.16(o)]	None.
3	Sulfur Content in Fuel <= 15 ppmw (0.0015% by weight). Effective July 1, 2016. [N.J.A.C. 7:27- 9.2(b)]	Sulfur Content in Fuel: Monitored by review of fuel delivery records per delivery showing fuel sulfur content. [N.J.A.C. 7:27-22.16(o)]	Sulfur Content in Fuel: Recordkeeping by invoices / bills of lading / certificate of analysis per delivery showing fuel sulfur content. [N.J.A.C. 7:27-22.16(o)]	None.
4	Fuel stored in New Jersey that met the applicable maximum sulfur content standard of Tables 1A or 1B of N.J.A.C. 7:27-9.2 at the time it was stored in New Jersey may be used in New Jersey after the operative date of the applicable standard in Table 1B. [N.J.A.C. 7:27- 9.2 (b)]	None.	None.	None.
5	The operating temperature shall not be greater than 350 degrees F. [N.J.A.C. 7:27-22.1]	None.	None.	None.
6	The vapor pressure of the liquid, excluding the vapor pressure of water, shall be less than 0.02 psia at the liquid's actual temperature or at 70 degrees F, whichever is higher. [N.J.A.C. 7:27-22.1]	None.	None.	None.
7	The tank or vessel shall have no visible emissions, exclusive of water vapor, to the outdoor atmosphere. [N.J.A.C. 7:27-22.1]	None.	None.	None.
8	The tank or vessel shall not emit any air contaminants which may cause an odor detectable outside the property boundaries of the facility. [N.J.A.C. 7:27-22.1]	None.	None.	None.
9	The tank or vessel shall not be subject to any NESHAPS, MACT, or NSPS air pollution control standards, excluding the NSPS requirements to maintain a record of the contents of the tank or vessel, the period of storage of these contents, and the maximum true vapor pressure of the liquid stored. [N.J.A.C. 7:27-22.1]	None.	None.	None.
10	The tank's or vessel's potential to emit each TXS and each HAP does not exceed the de minimus reporting thresholds as specified in N.J.A.C. 7:27-22, Appendix. [N.J.A.C. 7:27-22.1]	None.	None.	None.
11	The percentage by weight of all HAPs collectively in the raw material stored in the tank, or mixed or blended in the vessel, is less than 1.0 percent. [N.J.A.C. 7:27-22.1]	None.	None.	None.

New Jersey Department of Environmental Protection

Facility Specific Requirements

IS2 Fuel Oil Tank (>10,000 Gallons Capacity)

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
12	<p>The owner or operator shall have readily available upon Department request a statement certified in accordance with N.J.A.C. 7-27-1.39, signed by the responsible official, as defined at N.J.A.C. 7:27-1.4, that: (1) specifies the contents of the tank; (2) affirms that the tank or vessel meets the applicable requirement and (3) attests that the tank or vessel is in compliance with all other applicable State or federal air pollution requirements. [N.J.A.C. 7:27-22.1]</p>	None.	None.	None.

New Jersey Department of Environmental Protection

Facility Specific Requirements

GR1 Equipment Subject to Federal NSPS Requirements

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
1	For equipment subject to NSPS (E1, E2, E3, E16 and E17), all requests, reports, applications, submittals, and other communications to the Administrator pursuant to Part 60 shall be submitted in duplicate to the Regional Office of US Environmental Protection Agency. Submit information to: Region II, Director, Air and Waste Management Division, US Environmental Protection Agency, 21st Floor, 290 Broadway, New York, NY 10007. [40 CFR 60.4(a)]	None.	None.	Submit a report: As per the approved schedule to EPA Region II as required by 40 CFR 60. [40 CFR 60.4(a)]
2	For equipment E1, E2, E3, E16 and E17, copies of all information submitted to EPA pursuant to 40 CFR Part 60, must also be submitted to the appropriate Regional Enforcement Office of NJDEP. [40 CFR 60.4(b)]	None.	None.	Submit a report: As per the approved schedule to the appropriate Regional Enforcement Office of NJDEP as required by 40 CFR 60. [40 CFR 60.4(b)]
3	The owner or operator subject to the provisions of 40 CFR Part 60 (equipment E1, E2, E3, E16 and E17) shall furnish the Administrator written notification or, if acceptable to both the Administrator and the owner or operator of a source, electronic notification, of any physical or operational change to an existing facility which may increase the emission rate of any air pollutant to which a standard applies, unless that change is specifically exempted under an applicable subpart or in section 60.14(e). The notification shall include information describing the precise nature of the change, present and proposed emission control systems, productive capacity of facility before and after the change and the expected completion date of the change. Notification shall be postmarked within 60 days or as soon as practicable before any change is commenced. The Administrator may request additional relevant information subsequent to this notice. [40 CFR 60.7(a)(4)]	None.	None.	Submit notification: Upon occurrence of event to EPA Region II and the appropriate Regional Enforcement Office of NJDEP as required by 40 CFR 60.7 [40 CFR 60.7(a)(4)]
4	For equipment E1, E2, E3, E16 and E17, the owner or operator shall maintain records of the occurrence and duration of any startup, shutdown, or malfunction in the operation of an affected facility, any malfunction of air pollution control equipment or any periods during which continuous monitoring system or monitoring device is inoperative. [40 CFR 60.7(b)]	None.	Recordkeeping by data acquisition system (DAS) / electronic data storage upon occurrence of event , or manually in a permanently bound logbook. The records should be kept in a permanent form suitable for inspections. [40 CFR 60.7(b)]	None.

New Jersey Department of Environmental Protection

Facility Specific Requirements

GR1 Equipment Subject to Federal NSPS Requirements

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
5	<p>For equipment E1, E2 and E3, each owner or operator required to install a continuous monitoring device shall submit an excess emissions and monitoring systems performance report (excess emissions are defined in applicable subparts) and/or a summary report form (see section 60.7(d)) to the Administrator semiannually, except when: more frequent reporting is specifically required by an applicable subpart; or the Administrator, on a case-by-case basis, determines that more frequent reporting is necessary to accurately assess the compliance status of the source. All reports shall be postmarked by the 30th day following the end of each six-month period. [40 CFR 60.7(c)]</p>	None.	<p>Other: Written records of excess emissions shall include the following information: (1) The magnitude of excess emissions computed in accordance with section 60.13(h), any conversion factor(s) used, and the date and time of commencement and completion of each time period and excess emissions. The process operating time during the reporting period. (2) Specific identification of each period of excess emissions that occurs during startups, shutdowns, and malfunctions of the affected facility. The nature and cause of any malfunction (if known), the corrective action taken or preventative measures adopted. (3) The date and time identifying each period during which the continuous monitoring system was inoperative except for zero and span checks and the nature of the system repairs or adjustments. (4) When no excess emissions have occurred or the continuous monitoring system(s) have not been inoperative, repaired, or adjusted, such information shall be stated in the report.[40 CFR 60.7(c)].</p>	<p>Submit an Excess Emissions and Monitoring Systems Performance Report (EEMPR): Semi-annually on January 31 and July 31 of each year. Additionally, the report shall be submitted to the EPA Region II Administrator and be in the format specified at 40 CFR 60.7(c) and 40 CFR 60.7(d). Written reports of excess emissions shall include all the information included in the written records listed under recordkeeping requirement of this applicable requirement. [40 CFR 60.7(c)]</p>
6	<p>For equipment subject to NSPS CMS requirements (E1, E2 and E3): Each owner or operator required to install a continuous monitoring device shall submit an excess emissions and monitoring systems performance report (excess emissions are defined in applicable subparts) and/or a summary report form (see section 60.7(d)) to the Administrator semiannually, except when: more frequent reporting is specifically required by an applicable subpart; or the Administrator, on a case-by-case basis, determines that more frequent reporting is necessary to accurately assess the compliance status of the source. All reports shall be postmarked by the 30th day following the end of each six-month period. [40 CFR 60.7(c)]</p>	None.	<p>Other: Written records of excess emissions shall include the following information: (1) The magnitude of excess emissions computed in accordance with section 60.13(h), any conversion factor(s) used, and the date and time of commencement and completion of each time period and excess emissions. The process operating time during the reporting period. (2) Specific identification of each period of excess emissions that occurs during startups, shutdowns, and malfunctions of the affected facility. The nature and cause of any malfunction (if known), the corrective action taken or preventative measures adopted. (3) The date and time identifying each period during which the continuous monitoring system was inoperative except for zero and span checks and the nature of the system repairs or adjustments. (4) When no excess emissions have occurred or the continuous monitoring system(s) have not been inoperative, repaired, or adjusted, such information shall be stated in the report.[40 CFR 60.7(c)].</p>	<p>Submit an Excess Emissions and Monitoring Systems Performance Report (EEMPR): Semi-annually beginning on the 30th day of the 6th month following initial performance tests. The report shall be postmarked by the 30th day following the end of each six-month period. The report shall be submitted to the EPA Region II Administrator and the Regional Enforcement Office of NJDEP and be in the format specified at 40 CFR Part 60.7(c) and 40 CFR Part 60.7(d). Written reports of excess emissions shall include all the information included in the written records listed under recordkeeping requirement of this applicable requirement. [40 CFR 60.7(c)]</p>
7	<p>For equipment E1, E2 and E3, the owner or operator shall conduct performance tests and data reduction in accordance with the test methods and procedures contained in each applicable subpart, unless otherwise specified and approved by the Administrator. [40 CFR 60.8(b)]</p>	None.	None.	None.

New Jersey Department of Environmental Protection

Facility Specific Requirements

GR1 Equipment Subject to Federal NSPS Requirements

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
8	For equipment E1, E2 and E3, performance tests shall be conducted under conditions the Administrator specifies to the plant operator based on representative performance of the affected facility. Operations during periods of startup, shutdown and malfunction shall not constitute representative conditions for the purpose of the performance test nor shall emissions in excess of the level of the applicable emission limit be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard. [40 CFR 60.8(c)]	None.	None.	None.
9	For equipment E1, E2 and E3, the owner or operator shall provide the Administrator at least 30 days prior notice of any performance test and shall provide adequate performance testing facilities as specified in 40 CFR Part 60.8(e). [40 CFR 60.8(d)]	None.	None.	None.
10	For equipment E1, E2 and E3, unless otherwise specified in the applicable subpart, each performance test shall consist of three separate runs using the applicable test method. [40 CFR 60.8(f)]	None.	None.	None.
11	For equipment E1, E2 and E3, compliance with NSPS standards specified in this permit, other than opacity, shall be determined only by performance tests established by 40 CFR 60.8, unless otherwise specified in NSPS. [40 CFR 60.11(a)]	None.	None.	None.
12	For equipment subject to the NSPS COM requirement (E1, E2, and E3), the owner or operator shall demonstrate compliance with NSPS opacity standards specified in 40 CFR Part 60. [40 CFR 60.11(b)]	None.	None.	None.
13	For equipment required to conduct visual opacity tests (E16 and E17): The owner or operator shall demonstrate compliance with NSPS opacity standards specified in 40 CFR Part 60, unless otherwise specified and approved by the Administrator. [40 CFR 60.11(b)]	Monitored by visual determination annually, based on 6 minute blocks. Compliance with fugitive ash emission limits shall be based on a series of three one hour observations, performed annually, using EPA Reference Method 22. This is based on the requirement at 40 CFR 60.58b(k). [40 CFR 60.39b(d)]&. [40 CFR 60.11(b)]	Recordkeeping by data acquisition system (DAS) / electronic data storage annually , or manually in a permanently bound logbook. The owner or operator shall maintain records of opacity of emissions based on Method 9 observations. [40 CFR 60.13(h)]	Submit a report: Annually. The owner or operator shall submit results of Method 9 observation data to the Administrator. [40 CFR 60.11(e)(2)]
14	For equipment E1, E2, E3, E16 and E17, the NSPS opacity standard shall apply at all times except during periods of startup, shutdown, malfunctions and as otherwise specified in this permit. [40 CFR 60.11(c)]	None.	None.	None.

New Jersey Department of Environmental Protection

Facility Specific Requirements

GR1 Equipment Subject to Federal NSPS Requirements

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
15	At all times, including periods of start-up, shutdown, and malfunction, owners and operators shall, to the extent practicable, maintain and operate any affected facility (equipment E1, E2, and E3), including associated air pollution control equipment in a manner consistent with good air pollution control practice for minimizing emissions. Determination of whether acceptable operating and maintenance procedures are being used will be based on information available to the Administrator which may include, but is not limited to, monitoring results, opacity observations, review of operation and maintenance procedures, and inspection of the source. [40 CFR 60.11(d)]	None.	None.	None.
16	No owner or operator subject to NSPS standards in Part 60, shall build, erect, install, or use any article, machine, equipment or process, the use of which conceals an emission which would otherwise constitute a violation of an applicable standard. Such concealment includes, but is not limited to, the use of gaseous diluents to achieve compliance with an opacity standard or with a standard which is based on the concentration of a pollutant in the gases discharged to the atmosphere. [40 CFR 60.12]	None.	None.	None.
17	Opacity: For equipment E1, E2, and E3, the owners and operators of a COMS installed in accordance with the provisions of 40 CFR 60, must automatically, intrinsic to the opacity monitor, check the zero and upscale (span) calibration drifts at least once daily. For a particular COMS, the acceptable range of zero and upscale calibration materials is as defined in the applicable version of PS-1 in appendix B of this part. For a COMS, the optical surfaces, exposed to the effluent gases, must be cleaned before performing the zero and upscale drift adjustments, except for systems using automatic zero adjustments. The optical surfaces must be cleaned when the cumulative automatic zero compensation exceeds 4 percent opacity. [40 CFR 60.13(d)(1)]	None.	Other: Maintain records in accordance with 40 CFR 60.7(f).[40 CFR 60.13(d)].	None.
18	Opacity: Unless otherwise approved by the Administrator, the following procedures must be followed for a COMS. Minimum procedures must include an automated method for producing a simulated zero opacity condition and an upscale opacity condition using a certified neutral density filter or other related technique to produce a known obstruction of the light beam. Such procedures must provide a system check of all active analyzer internal optics with power or curvature, all active electronic circuitry including the light source and photodetector assembly, and electronic or electro-mechanical systems and hardware and or software used during normal measurement operation. [40 CFR 60.13(d)(2)]	None.	Other: Maintain records in accordance with 40 CFR 60.7(f).[40 CFR 60.13(d)].	None.

New Jersey Department of Environmental Protection

Facility Specific Requirements

GR1 Equipment Subject to Federal NSPS Requirements

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
19	Except for system breakdowns, repairs, calibration checks, and zero and span adjustments, all continuous opacity monitoring systems shall be in continuous operation for equipment E1, E2, and E3. They shall complete a minimum of one cycle of sampling and analyzing for each successive 10-second period and one cycle of data recording for each successive 6-minute period. [40 CFR 60.13(e)(1)]	Other: See Applicable Requirement. [40 CFR 60.13(e)(1)].	Other: See Applicable Requirement. [40 CFR 60.13(e)(1)].	None.
20	Except for system breakdowns, repairs, calibration checks, and zero and span adjustments, all continuous monitoring systems measuring emissions except opacity shall be in continuous operation for equipment E1, E2, and E3. They shall complete a minimum of one cycle of operation (sampling, analyzing and data recording) for each successive 15-minute period. [40 CFR 60.13(e)(2)]	Other: See Applicable Requirement. [40 CFR 60.13(e)(2)].	Other: See Applicable Requirement. [40 CFR 60.13(e)(2)].	None.
21	All continuous monitoring systems or monitoring devices shall be installed such that representative measurements of emissions or process parameters from the affected facility (equipment E1, E2, and E3) are obtained. Procedures for location of continuous monitoring systems contained in the applicable Performance Specifications of Appendix B of 40 CFR Part 60 shall be used. [40 CFR 60.13(f)]	None.	None.	None.
22	For equipment E1, E2, and E3, the owner or operator shall reduce all continuous monitoring systems for measuring opacity data to 6-minute averages which shall be calculated from 36 or more data points equally spaced over each 6-minute period. Data recorded during periods of continuous monitoring system breakdowns, repairs, calibration checks, and zero and span adjustments shall not be included in the data averages computed under this paragraph. For owners and operators complying with the requirements in 40 CFR 60.7(f)(1) or (2), data averages must include any data recorded during periods of monitor breakdown or malfunction. An arithmetic or integrated average of all data may be used. The data may be recorded in reduced or nonreduced form (e.g., ppm pollutant and percent O2 or ng of pollutant per J of heat input). All excess emissions shall be converted into units of the standard using the applicable conversion procedures specified in subparts. After conversion into units of the standard, the data may be rounded to the same number of significant digits as used in the applicable subparts to specify the emission limit (e.g. rounded to the nearest 1 percent opacity). [40 CFR 60.13(h)]	None.	Other: See Applicable Requirement. [40 CFR 60.13(h)].	None.

New Jersey Department of Environmental Protection

Facility Specific Requirements

GR1 Equipment Subject to Federal NSPS Requirements

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
23	<p>For equipment E1, E2, and E3, the owner or operator shall reduce all continuous monitoring systems (other than opacity) data to 1-hour averages which shall be computed from four or more data points equally spaced over each 1-hour period. Data recorded during periods of continuous monitoring system breakdowns, repairs, calibration checks, and zero and span adjustments shall not be included in the data averages computed under this paragraph. For owners and operators complying with the requirements in 40 CFR 60.7(f)(1) or (2), data averages must include any data recorded during periods of monitor breakdown or malfunction. An arithmetic or integrated average of all data may be used. The data may be recorded in reduced or nonreduced form (e.g., ppm pollutant and percent O₂ or ng of pollutant per J of heat input). All excess emissions shall be converted into units of the standard using the applicable conversion procedures specified in subparts. After conversion into units of the standard, the data may be rounded to the same number of significant digits as used in the applicable subparts to specify the emission limit (e.g. rounded to the nearest 1 percent opacity). [40 CFR 60.13(h)]</p>	None.	Other: See Applicable Requirement. [40 CFR 60.13 (h)].	None.
24	<p>Changes in time periods for submittal of information and postmark deadlines set forth in this subpart, may be made only upon approval by the Administrator and shall follow procedures outlined in 40 CFR Part 60.19. [40 CFR 60.19]</p>	None.	None.	None.

New Jersey Department of Environmental Protection

Facility Specific Requirements

U1 MWC #1, 2, 3 Municipal Waste Combustors (E1, E2, and E3) OS SUMMARY

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
1	<p>STACK TESTING SUMMARY The permittee shall conduct stack tests using an approved protocol to demonstrate compliance with emission limits for pollutants named and at the frequency specified in the following applicable requirements.</p> <p>Testing must be conducted at worst-case permitted operating conditions with regard to meeting the applicable emission standards, but without creating an unsafe condition. The permittee may propose, in the stack test protocol, to use CEMS data to satisfy the stack testing requirements, for NOx, CO or SO2, with BTS approval. In order for BTS to approve using CEMS data at the time of the stack test, the CEMS must be certified and be in compliance with all daily, quarterly and annual quality assurance requirements. The CEMS shall monitor and record emissions in units identical to those required by the applicable stack testing conditions of this permit. CEMS data, if allowed by this permit, shall be taken at the same worst case conditions as described above. [N.J.A.C. 7:27-22.16(a)]</p>	<p>Other: Monitoring as required by this OS Summary or under the applicable operating scenario(s). [N.J.A.C. 7:27-22.16(o)].</p>	<p>Recordkeeping by stack test results upon occurrence of event. Recordkeeping as required by this OS Summary or under the applicable operating scenario(s). [N.J.A.C. 7:27-22.16(o)]</p>	<p>Stack Test - Submit protocol, conduct test and submit results: As per the approved schedule, i.e., as required by the OS Summary or Operating Scenario conditions elsewhere in this permit. [N.J.A.C. 7:27-22.16(o)]</p>
2	<p>STACK TESTING REQUIREMENTS: For facilities demonstrating compliance with 40 CFR 62, Subpart FFF standards, the owner or operator shall conduct annual performance tests no less than 9 calendar months and no more than 15 calendar months following the previous performance test; and must complete 5 performance tests in each 5-year calendar period. From BOP090003. [40 CFR 62.14109(a)] & [40 CFR 60.58(b)]</p>	<p>Monitored by stack emission testing annually, based on each of three Department validated stack test runs. [40 CFR 60.58(b)(c)]</p>	<p>Recordkeeping by stack test results annually. [40 CFR 60.59(b)]</p>	<p>Stack Test - Submit protocol, conduct test and submit results: As per the approved schedule Stack test report must be submitted within 60 days after performing the test. [40 CFR 60.58(b)]</p>
3	<p>STACK TESTING REQUIREMENTS: Conduct annual stack tests on each municipal solid waste combustor to demonstrate compliance with the lead and cadmium emission limits. Stack testing is as required at 40 CFR 60.58b(d). [N.J.A.C. 7:27-22.16 (o)], [40 CFR 60.39b(d) & (f)] & [40 CFR 62.14109(b)]</p>	<p>Monitored by stack emission testing annually, based on the average of three tests (as a minimum.) Stack testing for lead and cadmium (using EPA Method 29) shall be as required at 40 CFR 60.58b(d)(1). [N.J.A.C. 22.16(o)], [40 CFR 60.39b(d) & (f)] & [40 CFR 62.14109(b)]</p>	<p>Recordkeeping by stack test results upon occurrence of event. All records shall be maintained onsite in either paper copy or computer-readable format. This is as indicated in 40 CFR 60.59b(d)(9)(i) and 40 CFR 60.59b(d)(k). [N.J.A.C. 7:27-22.16(o)], [40 CFR 60.39b(d) & (f)] & [40 CFR 62.14109(a)]</p>	<p>Stack Test - Submit protocol, conduct test and submit results: As per the approved schedule. For all tests, the permittee must contact BTS at 609-530-4041 to schedule a mutually acceptable test date which shall be no later than 15 months after the previous test. Stack test reports must be submitted to BTS within 60 days after performing the stack test pursuant to N.J.A.C. 7:27-22.19(d). The test results must be certified by a licensed professional engineer or certified industrial hygienist.</p> <p>Test results shall report lbs/hour, lbs/MM Btu, ppm (as needed).</p> <p>As indicated in 40 CFR 59b(g)(1), a list of the emission levels achieved during performance tests shall be included in the semi annual report submitted pursuant to 40 CFR 60.39b(d), 40 CFR 60.39b(f), and 40 CFR 14109(a). [N.J.A.C. 7:27-22.18(e)], [N.J.A.C. 7:27-22.18(h)], [40 CFR 60.39b(d) & (f)], & [40 CFR 62.14109(a)]</p>

New Jersey Department of Environmental Protection

Facility Specific Requirements

**U1 MWC #1, 2, 3 Municipal Waste Combustors (E1, E2, and E3)
OS SUMMARY**

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
4	<p>STACK TESTING REQUIREMENTS: Conduct annual stack tests on each municipal solid waste combustor to determine compliance with HCl emission limits. [N.J.A.C. 7:27-22.16(e)], [40 CFR 60.39b(f)] & [40 CFR 62.14109 (b)]</p>	<p>Monitored by stack emission testing annually, based on the average of three Department validated stack test runs to determine compliance with emission limits pursuant to N.J.A.C. 7:27-22.16(e), and the average of a minimum of three tests to determine compliance with emission limits pursuant to 40 CFR 60.39b(f) and 40 CFR 62.14103(b)(2). Stack testing for HCl (using EPA Method 26 or 26A) shall satisfy the requirements at 40 CFR 60.58b(f). [N.J.A.C. 7:27-22.16(e)], 40 CFR 60.39b (f), & [40 CFR 62.14109(b)]</p>	<p>Recordkeeping by stack test results upon occurrence of event. All records shall be maintained onsite in either paper copy or computer-readable format. This is as indicated in 40 CFR 60.59b(d)(9)(i) and 40 CFR 60.59b(d)(k). [N.J.A.C. 7:27-22.16(o)], [40 CFR 60.39b(f)] & [40 CFR 62.14109(a)]</p>	<p>Stack Test - Submit protocol, conduct test and submit results: As per the approved schedule. For all tests, the permittee must contact BTS at 609-530-4041 to schedule a mutually acceptable test date which shall be no later than 15 months after the previous test. A full stack test report must be submitted to BTS and a certified summary test report, as described in the protocol, must be submitted to the Regional Enforcement Office within 60 days after performing the stack test pursuant to N.J.A.C. 7:27-22.19(d). The test results must be certified by a licensed professional engineer or certified industrial hygienist. Test results shall report lbs/hour, lbs/MM Btu, ppm (as needed). As indicated in 40 CFR 59b(g)(1), a list of the emission levels achieved during performance tests shall be included in the semi annual report submitted pursuant to 40 CFR 60.39b(f) and 40 CFR 14109(a). [N.J.A.C. 7:27-22.18(e)], [N.J.A.C. 7:27-22.18(h)], [40 CFR 60.39b(f)], & [40 CFR 62.14109(a)]</p>
5	<p>STACK TESTING REQUIREMENTS: Conduct annual stack tests for dioxins/furans. Total polychlorinated dibenzodioxins emissions and total polychlorinated dibenzofurans (dioxins/furans) must be measured using EPA Reference Method 23. This is as indicated at 40 CFR 60.59b(g)(3). [N.J.A.C. 7:27-22.16(o)], [40 CFR 60.39b(d)]& [40 CFR 62.14109(b)]</p>	<p>Monitored by stack emission testing annually, based on the average of three tests. Minimum sample time shall be 4 hours per run, using EPA Test Method 23 specified at 40 CFR 60.58b(g)(3) & (5), except that: Where all performance tests over a 2-year period indicate that dioxin/furan emissions are <= 15 ng/dscm corrected to 7% O2 (total mass) for all units, the facility may elect to conduct annual performance tests in one unit per year. At a minimum, a performance test for dioxin/furan emissions shall be conducted annually (no more than 12 months following the previous performance test) on one unit. Each year a different unit shall be tested, and the units shall be tested in sequence (e.g., unit 1, unit 2, unit 3) as long as each test indicates an emission level less than or equal to 15 ng/dscm (total mass). If test indicates a dioxin/furan emission level greater than 15 ng/dscm corrected to 7% O2 (total mass), performance tests thereafter shall be conducted annually on all units until and unless all annual performance tests for all units over a 2-year period indicate a dioxin/furan emission level less than or equal to 15 ng/dscm corrected to 7% O2 (total mass). [N.J.A.C. 7:27-22.16(o)], [40 CFR 60.39b(d)], [40 CFR 62.14109(b)] & [40 CFR 62.14109 (d)(1)]</p>	<p>Recordkeeping by stack test results upon occurrence of event. All records shall be maintained onsite in either paper copy or computer-readable format. This is as specified at 40 CFR 60.59b(d)(9)(i) and 40 CFR 60.59b(k). [N.J.A.C. 22.16(o)], [40 CFR 60.39b(d)] & [40 CFR 62.14109(a)]</p>	<p>Stack Test - Submit protocol, conduct test and submit results: As per the approved schedule. For all tests, the permittee must contact BTS at 609-530-4041 to schedule a mutually acceptable test date which shall be no later than 15 months after the previous test. A full stack test report must be submitted to BTS and a certified summary test report, as described in the protocol, must be submitted to the Regional Enforcement Office within 60 days after performing the stack test pursuant to N.J.A.C. 7:27-22.19(d). The test results must be certified by a licensed professional engineer or certified industrial hygienist. Test results shall report lbs/hour, lbs/MM Btu, ppm, ng/dscm (as needed). Emission rates of each congener which contains 4 or more chlorine atoms shall be reported. As indicated in 40 CFR 59b(g)(1), a list of the emission levels achieved during performance tests shall be included in the semi annual report submitted pursuant to 40 CFR 60.39b(d), 40 CFR 60.39b(f), and 40 CFR 14109(a). [N.J.A.C. 7:27-22.16(o)], [N.J.A.C. 7:27-22.18(e)], [N.J.A.C. 7:27-22.18(h)], [40 CFR 60.39b(d)], [40 CFR 60.39b(f)], & [40 CFR 62.14109 (a)]</p>

New Jersey Department of Environmental Protection

Facility Specific Requirements

U1 MWC #1, 2, 3 Municipal Waste Combustors (E1, E2, and E3) OS SUMMARY

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
6	<p>STACK TESTING REQUIREMENTS: Conduct annual stack tests on each municipal solid waste combustor to demonstrate compliance with the particulate emission limits, by:</p> <ul style="list-style-type: none"> i. Three test runs to determine TSP; ii. Three test runs for PM-10 and PM 2.5 (including back half condensibles). <p>[N.J.A.C. 7:27-22.16(a)], [N.J.A.C. 7:27-22.16(e)], [40 CFR 60.39b(d)]& [40 CFR 62.14109(b)]</p>	<p>Monitored by stack emission testing annually, based on the average of three Department validated stack test runs conducted successively. Compliance with all TSP emission limits (except for the limit which stipulates boiler soot blowing) pursuant to N.J.A.C. 7:27-22.16(e) and 40 CFR 62.14103(a)(1) shall be determined by each of three EPA Method 5 test runs indicated in (i) of the applicable requirement, as required in the preconstruction permit and 40 CFR 60.58b(c). Compliance with the emission limit pursuant to N.J.A.C. 7:27-11 shall be determined from the worst-case run indicated in (ii) of the applicable requirement. Compliance with the PM-10 limits stipulated under N.J.A.C. 7:27-22.16(e) will be determined from the front and back-half of the PM-10 train by the average of the three EPA method 201A and 202 test runs indicated in (iii) of the applicable requirement. PM 2.5 shall be determined with the same methods. [N.J.A.C. 7:27-22.16(o)], [N.J.A.C. 7:27-22.16(e)], [40 CFR 60.39b(d)] and. [40 CFR 62.14109(b)]</p>	<p>Recordkeeping by stack test results upon occurrence of event. All records shall be maintained onsite in either paper copy or computer-readable format. This is as specified at 40 CFR 60.59b(d)(9)(i) and 40 CFR 60.59b(k). [N.J.A.C. 22.16(e)], [40 CFR 60.39b(d)] and. [40 CFR 62.14109(a)]</p>	<p>Stack Test - Submit protocol, conduct test and submit results: As per the approved schedule. For all tests, the permittee must contact BTS at 609-530-4041 to schedule a mutually acceptable test date which shall be no later than 15 months after the previous test. Stack test reports must be submitted to BTS within 60 days after performing the stack test pursuant to N.J.A.C. 7:27-22.19(d). The test results must be certified by a New Jersey licensed professional engineer or certified industrial hygienist. Test results shall report lbs/hour, gr/dscf, ppm (as needed). As indicated in 40 CFR 60.59b(g)(1), a list of the emission levels achieved during performance tests shall be included in the semi annual report submitted pursuant to 40 CFR 60.39b(d), 40 CFR 60.39b(f), and 40 CFR 14109(a). [N.J.A.C. 7:27-22.16(o)], [N.J.A.C. 7:27-22.18(e)], [N.J.A.C. 7:27-22.18(h)], [40 CFR 60.39b(d)], [40 CFR 60.39b(f)], and. [40 CFR 62.14109(a)]</p>
7	<p>STACK TESTING REQUIREMENTS: The permittee shall conduct annual stack emission testing for mercury on each municipal solid waste combustor at the inlet and outlet simultaneously to satisfy the requirements under N.J.A.C. 7:27-22.16(e), N.J.A.C. 7:27-27.4 and 40 CFR 60.58b(d)(2). [N.J.A.C. 7:27-22.16(e)], [N.J.A.C. 7:27-27.4], [40 CFR 60.39b(d)], & [40 CFR 62.14109(b)]</p>	<p>Monitored by stack emission testing annually, based on the average of three Department validated stack test runs using EPA Reference Method 29. The tests for mercury shall consist of a minimum of three source emission tests to measure mercury in the gas stream at the inlet of the air pollution control apparatus serving each combustion unit, and simultaneously perform three source emission tests to measure mercury in the gas stream at the exit of the control apparatus. If source emission testing fails to demonstrate compliance with the applicable requirement, then the frequency of source testing shall increase to three source emission tests quarterly. In this case, there shall be at least a 45 calendar day interval between the testing performed for a given quarter and the testing performed for the preceding quarter, unless a shorter period is approved by the Department. If compliance with the applicable requirement is then achieved and maintained during two consecutive years, the permittee may again reduce the frequency of source emission testing from three source emission tests performed quarterly to three source emission tests performed annually, not necessarily in the first quarter of each calendar year (from modification BOP080002.) Testing shall also satisfy the requirements at 40 CFR 60.58b(d)(2), which requires annual testing. [N.J.A.C. 7:27-27.4(c)], [40 CFR 60.39b(d)]&. [40 CFR 62.14109(b)]</p>	<p>Recordkeeping by stack test results upon occurrence of event. All records shall be maintained onsite in either paper copy or computer-readable format. This is as indicated in 40 CFR 60.59b(d)(9)(i) and 40 CFR 60.59b(d)(k). [N.J.A.C. 7:27-22.16(o)], [40 CFR 60.39b(d)], [40 CFR 60.39b(f)] &. [40 CFR 62.14109(a)]</p>	<p>Stack Test - Submit protocol, conduct test and submit results: As per the approved schedule. For all tests, the permittee must contact BTS at 609-530-4041 to schedule a mutually acceptable test date which shall be no later than 15 months after the previous test. A full stack test report must be submitted to BTS and a certified summary test report, as described in the protocol, must be submitted to the Regional Enforcement Office within 60 days after performing the stack test pursuant to N.J.A.C. 7:27-22.19(d). The test results must be certified by a licensed professional engineer or certified industrial hygienist. Test results shall report lbs/hour, ug/dscm, as needed. As indicated in 40 CFR 59b(g)(1), a list of the emission levels achieved during performance tests shall be included in the semi annual report submitted pursuant to 40 CFR 60.39b(d), 40 CFR 60.39b(f), and 40 CFR 14109(a). [N.J.A.C. 7:27-22.16(o)], [N.J.A.C. 7:27-22.18(e)], [N.J.A.C. 7:27-22.18(h)], [40 CFR 60.39b(d)], [40 CFR 60.39b(f)], &. [N.J.A.C. 7:27-27.4(f)]</p>

New Jersey Department of Environmental Protection

Facility Specific Requirements

U1 MWC #1, 2, 3 Municipal Waste Combustors (E1, E2, and E3) OS SUMMARY

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
8	<p>STACK TESTING REQUIREMENTS: The permittee shall conduct stack tests on each municipal solid waste combustor using an approved protocol within one year prior to the expiration of the renewed operating permit to demonstrate compliance with the SO₂, nitrogen oxides, SO₃ + H₂SO₄ (as converted and expressed as H₂SO₄), Volatile Organic Compounds (VOC), Arsenic, Beryllium, Chromium, Nickel, Ammonia, and TCDD (2,3,7,8-) emission limits. In addition, tests for polycyclic aromatic hydrocarbons (or polycyclic organic matter), Benzo (A) Pyrene, carbon tetrachloride, formaldehyde, perchloroethylene (tetrachloroethylene), trichloroethylene and vinyl chloride emissions must be conducted. [From modification BOP080002.] [N.J.A.C. 7:27-22.16(a)]</p>	<p>Monitored by stack emission testing prior to permit renewal, based on the average of three Department validated stack test runs. Stack test shall be conducted for SO₂, nitrogen oxides, SO₃+H₂SO₄ (as converted and expressed as H₂SO₄), VOC, Ammonia, Arsenic, Beryllium, Chromium, Nickel, and TCDD (2,3,7,8-) emission limits. In addition, tests for polycyclic aromatic hydrocarbons (or polycyclic organic matter), Benzo (A) Pyrene, carbon tetrachloride, formaldehyde, perchloroethylene (tetrachloroethylene), trichloroethylene and vinyl chloride emissions must be conducted. This is based on the preconstruction permit. [N.J.A.C. 7:27-22.16(e)]</p>	<p>Recordkeeping by stack test results upon occurrence of event based on the preconstruction permit. [N.J.A.C. 7:27-22.16(e)]</p>	<p>Stack Test - Submit protocol, conduct test and submit results: As per the approved schedule (before one year prior to renewal of this operating permit.) Stack testing shall be performed using approved protocols. For all tests, the permittee must contact BTS at 609-530-4041 to schedule a mutually acceptable test date which shall be no later than five years after the previous test. A full stack test report must be submitted to BTS and a certified summary test report, as described in the protocol, must be submitted to the Regional Enforcement Office within 60 days after performing the stack test pursuant to N.J.A.C. 7:27-22.19(d). The test results must be certified by a licensed professional engineer or certified industrial hygienist.</p> <p>Test results shall report lbs/hour, lbs/MM Btu, ppm (as needed) [N.J.A.C. 7:27-22.18(e)] & [N.J.A.C. 7:27-22.18(h)]</p>
9	<p>STACK TESTING REQUIREMENTS: The permittee shall conduct stack tests on each municipal solid waste combustor using an approved protocol within one year prior to the expiration of the renewed operating permit to demonstrate compliance with the 1-hour CO and HF emission limits. [From modification BOP080002.] [N.J.A.C. 7:27-22.16(a)]</p>	<p>Monitored by stack emission testing prior to permit expiration date, based on each of three Department validated stack test runs using EPA Method 10 for CO and EPA Method 13A for HF, or methods approved by the Department and EPA, based on the preconstruction permit. [N.J.A.C. 7:27-22.16(e)]</p>	<p>Recordkeeping by stack test results upon occurrence of event based on the preconstruction permit. [N.J.A.C. 7:27-22.16(e)]</p>	<p>Stack Test - Submit protocol, conduct test and submit results: As per the approved schedule (before one year prior to renewal of this operating permit.) Stack testing shall be performed using approved protocols. For all tests, the permittee must contact BTS at 609-530-4041 to schedule a mutually acceptable test date which shall be no later than five years after the previous test. A full stack test report must be submitted to BTS and a certified summary test report, as described in the protocol, must be submitted to the Regional Enforcement Office within 60 days after performing the stack test pursuant to N.J.A.C. 7:27-22.19(d). The test results must be certified by a licensed professional engineer or certified industrial hygienist.</p> <p>Test results shall report lbs/hour, lbs/MM Btu, ppm (as needed) [N.J.A.C. 7:27-22.18(e)] & [N.J.A.C. 7:27-22.18(h)]</p>
10	<p>These municipal waste incinerators are each subject to the 40 CFR 60 Subpart Cb Emission Guidelines and Compliance Times for Large Municipal Waste Combustors that were Constructed on or Before September 20, 1994. Compliance with all applicable portions of this regulation is required. [40 CFR 60.32(b)]</p>	<p>None.</p>	<p>None.</p>	<p>None.</p>
11	<p>The operating practices in this OP shall be at least as protective as those requirements listed in 40 CFR 60.53b(b) and (c) of subpart Eb [40 CFR 60.35b]</p>	<p>None.</p>	<p>None.</p>	<p>None.</p>
12	<p>The municipal waste combustor operator training and certification shall be at least as protective as those requirements listed in 40 CFR 60.54b of subpart Eb. The compliance with these requirements shall be according to the schedule specified in 40 CFR 60.39b(c)(4). [40 CFR 60.35b]</p>	<p>None.</p>	<p>None.</p>	<p>None.</p>

New Jersey Department of Environmental Protection

Facility Specific Requirements

U1 MWC #1, 2, 3 Municipal Waste Combustors (E1, E2, and E3) OS SUMMARY

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
13	Municipal waste combustor fugitive ash emissions shall be at least as protective as those requirements listed in 40 CFR 60.55b of subpart Eb. [40 CFR 60.36b]	None.	None.	None.
14	This OP shall include performance testing methods listed in 40 CFR 60.58b subpart Eb, as applicable, except as provided for under 40 CFR 60.24(b)(2) of subpart B and paragraphs 38b(b). Reporting and recordkeeping provisions listed in 40 CFR 60.59b of subpart Eb, as applicable, except for the siting requirements under 40 CFR 60.59b(a), (b)(5), and (d) (11) of subpart Eb. [40 CFR 60.38b(a)]	None.	None.	None.
15	This OP shall continue to require meeting the revised April 28, 2009 emission limits in 40 CFR 60.33b(a), (c), and (d) and the revised testing provisions in 40 CFR 60.38b(b) [Where all performance tests over a 2-year period indicate that dioxin/furan emissions are less than or equal to 15 nanograms per dry standard cubic meter (total mass) for all affected facilities located within a municipal waste combustor plant] [40 CFR 60.39b(g)]	None.	None.	None.
16	The facility is not subject to the nitrogen oxide standards in the NSPS for industrial boilers (40 CFR, Part 60, Subpart Db) since any facility covered by an EPA approved State or Federal section 111(d)/129 plan implementing Subpart Cb or subpart BBBB of this part is not covered by subpart Db. [40 CFR 60.40b(l)]	None.	None.	None.
17	These municipal waste incinerators meeting the applicability requirements under section 40 CFR 60.32b are not subject to subpart E of 40 CFR 60 in accordance with the final rule (Subpart Cb) dated May 10, 2006 (at 71 FR 27333.) [40 CFR 60.32b(n)]	None.	None.	None.
18	The facility is not subject to the NESHAP for beryllium (40 CFR Part 61, Subpart C), and shall not accept any beryllium containing waste as defined in 40 CFR 61.31 (g). [N.J.A.C. 7:27-22.16(e)]	Other: Waste contents. Per delivery. [N.J.A.C. 7:27-22.16(a)].	Other: Waste manifests. Per Delivery. [N.J.A.C. 7:27-22.16(o)].	None.
19	The three municipal solid waste units are subject to the emission guidelines codified at 40 CFR 62 Subpart FFF, Federal Plan Requirements for Large Municipal Waste Combustors Constructed on or Before September 20, 1994. Compliance with all applicable portions of these Subparts is required. [40 CFR 62.14100]	None.	None.	None.
20	Particulate Emissions <= 42.3 lb/hr. Maximum emission rate for each MWC from the table at N.J.A.C. 7:27-4.2 (a), based on the Maximum Gross Heat input. Emission limit applies at all times, including startup and shutdown. [N.J.A.C. 7:27-4.2(a)]	None.	None.	None.

New Jersey Department of Environmental Protection

Facility Specific Requirements

U1 MWC #1, 2, 3 Municipal Waste Combustors (E1, E2, and E3) OS SUMMARY

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
21	SO2 <= 2,000 ppmv at standard conditions. Emission limit applies at all times, including startup and shutdown. [N.J.A.C. 7:27- 7.2(b)1]	None.	None.	None.
22	SO2 <= 1,100 lb/hr for each MWC (in any 60-minute period), based on the calculation procedure at N.J.A.C. 7:27-7.2(r). Emission limit applies at all times, including startup and shutdown. [N.J.A.C. 7:27- 7.2(b)2]	None.	None.	None.
23	SO2 <= 2,200 lb/hr for each MWC at any instant, based on the calculation procedure at N.J.A.C. 7:27-7.2(r). Emission limit applies at all times, including startup and shutdown. [N.J.A.C. 7:27- 7.2(b)2]	None.	None.	None.
24	SO3 and H2SO4, as converted and expressed as H2SO4 <= 10 mg/ft ³ at standard conditions. Emission limit applies for each MWC at all times, including startup and shutdown. [N.J.A.C. 7:27- 7.2(g)1]	None.	None.	None.
25	SO3 and H2SO4, as converted and expressed as H2SO4 <= 260 lb/hr in any 60-minute period, based on the calculation procedure at N.J.A.C. 7:27-7.2(r). Emission limit applies at all times, including startup and shutdown. [N.J.A.C. 7:27- 7.2(g)2]	None.	None.	None.
26	SO3 and H2SO4, as converted and expressed as H2SO4 <= 520 lb/hr at any instant, based on the calculation procedure at N.J.A.C. 7:27-7.2(r). Emission limit applies at all times for each MWC, including startup and shutdown. [N.J.A.C. 7:27- 7.2(g)2]	None.	None.	None.
27	SO2 <= 1.2 lb/MMBTU gross heat input determined as a 30-day rolling average. No person shall expand or reconstruct an existing solid fuel-fired steam generating unit or construct a new solid fuel-fired steam generating unit having a rated hourly capacity that exceeds, or would exceed, as a result of expansion, construction, and/or reconstruction, 250,000,000 British Thermal Units (BTU) gross heat input unless the sulfur dioxide emissions, if the unit is a resource recovery facility, do not exceed the above limit. This limit applies to eligible resource recovery units. Emission limit applies for each MWC at all times, including startup and shutdown. [N.J.A.C. 7:27-10.3(a)3]	SO2: Monitored by continuous emission monitoring system continuously, based on a 1 hour block average. Stack test shall demonstrate that standard is assured by continuous emission monitoring of SO2 in ppmvd. [From Renewal BOP0800001.] Compliance with the standard shall be determined in accordance with the provisions of 40 CFR Part 60 Subpart Da, noted below: For affected facilities for which construction, modification, or reconstruction commenced before May 4, 2011, compliance with applicable 30-boiler operating day rolling average SO2 emissions limits is determined by calculating the arithmetic average of all hourly emission rates for SO2 for the 30 successive boiler operating days, except for data obtained during startup, shutdown, or malfunction. [40 CFR 60.48Da(d)] &. [N.J.A.C. 7:27-10.3(b)]	SO2: Recordkeeping by data acquisition system (DAS) / electronic data storage continuously for daily compliance and by stack test records upon occurrence of event. [N.J.A.C. 7:27-22.16(o)]	None.
28	Particulate Emissions <= 0.1 gr/dscf @ 12% CO2 (including ash, excluding the contribution of auxiliary fuel). Emission limit applies for each MWC at all times, including startup and shutdown. [N.J.A.C. 7:27-11.3(a)4]	Particulate Emissions: Monitored by stack emission testing prior to permit expiration date, based on the average of three Department validated stack test runs. See stack testing requirements in U1 OS0. [N.J.A.C. 7:27-22.16(o)]	Particulate Emissions: Recordkeeping by stack test results upon occurrence of event. See stack testing requirements in U1 OS0. [N.J.A.C. 7:27-22.16(o)]	Stack Test - Submit protocol, conduct test and submit results: As per the approved schedule. See stack testing requirements in U1 OS0. [N.J.A.C. 7:27-22.16(o)]

New Jersey Department of Environmental Protection

Facility Specific Requirements

U1 MWC #1, 2, 3 Municipal Waste Combustors (E1, E2, and E3) OS SUMMARY

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
29	Opacity <= 1 Ringlemann Smoke Chart. Emission limit applies for each MWC at all times, including startup and shutdown. [N.J.A.C. 7:27-11.3(b)2ii]	Opacity: Monitored by stack emission testing prior to permit expiration date, based on the average of three Department validated stack test runs. See stack testing requirements in U1 OS0. [N.J.A.C. 7:27-11.3]	Opacity: Recordkeeping by stack test results upon occurrence of event. See stack testing requirements in U1 OS0. [N.J.A.C. 7:27-11.3]	Stack Test - Submit protocol, conduct test and submit results: As per the approved schedule See stack testing requirements in U1 OS0. [N.J.A.C. 7:27-11.3]
30	The provisions of 7:27-11.3(b)(2) shall not apply to: 1. Smoke emitted during the building of a new fire, the shade or appearance of which is not greater than Number 2 of the Ringelmann smoke chart for a period of three consecutive minutes; or ii. Emissions of such opacity within a stack or chimney to a degree greater than the emission designated as Number 2 of the Ringelmann smoke chart for a period not greater than three consecutive minutes. [N.J.A.C. 7:27-11.3(b)3]	None.	None.	None.
31	No person shall cause, suffer, allow or permit the emission of particles of unburned waste or ash from any common incinerator or from any special incinerator which are individually large enough to be visible while suspended in the atmosphere. Emission limit applies at all times, including startup and shutdown. [N.J.A.C. 7:27-11.3(c)]	None.	None.	None.
32	Odor: No person shall construct, install, use or cause to be used any common incinerator or any special incinerator which will result in odors being detectable by sense of smell in any area of human use or occupancy. Emission limit applies at all times, including startup and shutdown. [N.J.A.C. 7:27-11.3(d)]	None.	None.	None.
33	Any person responsible for the use of an incinerator shall when ordered by the Department, provide the facilities and necessary equipment for determining the density of smoke being discharged from a stack or chimney and shall conduct such smoke tests using methods approved by the Department. Emission limit applies at all times, including startup and shutdown. [N.J.A.C. 7:27-11.3(e)1]	None.	Other: All smoke test data shall be recorded in a permanent log at such time intervals as specified by the Department. Data shall be maintained for a period of not less than one year and shall be available for review by the Department.[N.J.A.C. 7:27-11.3(e)1].	None.
34	Any person responsible for the use of an existing incinerator shall upon request of the Department provide such sampling facilities and testing facilities exclusive of instruments and sensing devices as may be necessary for the Department to determine the nature and quantity of emissions from such incinerators and shall during such testing operate the incinerator at a charging rate of waste no less than the designed capacity of the incinerator using materials representative of the types of wastes normally burned. Emission limit applies at all times, including startup and shutdown. [N.J.A.C. 7:27-11.3(e)]	None.	None.	None.

New Jersey Department of Environmental Protection

Facility Specific Requirements

**U1 MWC #1, 2, 3 Municipal Waste Combustors (E1, E2, and E3)
OS SUMMARY**

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
35	No person shall use or cause to be used any incinerator unless all components connected, or attached to, or serving the incinerator, including control apparatus are functioning properly and are in use, in accordance with the permit to construct, and the certificate to operate. Emission limit applies at all times, including startup and shutdown. [N.J.A.C. 7:27-11.5(c)]	None.	None.	None.
36	VOC (Total) <= 82.8 tons/yr based on Preconstruction Permits (Total for three MWCs). [N.J.A.C. 7:27-22.16(e)]	None.	None.	None.
37	NOx (Total) <= 1,248 tons/yr based on Preconstruction Permits (Total for three MWCs). [N.J.A.C. 7:27-22.16(e)]	None.	None.	None.
38	CO <= 1,656 tons/yr based on Preconstruction Permits (Total for three MWCs). [N.J.A.C. 7:27-22.16(e)]	None.	None.	None.
39	SO2 <= 996 tons/yr based on Preconstruction Permits (Total for three MWCs). [N.J.A.C. 7:27-22.16(e)]	None.	None.	None.
40	TSP <= 53 tons/yr (Total for three MWCs) based on concentration limit of 12 mg/dscm @ 7% O2. [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.
41	PM-10 (Total) <= 203 tons/yr (Total for three MWCs). [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.
42	PM-2.5 (Total) <= 203 tons/yr total for three MWCs PM-2.5 is assumed by the facility to be equal to PM-10. [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.
43	No person shall cause, suffer, allow, or permit the emission of particles of unburned waste or ash which are individually large enough to be visible while suspended in the atmosphere. [N.J.A.C. 7:27-22.16(e)]	None.	None.	None.
44	HAPs (Total) <= 299 tons/yr (Total for three MWCs). [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.
45	Arsenic compounds <= 0.044 tons/yr (Total for three MWCs). [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.
46	Beryllium compounds <= 0.003 tons/yr from Preconstruction Permits (Total for three MWCs). [N.J.A.C. 7:27-22.16(e)]	None.	None.	None.
47	Cadmium compounds <= 0.044 tons/yr (Total for three MWCs) based on concentration limit of 10 ug/dscm @ 7% O2. [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.
48	Chromium compounds <= 0.143 tons/yr (Total for three MWCs) from modification BOP090003. [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.
49	HCl Emissions <= 284 tons/yr from Preconstruction Permit (Total for three MWCs). [N.J.A.C. 7:27-22.16(e)]	None.	None.	None.

New Jersey Department of Environmental Protection

Facility Specific Requirements

**U1 MWC #1, 2, 3 Municipal Waste Combustors (E1, E2, and E3)
OS SUMMARY**

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
50	Hydrogen fluoride <= 10.8 tons/yr from Preconstruction Permits (Total for three MWCs). [N.J.A.C. 7:27-22.16(e)]	None.	None.	None.
51	Lead compounds <= 0.44 tons/yr (Total for three MWCs) based on concentration limit of 100 ug/dscm @ 7% O ₂ . [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.
52	Mercury compounds <= 0.12 tons per calendar year (Total for three MWCs), or the facility shall have demonstrated during the calendar year that a minimum of 95% removal (revised by OP modification BOP090003) of mercury compounds had been achieved for each quarterly average of all stack tests conducted for each combustor required in this Subject Item U1, OS Summary. This limit is based on the concentration limit specified in N.J.A.C. 7:27-27.4(a). Mercury emissions based on concentration limit of 28 ug/dscm @ 7% O ₂ . [N.J.A.C. 7:27-22.16(a)]	Mercury compounds: Monitored by calculations at the approved frequency using the following formula (using EPA F-Factor 14,389 dscf @ 7% O ₂): Hg (tons per year) = X times 1 m ³ /35.3 ft ³ x 14389 dscf/MMBTU x 423 10E6 Btu/hr/unit x 8760 hrs/yr x (1 gram/10E6 ug) x (1 lb/454 grams) x 1 ton/2000 lb x 3 (for 3 MWCs), where X equals the average of all stack test results for the calendar year expressed in ug/dscm. [N.J.A.C. 7:27-22.16(o)]	Mercury compounds: Recordkeeping by manual logging of parameter annually or quarterly (as appropriate.) Record calculations each quarter and/or annually, showing the running total for each calendar year. [N.J.A.C. 7:27-22.16(o)]	None.
53	Nickel compounds <= 0.039 tons/yr (Total for three MWCs.). [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.
54	Polycyclic organic matter <= 3.81 tons/yr from Preconstruction Permits (Total for three MWCs). [N.J.A.C. 7:27-22.16(e)]	None.	None.	None.
55	Dioxins/Furans (Total) <= 0.00013 tons/yr upon completion of the baghouse project, modification BOP090003, for three MWCs based on lower federal concentration limit of 30 ng/dscm @ 7% O ₂ for a baghouse. [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.
56	TCDD Emissions (2,3,7,8-) <= 0.000119 tons/yr (Total for three MWCs.). [N.J.A.C. 7:27-22.16(e)]	None.	None.	None.
57	Ammonia <= 133 tons/yr based on Preconstruction Permits (Total for three MWCs). [N.J.A.C. 7:27-22.16(e)]	None.	None.	None.
58	Maximum Gross Heat Input <= 423 MMBTU/hr (HHV) (each combustor) while firing municipal solid waste (MSW) and <= 109 MMBTU/hr while firing No. 2 fuel oil. [N.J.A.C. 7:27-22.16(a)]	Maximum Gross Heat Input: Monitored by calculations once initially. Calculations contained in letter dated October 30, 2001. [N.J.A.C. 7:27-22.16(e)]	Other: Retain calculations in permanent file. [N.J.A.C. 7:27-22.16(o)].	None.
59	The permitted maximum steam production rate for each boiler is 247,500 pounds per hour at 650 psia and 752 degrees F (nominal). [N.J.A.C. 7:27-22.16(e)]	Monitored by integrated steam flow monitor continuously, based on a 4 hour block average. [N.J.A.C. 7:27-22.16(e)]	Recordkeeping by strip chart or data acquisition (DAS) system continuously. [N.J.A.C. 7:27-22.16(e)]	None.
60	The emission limits specified in PSD permit and included herein at Subject Item U1, OS Summary, Refs #36-40, 45-54 & 56-57 and at OS 10, Refs #2-6, 8-17 & #20-32 shall remain not applicable during the start-up period. Clarification by modification BOP090003. [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.

New Jersey Department of Environmental Protection

Facility Specific Requirements

U1 MWC #1, 2, 3 Municipal Waste Combustors (E1, E2, and E3) OS SUMMARY

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
61	Start-up Period: commences when the affected incinerator begins the combustion of municipal waste, including continuous, semicontinuous, or batch feeding of municipal solid waste to the furnace. The start-up period does not include any warm-up period when the affected unit is combusting only auxiliary fuel (fuel oil) and no municipal solid waste is being combusted. The duration of exemption from emission limits during the start-up period shall not exceed three hours. [N.J.A.C. 7:27-22.16(e)]	Start-up Period: Monitored by waste feed/charge rate monitoring (solid) continuously. [N.J.A.C. 7:27-22.16(o)]	Start-up Period: Recordkeeping by data acquisition system (DAS) / electronic data storage continuously. [N.J.A.C. 7:27-22.16(o)]	None.
62	To obtain start-up allowances, the facility must: a. Maintain the equipment; b. Operate the equipment properly; c. Take steps to minimize emissions during start-up periods. [N.J.A.C. 7:27-22.16(e)]	None.	None.	None.
63	Start-up Period: Any visible emissions caused by start-up shall not exceed an average of 10% opacity in any 6 minute block period. [N.J.A.C. 7:27-22.16(e)]	Start-up Period: Monitored by continuous opacity monitoring system continuously, based on 6 minute blocks , using USEPA referenced Method 9, or an equivalent method approved by USEPA and the Department. [N.J.A.C. 7:27-22.16(e)]	Start-up Period: Recordkeeping by strip chart or data acquisition (DAS) system continuously. [N.J.A.C. 7:27-22.16(e)]	Submit an Excess Emissions and Monitoring Systems Performance Report (EEMPR): On or before every April 30, July 30, October 30, and January 30 for the preceding quarter year (the quarter years begin on January 1, April 1, July 1, and October 1) electronically through the NJDEP online EEMPR web portal. [N.J.A.C. 7:27-22.16(o)]
64	The owner or operator shall develop a QA/QC plan for all CEMS/COMS required by this permit prepared in accordance with the NJDEP Technical Manual 1005 posted on the AQPP webpage at http://www.state.nj.us/dep/aqpp . [N.J.A.C. 7:27-22.16(a)]	Other: The QA/QC coordinator shall be responsible for reviewing the QA/QC plan on an annual basis. [N.J.A.C. 7:27-22.16(o)].	Other: Maintain readily accessible records of the QA/QC plan including QA date and quarterly reports. [N.J.A.C. 7:27-22.16(o)].	None.
65	Shutdown Period: commences when the feeding of municipal solid waste to the hopper is terminated as a result of a scheduled shutdown or malfunction. The shutdown period ends when municipal solid waste is no longer combusting on the grate. The duration of exemption from emission limits during the shutdown period shall not exceed three hours. Malfunction resulting in shutdown of a unit shall be considered a shutdown, unless operation of the affected unit is resumed before the shutdown is complete. Resuming the operation of a unit before shutdown is completed, if the shutdown is the result of malfunction, shall be considered a malfunction. [N.J.A.C. 7:27-22.16(e)]	None.	None.	None.
66	To obtain shutdown allowances, the facility must: a. Maintain the equipment; b. Operate the equipment properly; c. Take steps to minimize emissions during shutdown periods. [N.J.A.C. 7:27-22.16(e)]	None.	None.	None.

New Jersey Department of Environmental Protection

Facility Specific Requirements

U1 MWC #1, 2, 3 Municipal Waste Combustors (E1, E2, and E3) OS SUMMARY

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
67	Shutdown Period: Any visible emissions caused by shutdown shall not exceed an average of 10% opacity in any 6 minute block period. [N.J.A.C. 7:27-22.16(e)]	Shutdown Period: Monitored by continuous opacity monitoring system continuously, based on 6 minute blocks , using USEPA Referenced Method 9, or an equivalent method approved by USEPA and the Department. [N.J.A.C. 7:27-22.16(e)]	Shutdown Period: Recordkeeping by strip chart or data acquisition (DAS) system continuously. [N.J.A.C. 7:27-22.16(e)]	Submit a report: As per the approved schedule. [N.J.A.C. 7:27-22.16(e)]
68	Temperature in the Exit Gas Stream: Upon start-up of a unit, no solid waste may be introduced into the furnace unless the temperature 0.3 seconds downstream of secondary air injection is 938 degrees F as recorded by the permanent thermocouples located at the 116' 4" elevation. [N.J.A.C. 7:27-22.16(e)]	Temperature in the Exit Gas Stream: Monitored by temperature instrument upon occurrence of event. [N.J.A.C. 7:27-22.16(e)]	Temperature in the Exit Gas Stream: Recordkeeping by strip chart or data acquisition (DAS) system continuously or by manual logging upon occurrence of event. [N.J.A.C. 7:27-22.16(e)]	None.
69	Temperature in the Exit Gas Stream: Within one hour after waste has been introduced into any furnace, the temperature one second downstream of secondary air injection must be no less than 1,136 degrees F as recorded by the permanent thermocouples located at 116' 4" elevation. [N.J.A.C. 7:27-22.16(e)]	Temperature in the Exit Gas Stream: Monitored by temperature instrument continuously. [N.J.A.C. 7:27-22.16(e)]	Temperature in the Exit Gas Stream: Recordkeeping by strip chart or data acquisition (DAS) system continuously or by manual logging upon occurrence of event. [N.J.A.C. 7:27-22.16(e)]	None.
70	Temperature in the Exit Gas Stream >= 1,212 degrees F. The temperature one second downstream of secondary air injection at which each furnace must operate at least 90% of the time when waste is being burned, must be no less than 1,212 degrees F as recorded by the permanent thermocouples located at the 116' 4" elevation. [N.J.A.C. 7:27-22.16(e)]	Temperature in the Exit Gas Stream: Monitored by temperature instrument continuously. Operator shall ensure compliance with operation time at or above minimum temperature limit >= 90% at least quarterly. [BOP090003]. [N.J.A.C. 7:27-22.16(e)]	Temperature in the Exit Gas Stream: Recordkeeping by strip chart or data acquisition (DAS) system continuously or by manual logging upon occurrence of event. [N.J.A.C. 7:27-22.16(e)]	None.
71	Temperature in the Exit Gas Stream: The auxilliary burner shall be placed into position and operated if the temperature one second downstream of secondary air injection in any furnace drops below 1,212 degrees F on a 4-hour block average basis as recorded by the permanent thermocouples located at the 116' 4" elevation during the combustion of waste. [N.J.A.C. 7:27-22.16(a)]	Temperature in the Exit Gas Stream: Monitored by temperature instrument continuously. [N.J.A.C. 7:27-22.16(e)]	Temperature in the Exit Gas Stream: Recordkeeping by strip chart or data acquisition (DAS) system continuously or by manual logging upon occurrence of event. [N.J.A.C. 7:27-22.16(e)]	None.
72	Oxygen: The average concentration of oxygen in the flue gas at each furnace's exit shall not be less than 3% by volume measured on a dry basis (3.5% by volume measured on a wet basis). [N.J.A.C. 7:27-22.16(e)]	Oxygen: Monitored by continuous emission monitor continuously based on any 5 minute averaging period. [N.J.A.C. 7:27-22.16(e)]	Oxygen: Recordkeeping by strip chart or data acquisition (DAS) system continuously. [N.J.A.C. 7:27-22.16(e)]	None.
73	If the five (5) minute average oxygen concentration in the flue gas at any furnace's exit drops below 3.0% by volume on a dry basis (3.5% on a wet basis), waste charging to the affected furnace shall cease within thirty (30) minutes from the determination of the low oxygen level. [N.J.A.C. 7:27-22.16(a)]	Monitored by waste feed/charge rate monitoring (solid) continuously. [N.J.A.C. 7:27-22.16(o)]	Recordkeeping by strip chart or data acquisition (DAS) system continuously. [N.J.A.C. 7:27-22.16(o)]	None.
74	The Permittee shall monitor incoming waste trucks to determine whether they contain large quantities of easily discernible yard wastes, such as grass clippings, leaves, tree trimmings, bushes and shrubs and prevent bulk quantity of these wastes from being charged to the incinerators. (PSD permit, Attachment 1, Section J.) [N.J.A.C. 7:27-22.16(e)]	None.	None.	None.

New Jersey Department of Environmental Protection

Facility Specific Requirements

U1 MWC #1, 2, 3 Municipal Waste Combustors (E1, E2, and E3) OS SUMMARY

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
75	Each unit shall be equipped with continuous monitors and continuous recorders which shall be operated to accurately maintain the following operating records: a. temperature at the top of radiation section (elevation 116' 4") b. scrubber slurry flow rate; c. steam production rate/flow, steam pressure and steam temperature of each boiler. [N.J.A.C. 7:27-22.16(e)]	None.	None.	None.
76	Operating Log: Log books shall be kept for each unit to accurately maintain records. [N.J.A.C. 7:27-22.16(e)]	None.	Recordkeeping by manual logging of parameter or storing data in a computer data system daily. For each unit, maintain the following records: a. the specific times of operation of each furnace; b. the specific times of operation of the auxiliary burners; c. incidents of low oxygen concentration (below 3%) as specified in this permit; d. incidents of malfunctions (failures) of baghouses, scrubber or SNCR system; e. failure to maintain at least 1136 degrees F at the 116' 4" elevation, and f. exceedances of emission standards determined by continuous monitoring. [N.J.A.C. 7:27-22.16(a)]	None.
77	MERCURY CONTROL SYSTEM: The permittee shall install and operate mercury emissions control apparatus (activated carbon injection system) designed to reduce at a minimum 80 percent of the emissions of mercury from each MSW incinerator. [N.J.A.C. 7:27-22.16(e)]	None.	None.	None.
78	Mercury Emissions <= 28 ug/dscm, based on an annual average and with each test run corrected to seven percent oxygen, as tested in accordance with a test protocol approved pursuant to N.J.A.C. 7:27-27.8 (a) and (b), or: The reduction efficiency for control of mercury emissions of the air pollution control apparatus of any MSW incinerator shall be at least 95 percent on and after January 3, 2012 based on the annual average of all valid tests performed for each four consecutive quarters (from N.J.A.C. 7:27-27.4(a)(2)(iii)). [From modification BOP090003.] The company must meet 28 ug/m3 or 95% control and also never exceed 464 lbs per year. [N.J.A.C. 7:27-27.4 (a)]	Other: See stack testing requirements in U1 OS0. [N.J.A.C. 7:27-27.4(c)].	Other: See stack testing requirements in U1 OS0. [N.J.A.C. 7:27-22.16(o)].	Stack Test - Submit protocol, conduct test and submit results: As per the approved schedule. See stack testing requirements in U1 OS0. [N.J.A.C. 7:27-27.8 (a)]

New Jersey Department of Environmental Protection

Facility Specific Requirements

U1 MWC #1, 2, 3 Municipal Waste Combustors (E1, E2, and E3) OS SUMMARY

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
79	The owner or operator of a MSW incinerator served by a control apparatus shall perform compliance testing every quarter to measure mercury in the gas stream at the inlet of the air pollution control apparatus serving each incinerator and simultaneously perform compliance testing every quarter to measure mercury in the gas stream at the exit of the control device. There shall be at least a 45 calendar day interval between the testing performed for a given quarter and the testing performed for the preceding quarter unless otherwise approved by the Department. [N.J.A.C. 7:27-27.4(b)]	Other: See stack testing requirements in U1 OS0. [N.J.A.C. 7:27-27.4(d)].	Other: See stack testing requirements in U1 OS0. [N.J.A.C. 7:27-27.4(d)].	Stack Test - Submit protocol, conduct test and submit results: As per the approved schedule. See stack testing requirements in U1 OS0. [N.J.A.C. 7:27-27.4(a)]
80	Any person who achieves and maintains compliance with the preceding mercury testing requirements during two consecutive years may reduce the frequency of mercury testing from each quarter to compliance testing performed only once per year, not necessarily in the first quarter of each year. Testing shall be not less than 9 months nor more than 15 months after previous test and at "worst case" conditions (See Ref #1.) Also facility shall conduct no less than 5 tests during 5-year permit term. [From modification BOP080002.] However if subsequent testing fails to demonstrate compliance with the mercury testing requirements, then the frequency of mercury testing shall revert back to the quarterly requirement. [N.J.A.C. 7:27-22.16(a), (e)] & [N.J.A.C. 7:27-27.4(c)]	Monitored by stack emission testing annually not less than 9 months nor more than 15 months after previous test. See stack testing requirements in U1 OS0. [N.J.A.C. 7:27-27.4(c)]	Recordkeeping by stack test results annually. See stack testing requirements in U1 OS0. [N.J.A.C. 7:27-27.9(c)]	Submit a stack test report: Within 60 days of stack testing or by February 28 of the following calendar year to the Northern regional enforcement office and to the Chief, Bureau of Technical Services. Report of stack emission testing, including all test runs, shall be reviewed prior to submission and certified by a licensed professional engineer or an industrial hygienist certified by the American Board of Industrial Hygiene. See stack testing requirements in U1 OS0. [N.J.A.C. 7:27-27.9(c) & [N.J.A.C. 7:27-27.9(d)]
81	Mercury Emissions: The owner or operator of any MSW incinerator that has a reagent based mercury emission control system shall operate each MSW incinerator at, or above, the optimized reagent feed rate established in the optimization tests and approved by the Department. [N.J.A.C. 7:27-27.8(d)]	None.	None.	None.
82	Any owner or operator of a MSW incinerator that submits to the Department a report of compliance testing, including all test runs for a MSW incinerator shall have such report reviewed prior to submission and certified by a registered professional engineer or an industrial hygienist certified by the American Board of Industrial Hygiene. [N.J.A.C. 7:27-27.9(d)]	None.	None.	None.
83	Any owner or operator of a MSW incinerator who submits to the Department a report of compliance testing, including all test runs, shall certify that report. [N.J.A.C. 7:27-27.9(f)]	None.	None.	None.
84	The owner or operator shall make any record made pursuant to N.J.A.C. 7:27-27.9 (e), i.e. the required mercury stack test records, available to the Department, or its authorized representatives, for inspection for a period of five years after the date the record is made. [N.J.A.C. 7:27-27.9(g)]	None.	Recordkeeping by manual logging of parameter or storing data in a computer data system upon occurrence of event. The owner or operator shall make any record made available to the Department, or its authorized representatives, for inspection for a period of five years after the date the record is made. [N.J.A.C. 7:27-22.16(o)]	None.

New Jersey Department of Environmental Protection

Facility Specific Requirements

U1 MWC #1, 2, 3 Municipal Waste Combustors (E1, E2, and E3) OS SUMMARY

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
85	The carbon injection system shall be operated and maintained in accordance with the facility's Air Pollution Control Maintenance Plan and the manufacturer's recommendations. [N.J.A.C. 7:27-22.16(e)]	None.	None.	None.
86	The Permittee shall, in accordance with N.J.A.C. 7:27-27.8(d), conduct optimization tests on any single unit to determine the optimized activated carbon feed rate for mercury emission control. The resultant optimum feed rate from the optimization test shall be applied to all three of the carbon injection units. The Permittee shall set the optimum carbon feed rate at a level, above which, there will be no appreciable reduction in mercury emissions relative to the amount of activated carbon added. The Permittee shall operate each carbon injection unit at, or above, the optimized carbon feed rate approved by the Department. The carbon injection mercury control system shall be operated at all times while solid waste is being combusted in the incinerator. [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.
87	The rate of carbon injection, from the operating permit application, through CD1010, 1011 & 1012 shall be greater than or equal to 34 lb/hr in accordance with the approval letter dated March 8, 2001. [N.J.A.C. 7:27-22.16(e)]	Other: Carbon feed auger shall be continuously monitored. In addition, Hopper Fill Cycle Rate shall be 2.0 hours or less and shall also be continuously monitored. [N.J.A.C. 7:27-22.16(e)].	Recordkeeping by data acquisition system (DAS) / electronic data storage continuously. All alarms indicating problems with auger operation and/or speed, or with Hopper Fill Cycle Rate shall be recorded. [N.J.A.C. 7:27-22.16(e)]	None.
88	The actual total quantity of carbon used at the facility must equal or exceed the minimum required quarterly carbon usage (Q _{min} = R, carbon pounds per hour, multiplied by the total hours of waste feed to all three units during a calendar quarter.) [N.J.A.C. 7:27-22.16(e)]	Monitored by material balance quarterly: once per quarter; quarters shall begin on January 1, April 1, July 1, and October 1 of each year. Material balance shall be based on bulk deliveries of carbon and storage silo inventories. As an alternative, hopper fills, which are recorded during each shift, may be used to determine quarterly carbon usage. [From modification BOP080002.]. [N.J.A.C. 7:27-22.16(a)]	Recordkeeping by data acquisition system (DAS) / electronic data storage each month during operation, or manually in a permanently bound logbook to include the total hours of waste feed to each unit, the total combined hours, total minimum combined quantity of carbon required, and total combined amount of carbon actually used per quarter. Hopper fills also may be recorded. [N.J.A.C. 7:27-22.16(o)]	Submit a report: On or before every April 30, July 30, October 30, and January 30 for the preceding quarter year (the quarter years begin on January 1, April 1, July 1, and October 1) electronically through the NJDEP online EEMPR web portal. [N.J.A.C. 7:27-22.16(o)]
89	The carbon feed auger speed for each consecutive three hour period (12 to 3, 3 to 6, etc) must be maintained at or above the speed that has been determined, by actual measurement during calibration, to deliver the minimum required carbon feed rate. If the auger or M-drive malfunctions where carbon is not being recorded by the DCS, hopper fills may be used to demonstrate compliance with continuous carbon feed. [From modification BOP080002.]. [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.

New Jersey Department of Environmental Protection

Facility Specific Requirements

U1 MWC #1, 2, 3 Municipal Waste Combustors (E1, E2, and E3) OS SUMMARY

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
90	The operation below the minimum allowable carbon feed rate as indicated by the auger speed is a permit violation unless within three hours the condition that causes the excursion is corrected, the proper rate is restored, or the waste charging to the hopper of the affected furnace must cease until carbon feed is again at the minimum allowable rate. As an alternate, hopper fills may be used to demonstrate that the minimum allowable carbon feed is being maintained. [From modification BOP080002.] The total time of all such excursions for each unit in a calendar quarter must not exceed 2% of the total operating time for the quarter. [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.
91	The carbon feed auger speed, versus actual carbon delivery rate, shall be calibrated at least once per quarter by actual measurements (collecting and weighing the carbon delivered by the feeder) for each unit. a. The maximum time between calibrations shall not be more than 120 days. b. The date and time of each calibration and the results of the actual carbon delivery rates must be recorded and must be made available upon request by the Department personnel. c. Temporary diversions of carbon during calibrations of carbon feed auger speeds, or calibrations of the carbon feed hoppers, for up to one (1) hour in any calendar day, do not apply to the preceding condition in accordance with the approval letter dated November 18, 1998. [N.J.A.C. 7:27-22.16(e)]	Other: Conduct weigh-out test on carbon injection auger for one combustor every 120 days.[N.J.A.C. 7:27-22.16 (e)].	Other: Retain records of carbon weigh-out procedure. Upon occurrence of event. [N.J.A.C. 7:27-22.16(e)].	None.
92	During operation, the carbon injection system operating parameter(s) that are the primary indicator(s) of the carbon mass feed rate (e.g., screw feeder setting) must equal or exceed the level established during performance tests for mercury emissions. This is as required by 40 CFR 60.58b(m)(2). [40 CFR 60.39b(d)] & [40 CFR 62.14109(b)]	Other: Monitored by carbon feed rate, as required at 40 CFR 60.58b(m)(2). [40 CFR 60.39b(d)]&[40 CFR 62.14109(b)].	Recordkeeping by data acquisition system (DAS) / electronic data storage continuously The facility shall record the average carbon mass feed rate (in kg/hr or lb/hr) estimated for each hour of operation. This is as required at 40 CFR 60.59b(d)(4)(iii). Also, as required at 40 CFR 60.59b(d)(15), the facility shall record the dates where the carbon feed rate is less than the levels established by the performance tests for mercury and dioxins/furans. [40 CFR 60.39b(d)] & [40 CFR 62.14109(a)]	None.
93	ACID GAS SCRUBBER: Each scrubber shall be operated and maintained in accordance with the facility's Air Pollution Control Maintenance Plan and the manufacturer's recommendations. [N.J.A.C. 7:27-22.16(e)]	None.	None.	None.
94	Lime slurry shall be used as scrubbing chemical additive. [N.J.A.C. 7:27-22.16(e)]	None.	None.	None.

New Jersey Department of Environmental Protection

Facility Specific Requirements

U1 MWC #1, 2, 3 Municipal Waste Combustors (E1, E2, and E3) OS SUMMARY

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
95	<p>SO2 <= 94 ppmvd corrected to 7% O2 concentration in the flue gas , average SO2 concentration in the stack gas or SO2 reduced to <= 30% of the concentration (ppmvd @ 7% O2) at the inlet of the scrubber.</p> <p>The limit of 94 ppmvd shall not apply for 1-hour block periods during which the average concentration of SO2 (ppmvd @ 7% O2) in the stack gas is less than 30% of the average concentration of SO2 (ppmvd @ 7% O2) at the inlet to the acid gas control equipment. [N.J.A.C. 7:27-22.16(e)]</p>	<p>SO2: Monitored by continuous emission monitoring system continuously, based on a 1 hour block average , beginning and ending on the hour. Monitor shall assure that acid gas absorber system is operating correctly. [N.J.A.C. 7:27-22.16(a)]</p>	<p>SO2: Recordkeeping by strip chart or data acquisition (DAS) system continuously. [N.J.A.C. 7:27-22.16(e)]</p>	<p>Submit an Excess Emissions and Monitoring Systems Performance Report (EEMPR): On or before every April 30, July 30, October 30, and January 30 for the preceding quarter year (the quarter years begin on January 1, April 1, July 1, and October 1) electronically through the NJDEP online EEMPR web portal. [N.J.A.C. 7:27-22.16(o)]</p>
96	<p>Hydrogen chloride <= 47 ppmvd @ 7% O2 , average HCl concentration in the stack gas or reduced to <= 10% of the HCl concentration (ppmvd @ 7% O2) at the inlet of the scrubber.</p> <p>The limit of 47 ppmvd shall not apply for 1-hour block periods during which the average concentration of HCl (ppmvd @ 7% O2) in the stack gas is less than 10% of the average concentration of HCl (ppmvd @ 7% O2) at the inlet to the acid gas control equipment. [N.J.A.C. 7:27-22.16(a)]</p>	<p>Hydrogen chloride: Monitored by stack emission testing annually, based on the average of three 1-hour tests. See stack testing requirements in U1 OS0. [N.J.A.C. 7:27-22.16(e)]</p>	<p>Hydrogen chloride: Recordkeeping by stack test results annually. See stack testing requirements in U1 OS0. [N.J.A.C. 7:27-22.16(e)]</p>	<p>Stack Test - Submit protocol, conduct test and submit results: As per the approved schedule. See stack testing requirements in U1 OS0. [N.J.A.C. 7:27-22.16(e)]</p>
97	<p>The temperature at the particulate control device inlet shall not exceed the maximum demonstrated particulate matter control device temperature as defined in 40 CFR 60.51b by more than 17 degrees Celsius (or 31 degrees Fahrenheit), except: (1) During the annual dioxin/furan performance test the 2 weeks preceding the annual dioxin/furan performance test, no particulate matter control device temperature limitations are applicable; (2) The particulate matter control device temperature limits may be waived in accordance with permission granted by the Administrator or delegated State regulatory authority for the purpose of evaluation system performance, testing new technology or control technologies, diagnostic testing, or related activities for the purpose of improving facility performance or advancing the state-of-the-art for controlling facility emissions. This is based on the requirement at 40 CFR 60.53b(c). [40 CFR 60.39b(d)] & [40 CFR 62.14104(b)]</p>	<p>Monitored by temperature instrument continuously, based on a 1 hour block average which shall be used to calculate 4-hour block arithmetic averages, based on the requirement at 40 CFR 60.58b(i)(7). [40 CFR 60.39b(d)] & [40 CFR 62.14109(b)]</p>	<p>Recordkeeping by data acquisition system (DAS) / electronic data storage continuously. All 4-hour block arithmetic temperature averages shall be computed and recorded and be available for submittal to the Administrator or review onsite by an inspector. This is as stated at 40 CFR 60.59b(d)(2)(ii). [40 CFR 60.39b(d)] & [40 CFR 62.14109(a)]</p>	<p>None.</p>
98	<p>BAGHOUSE SYSTEM Temperature of the flue gas at the inlet of the particulate control device, shall not exceed 30 degrees F above the maximum four-hour block average temperature during the most recent dioxin/furan compliance stack emission tests. [40 CFR 60.51a] & [40 CFR 60.56a(c)]</p>	<p>Monitored by temperature instrument continuously, based on a 4 hour rolling average based on a 1 hour block average. [40 CFR 60.58a(h)(7)]</p>	<p>Recordkeeping by strip chart or data acquisition (DAS) system continuously. [N.J.A.C. 7:27-22.16(o)]</p>	<p>None.</p>
99	<p>Particulates Control Efficiency >= 99 %. Minimum control efficiency for each baghouse (CD1023, CD1024 and CD1025) from the operating permit modification application. [N.J.A.C. 7:27-22.16(a)]</p>	<p>None.</p>	<p>None.</p>	<p>None.</p>

New Jersey Department of Environmental Protection

Facility Specific Requirements

U1 MWC #1, 2, 3 Municipal Waste Combustors (E1, E2, and E3) OS SUMMARY

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
100	The permittee shall conduct bag cleaning, maintenance and replacement in each baghouse on a schedule necessary to achieve the required particulate removal efficiency as specified by the manufacturer. [N.J.A.C. 7:27-22.16(a)]	Monitored by visual determination annually during the annual boiler outage and at other times necessary to achieve the required particulate matter removal efficiency based on baghouse differential pressure and COMS data to determine the condition of each bag. [N.J.A.C. 7:27-22.16(o)]	Recordkeeping by manual logging of parameter or storing data in a computer data system upon occurrence of event. Maintain all baghouse maintenance and replacement records. [N.J.A.C. 7:27-22.16(o)]	None.
101	Baghouse construction schedule The proposed baghouses will be installed in accordance with a phased construction schedule as indicated in the modification application BOP090003, as follows: construction of the first baghouse to commence in 2014, and all three (3) baghouses shall be installed and operational by December 31, 2016. [N.J.A.C. 7:27-22.16(a)]	None.	Other: Maintain documentation of construction. [N.J.A.C. 7:27-22.16(o)].	None.
102	Upon completion of the baghouse project, BOP090003, each unit shall be equipped with continuous monitors and continuous recorders which shall be operated to accurately maintain the following operating records: a. Scrubber slurry flow rate; b. Steam production rate/flow, steam pressure and steam temperature of each boiler; and c. Temperature at the baghouse inlet. [Modification BOP090003] [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.
103	THERMAL DeNOx SYSTEM: The SNCR shall be operated and maintained in accordance with the facility's Air Pollution Control Maintenance Plan and the manufacturer's recommendations. [N.J.A.C. 7:27-22.16(e)]	None.	None.	None.
104	See GR1 for applicable requirements from NSPS Subpart A, General Provisions. [40 CFR 60]	None.	None.	None.
105	The facility is not subject to the nitrogen oxide standards in the NSPS for industrial boilers (40 CFR 60, Subpart Db) as revised June 13, 2007, restated below: (k) Any affected facility that meets the applicability requirements and is subject to an EPA approved State or Federal section 111(d)/129 plan implementing subpart Cb or subpart BBBB of this part is not covered by this subpart. [40 CFR 60.40b(k)]	None.	None.	None.

New Jersey Department of Environmental Protection

Facility Specific Requirements

U1 MWC #1, 2, 3 Municipal Waste Combustors (E1, E2, and E3) OS SUMMARY

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
106	The standards under 40 CFR 62, Subpart FFF apply at all times except during periods of startup, shutdown, or malfunction. Duration of startup, shutdown, or malfunction periods are limited to 3 hours per occurrence. The startup period commences when the affected facility begins the continuous burning of municipal solid waste and does not include any warmup period when the affected facility is combusting fossil fuel or other nonmunicipal solid waste fuel, and no municipal solid waste is being fed to the combustor. Continuous burning is the continuous, semicontinuous, or batch feeding of municipal solid waste for purposes of waste disposal, energy production, or providing heat to the combustion system in preparation for waste disposal or energy production. The use of municipal solid waste solely to provide thermal protection of the grate or hearth during the startup period when municipal solid waste is not being fed to the grate is not considered to be continuous burning. This is based on the requirement at 40 CFR 60.58b(a)(1). 40 CFR 60.39b(d) & [40 CFR 62.14109(b)]	None.	None.	None.
107	Opacity <= 10 % (6-minute average), emission limit for opacity exhibited by the gases discharged to the atmosphere from a designated facility except during periods of startup, shutdown, and malfunction. Startup, shutdown, and malfunction exception is specified by 40 CFR 62.14109(b) and 40 CFR 60.58b(a)(1). [40 CFR 60.33b(a)(1)(iii)] & . [40 CFR 62.14103(a)(1)]	Opacity: Monitored by continuous opacity monitoring system continuously, based on 6 minute blocks. The continuous opacity monitoring system shall conform to Performance Specification 1 in 40 CFR 60, appendix B. This is as required at 40 CFR 60.58b(c)(8). See stack testing requirements in U1 OS0. 40 CFR 60.58b(c)(11). [40 CFR 62.14109(b)]	Opacity: Recordkeeping by data acquisition system (DAS) / electronic data storage continuously. All 6-minute opacity levels shall be available for submittal or review onsite by an inspector, as required at 40 CFR 60.59b(d)(i)(A). . See stack testing requirements in U1 OS0. Recordkeeping for stack testing is as required at 40 CFR 60.59b(d)(9). [40 CFR 62.14109(a)]	None.
108	Particulate Emissions <= 25 mg/dscm @ 7% O2 from each MWC on and after April 28, 2009, except during periods of startup, shutdown, and malfunction. Startup, shutdown, and malfunction exception is specified by 40 CFR 62.14109(b). [40 CFR 60.33b(a)(1)(i)] & . [40 CFR 62.14103(a)(1)]	Particulate Emissions: Monitored by stack emission testing annually, based on the average of three 1-hour tests. See stack testing requirements in U1 OS0. Monitoring is based on the requirements at 40 CFR 60.58b(c)(9). [40 CFR 62.14109(b)]	Particulate Emissions: Recordkeeping by stack test results annually. See stack testing requirements in U1 OS0. Recordkeeping is based on the requirements at 40 CFR 60.59b(d)(9). [40 CFR 62.14109(a)]	None.
109	Nitrogen oxides (NOx) <= 205 ppmvd @ 7% O2 , 24-hour daily arithmetic average (midnight to midnight) from each MWC except during periods of startup, shutdown, and malfunction. Startup, shutdown, and malfunction exception is specified by 40 CFR 62.14109(b). 40 CFR 60.33b(d) & . [40 CFR 62.14103(d)]	Nitrogen oxides (NOx): Monitored by continuous emission monitoring system continuously, based on a 1 hour block average. Monitor as specified at 40 CFR 60.58b(h)(5). EPA Reference Method 19, section 4.1, shall be used for determining the 24-hour daily arithmetic average nitrogen oxides emission concentration. [40 CFR 62.14109(b)]	Nitrogen oxides (NOx): Recordkeeping by strip chart or data acquisition (DAS) system continuously. All 1-hour average nitrogen oxide concentrations shall be recorded and be available for submittal or review onsite by an inspector. This is as specified at 40 CFR 60.59b(d)(2)(i)(C). [40 CFR 62.15109(a)]	None.
110	CO <= 100 ppmvd @ 7% O2 from each MWC except during periods of startup, shutdown, and malfunction. Startup, shutdown, and malfunction exception is specified by 40 CFR 62.14109(b), 40 CFR 60.34b(a) and 40 CFR 60.58b(a)(1). [40 CFR 62.14104(a)]	CO: Monitored by continuous emission monitoring system continuously, based on a 1 hour block average which shall be used to calculate a 4-hour block average. The continuous emission monitoring system shall be operated according to Performance Specification 4A in 40 CFR 60, appendix B. Monitoring is as specified at 40 CFR 60.58b(i)(1), 40 CFR 60.58b(i)(3), and 40 CFR 60.58b(i)(4). [40 CFR 62.14109(b)]	CO: Recordkeeping by strip chart or data acquisition (DAS) system continuously. All 1-hour average CO concentrations shall be recorded and available for submittal to the administrator or review onsite by an inspector. This is as stated at 40 CFR 60.59b(d)(2)(i)(D). [40 CFR 62.14109(a)(1)]	None.

New Jersey Department of Environmental Protection

Facility Specific Requirements

U1 MWC #1, 2, 3 Municipal Waste Combustors (E1, E2, and E3) OS SUMMARY

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
111	Lead Emissions <= 0.4 mg/dscm @ 7% O2 from each MWC on and after April 28, 2009, except during periods of startup, shutdown, and malfunction. Startup, shutdown, and malfunction exception is specified by 40 CFR 62.14109(b). 40 CFR 60.33b(a)(4) &. [40 CFR 62.14103(a)(2)]	Lead Emissions: Monitored by stack emission testing annually, based on the average of three 1-hour tests. See stack testing requirements in U1 OS0. Monitoring is based on the Method 29 requirements at 40 CFR 60.58b(d)(1). [40 CFR 62.14109(b)]	Lead Emissions: Recordkeeping by stack test results annually. See stack testing requirements in U1 OS0. Recordkeeping is based on the requirements at 40 CFR 60.59b(d)(9). [40 CFR 62.14109(a)]	None.
112	Cadmium Emissions <= 0.035 mg/dscm @ 7% O2 from each MWC on and after April 28, 2009 except during periods of startup, shutdown, and malfunction. Startup, shutdown, and malfunction exception is specified by 40 CFR 62.14109(b). [40 CFR 60.33b(a)(2)(i) &. [40 CFR 62.14103(a)(2)]	Cadmium Emissions: Monitored by stack emission testing annually, based on the average of three 1-hour tests. See stack testing requirements in U1 OS0. Monitoring requirements are based on the requirements at 40 CFR 60.58b(d)(1). [40 CFR 62.14109(b)]	Cadmium Emissions: Recordkeeping by stack test results annually. See stack testing requirements in U1 OS0. Recordkeeping is based on the requirements at 40 CFR 60.59b(d)(9). [40 CFR 62.14109(a)]	None.
113	Mercury Emissions <= 0.05 mg/dscm @ 7% O2 or 15 percent of the potential mercury emission concentration (85-percent reduction by weight), corrected to 7% oxygen, whichever is less stringent, from each MWC on and after April 28, 2009 except during periods of startup, shutdown, and malfunction. Startup, shutdown, and malfunction exception is specified by 40 CFR 62.14109(b). [40 CFR 60.33b(a)(3)] &. [40 CFR 62.14103(a)(3)]	Mercury Emissions: Monitored by stack emission testing annually, based on the average of three 1-hour tests. See stack testing requirements in U1 OS0. Monitoring is based on the requirements of 40 CFR 60.58b(d)(2). [40 CFR 62.14109(b)]	Mercury Emissions: Recordkeeping by stack test results annually. See stack testing requirements in U1 OS0. Recordkeeping is based on the requirements at 40 CFR 60.59b(d)(9)(i). [40 CFR 62.14109(a)]	None.
114	SO2 <= 29 ppmvd @ 7% O2 , or 25% of the potential sulfur dioxide emission concentration (75 percent reduction by weight or volume) whichever is less stringent, from each MWC except during periods of startup, shutdown, and malfunction. Startup, shutdown, and malfunction exception is specified by 40 CFR 62.14109(b). Compliance with this emission limit is based on a 24-hour daily geometric mean. [40 CFR 60.33b(b)(3)(i)] &. [40 CFR 62.14103(b)(1)]	SO2: Monitored by continuous emission monitoring system continuously, based on a daily average (a 24-hour daily geometric average), or a daily geometric average percent reduction using EPA Reference Method 19. This is based on the requirement at 40 CFR 60.58b(e)(4). [40 CFR 62.14109(b)]	SO2: Recordkeeping by strip chart or data acquisition (DAS) system continuously. The owner or operator shall maintain records of all 1-hour average sulfur dioxide emission concentrations. This is as specified at 40 CFR 60.59b(d)(2)(i)(B). [40 CFR 61.14109(a)]	None.
115	HCl Emissions <= 29 ppmvd @ 7% O2 or 5% of the potential hydrogen chloride emission concentration (95 percent reduction by weight or volume) whichever is less stringent, from each MWC except during periods of startup, shutdown, and malfunction. Startup, shutdown, and malfunction exception is specified by 40 CFR 62.14109(b). [40 CFR 60.33b(b)(3)(i)] &. [40 CFR 62.14103(b)(2)]	HCl Emissions: Monitored by stack emission testing annually, based on the average of three 1-hour tests. See stack testing requirements in U1 OS0. Monitoring, including determining % reduction, is based on the requirements at 40 CFR 60.58b(f). [40 CFR 62.14109(b)]	HCl Emissions: Recordkeeping by stack test results annually. See stack testing requirements in U1 OS0. Recordkeeping is based on the requirements at 40 CFR 60.59b(d)(9). [40 CFR 62.14109(a)]	None.
116	Dioxins/Furans (Total) <= 30 ng/dscm @ 7% O2 , except during periods of start-up, shutdown, and malfunction. Startup, shutdown, and malfunction exception is specified by 40 CFR 62.14109(b) and 40 CFR 60.58b(a)(1). This limitation applies after completion of the baghouse project, modification BOP090003. 40 CFR 60.39b(d), 40 CFR 60.53a(b) &. [40 CFR 62.14103(c)(2)]	Dioxins/Furans (Total): Monitored by stack emission testing annually, based on the average of three 1-hour tests. See stack testing requirements in U1 OS0. Monitoring is as required at 40 CFR 60.58b(h)(5), except as specified at 40 CFR 62.14109(d)(1). [40 CFR 62.14109(b)] &. [40 CFR 62.14109(d)(1)]	Dioxins/Furans (Total): Recordkeeping by stack test results annually. See stack testing requirements in U1 OS0. This is as specified at 40 CFR 60.59b(d)(9)(i). [40 CFR 62.14109(a)]	None.

New Jersey Department of Environmental Protection

Facility Specific Requirements

U1 MWC #1, 2, 3 Municipal Waste Combustors (E1, E2, and E3) OS SUMMARY

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
117	<p>No owner or operator of an affected facility shall cause it to operate at a load level greater than 110 percent of the maximum demonstrated municipal waste combustor unit load as defined in 40 CFR 60.51b, except: (1) During the annual dioxin/furan performance test and the 2 weeks preceding that test, no municipal waste combustor unit load limit is applicable; (2)The municipal waste combustor unit load limit may be waived in accordance with permission granted by the Administrator or delegated State regulatory authority for the purpose of evaluating system performance, testing new technology or control technologies, diagnostic testing, or related activities for the purpose of improving facility performance or advancing the state-of-the art for controlling facility emissions. This is as stated at 40 CFR 60.53b(b). [40 CFR 60.39b(d)]& [40 CFR 62.14104(b)]</p>	<p>Other: The owner or operator shall operate a steam or feedwater flow meter on a continuous basis, as required at 40 CFR 60.58(i)(6)(i). Steam (or feed water flow) flow calculations as required under 40 CFR 60.58(i)(6)(i) shall be in accordance with ASME PTC 4.1-1964 (Reaffirmed 1991), Power test codes : Test Code for Steam Generating Units (with 1968 and 1969 Addenda). For design, construction, installation, calibration, and use of nozzles and orifices required in 40 CFR 60.58(i)(6)(ii), proceed in accordance with the recommendations in ASME Interim Supplement 19.5 on Instruments and Apparatus: Application, Part II of Fluid Meters, 6th Edition (1971). Measurement devices such as flow nozzles and orifices are not required to be recalibrated after they are installed, as stipulated at 40 CFR 58b(i)(6)(iii). Also, as stipulated at 40 CFR 58b(i)(6)(iv), all signal conversion elements associated with steam (or feedwater flow) measurements must be calibrated according to the manufacturer's instructions before each dioxin/furan performance test, and at least once per year. [40 CFR 60.39b(d)] &[40 CFR 62.14104(b)].</p>	<p>Recordkeeping by data acquisition system (DAS) / electronic data storage continuously based on the requirement at 40 CFR 60.58(i)(6)(i). [40 CFR 60.39b(d)] &. [40 CFR 62.14104(b)]</p>	None.
118	<p>Each chief facility operator and shift supervisor must obtain and maintain a current provisional operator certification from either the American Society of Mechanical Engineers (QRO-1-1994) or a State certification program. [40 CFR 60.35b, 40 CFR 60.39b (d), 40 CFR 60.54b] & [40 CFR 62.14105(a)]</p>	None.	<p>Other: The facility shall maintain the following records for a period of five years:</p> <p>Records showing the names of the municipal waste combustor chief facility operator, shift supervisors and control room operators who have been fully certified or who are provisionally certified by the American Society of Mechanical Engineers (ASME) or an equivalent State approved certification program, including the dates of initial and renewal certifications and documentation of current certification.</p> <p>Records showing the names of the municipal waste combustor chief facility operator, shift supervisors and control room operators who have completed the EPA municipal waste combustor operator training course or a State approved equivalent course including documentation of training completion.</p> <p>This is based on the recordkeeping requirements at 40 CFR 60.59b(d)(12) [40 CFR 62.14105(a)].</p>	None.
119	<p>Each chief facility operator and shift supervisor must complete full certification or must have scheduled a full certification exam with either the American Society of Mechanical Engineers (QRO-1-1994) or a State certification program. 40 CFR 60.39b(d)& [40 CFR 62.14105(b)]</p>	None.	None.	None.

New Jersey Department of Environmental Protection

Facility Specific Requirements

**U1 MWC #1, 2, 3 Municipal Waste Combustors (E1, E2, and E3)
OS SUMMARY**

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
120	<p>The facility must not be operated unless one of the following persons is on duty:</p> <ul style="list-style-type: none"> - a fully certified chief facility operator; - a provisionally certified chief facility operator who is scheduled to take the full certification exam no later than 12 months after the effective date of 40 CFR 62 Subpart FFF; - a fully certified shift supervisor; or - a provisionally certified shift supervisor who is scheduled to take the full certification exam no later than 12 months after the effective date of 40 CFR 62 Subpart FFF. <p>If one of the persons listed above must leave the facility during their operating shift, a provisionally certified control room operator who is onsite may fulfill this requirement. [40 CFR 60.39b(d), 40 CFR 60.54b(i)] & [40 CFR 62.14105(c)]</p>	None.	None.	None.
121	<p>As further clarification to the preceding "Stand-in" Provisions, a provisionally certified control room operator can stand-in for a certified plant or shift supervisor when they are off site for periods of up to eight hours without notification of EPA, for periods up to two weeks if EPA is notified in writing, and case by case with enforcement discretion for periods longer than two weeks if EPA is notified in writing with adequate detail of the reasons for the situation and if the MWC owner demonstrates to EPA that a good faith effort is being made to correct the problem. [N.J.A.C. 7:27-22.16(a)]</p>	None.	None.	None.
122	<p>Each chief facility operator, shift supervisor and control room operator at an affected facility must complete the EPA municipal waste combustor operator training course or the State municipal waste operator training course, except for chief facility operators, shift supervisors, and control room operators who have obtained full certification from the ASME on or before the effective date of 40 CFR 62 Subpart FFF. [40 CFR 60.39b(d), 40 CFR 60.54b] & [40 CFR 62.14105(d)]</p>	None.	None.	None.

New Jersey Department of Environmental Protection

Facility Specific Requirements

U1 MWC #1, 2, 3 Municipal Waste Combustors (E1, E2, and E3) OS SUMMARY

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
123	<p>OPERATING MANUAL: The facility must develop and update on a yearly basis a manual that must, at a minimum, address the following elements of municipal waste combustor unit operation:</p> <ul style="list-style-type: none"> - A summary of the applicable standards of 40 CFR 62 Subpart FFF; - A description of basic combustion theory applicable to a MWC unit; - Procedures for receiving, handling and feeding MSW; - Procedures for MWC unit startup, shutdown and malfunction; - Procedures for maintaining proper combustion air supply levels; - Procedures for operating the MWC unit within the standards established under 40 CFR 62 Subpart FFF; - Procedures for responding to periodic upset or off-specification conditions; - Procedures for minimizing particulate matter carryover; - Procedures for handling ash; - Procedures for monitoring MWC unit emissions; - Reporting and Recordkeeping procedures. [40 CFR 60.39b(d), 40 CFR 60.54b(e)] & [40 CFR 62.14105(e)] 	None.	Other: The operating manual and records of training must be available for inspection by USEPA or the Department upon request. [40 CFR 60.39b(d)] & [40 CFR 62.14105(g)].	None.
124	<p>TRAINING FOR OPERATING MANUAL REVIEW: - The facility must establish a training program to review the operating manual according to the schedule specified below with each person who has responsibilities affecting the operation of the facility, including but not limited to, chief facility operators, shift supervisors, control room operators, ash handlers, maintenance personnel and crane/load handlers. Each person undergoing the manual review training shall do so no later than the dates specified below, whichever is later:</p> <ul style="list-style-type: none"> - The date prior to the day the person assumes responsibilities affecting MWC unit operation; or - The date 12 months after the effective date of 40 CFR 62 Subpart FFF; or - Annually following the initial review. <p>ACCESS TO OPERATING MANUAL: The operating manual must be kept in a location readily accessible to each person required to undergo training. [40 CFR 60.39b(d), 40 CFR 60.54b(f) & (g)] & [40 CFR 62.14105(f)]</p>	None.	Other: The facility shall maintain records showing the names of persons who have completed a review of the operating manual including the date of initial review and subsequent annual reviews. This is based on the recordkeeping requirement at 40 CFR 50.59b(d)(13). [40 CFR 60.39b(d)] & [40 CFR 62.14105(a)].	None.

New Jersey Department of Environmental Protection

Facility Specific Requirements

U1 MWC #1, 2, 3 Municipal Waste Combustors (E1, E2, and E3) OS SUMMARY

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
125	<p>SEMI-ANNUAL REPORT: The facility shall submit a semi-annual report which shall include the following:</p> <ul style="list-style-type: none"> - Information recorded which indicates the average sulfur dioxide, nitrogen oxides, carbon monoxide, municipal waste combustor unit load level, particulate matter control device inlet temperature or opacity data were above the applicable limits with reasons for such exceedances and a description of the corrective action taken. - A copy of the annual test report documenting the emissions level and the corrective action taken if the test report indicates any particulate matter, opacity, cadmium, lead, mercury, dioxins/furans, hydrogen chloride or fugitive ash emission levels that were above applicable pollutant limits. - Identification of the calendar dates when the average hourly carbon feed rate was below the required feed rate with reasons for such occurrences and a description of corrective action taken. - Identification of the calendar dates when the average hourly carbon feed rate is not operational, with reasons for such occurrences and a description of corrective action taken. This is as stated at 40 CFR 60.59b(h). [40 CFR 60.39b(d)] & [40 CFR 62.14109(a)] 	None.	<p>Other: All semi-annual reports must be maintained on site as a paper copy for a minimum of 5 years. This is as stated at 40 CFR 60.59b(j). [40 CFR 60.39b(d)] & [40 CFR 62.14109(a)].</p>	<p>Submit a report: As per the approved schedule that follows to EPA Region II and the appropriate Regional Enforcement Office of NJDEP. The report for the first half of the calendar year must be submitted by August 1 of the same year. The report for the second half of the calendar year must be submitted by February 1 of the following year. This is as stated at 40 CFR 50.59(h). [40 CFR 60.39b(d)] & [40 CFR 62.14109(a)]</p>
126	<p>SEMI-ANNUAL REPORT (continued): Upon issuance of the operating permit, the semi-annual report shall include the following:</p> <ul style="list-style-type: none"> - A list of the particulate matter, opacity, cadmium, lead, mercury, dioxins/furans, hydrogen chloride and fugitive ash emission levels achieved during performance tests - A list of the highest emission level recorded for sulfur dioxide, nitrogen dioxides, carbon monoxide, municipal waste combustor load level and particulate matter control device inlet temperature. - A list of the highest opacity level measured - The total number of days that the minimum number of hours of data for sulfur dioxide, nitrogen oxides, carbon monoxide, municipal waste combustor unit load level and particulate matter control device inlet temperature were not obtained for the calculation of the average emissions concentrations or parameters. - The total number of hours that data for sulfur dioxide, nitrogen oxides, carbon monoxide, municipal waste combustor unit load and particulate matter control device inlet temperature were excluded from the calculation of average emissions concentrations or parameters. This is based on the requirements of 40 CFR 59b(g)(1). [40 CFR 60.39b(d)] & [40 CFR 62.14109(a)] 	None.	<p>Other: All semi-annual reports must be maintained on site as a paper copy for a minimum of 5 years. This is as stated at 40 CFR 60.59b(j). [40 CFR 60.39b(d)] & [40 CFR 62.14109(a)].</p>	<p>Submit a report: As per the approved schedule that follows to EPA Region II and the appropriate Regional Enforcement Office of NJDEP. The report for the first half of the calendar year must be submitted by August 1 of the same year. The report for the second half of the calendar year must be submitted by February 1 of the following year. This is based on the requirements at 40 CFR 60.59b(g). [40 CFR 60.39b(d)] & [40 CFR 62.14109(a)]</p>

New Jersey Department of Environmental Protection

Facility Specific Requirements

U1 MWC #1, 2, 3 Municipal Waste Combustors (E1, E2, and E3) OS SUMMARY

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
127	<p>SEMI-ANNUAL REPORT (continued):</p> <p>-The facility shall also provide a summary report with the same data specified in the semi-annual reports for the preceding year in order to provide the Administrator with a summary of the performance of the facility over a 2 year period. This summary report shall highlight any emission or parameter level that did not achieve the required emission or parameter limits.</p> <p>- The facility will also include a notification of intent to begin reduced dioxin/furan performance testing schedule as allowed in 40 CFR 60.58(g)(5)(iii), i.e. NSPS Subpart Eb. These are based on the requirements of 40 CFR 60.59b(g). [40 CFR 60.39b(d)] & [40 CFR 62.14109(a)]</p>	None.	<p>Other: All semi-annual reports must be maintained on site as a paper copy for a minimum of 5 years. This is as stated at 40 CFR 60.59b(j). [40 CFR 60.39b(d)] & [40 CFR 62.14109(a)].</p>	<p>Submit a report: As per the approved schedule that follows to EPA Region II and the appropriate Regional Enforcement Office of NJDEP. The report for the first half of the calendar year must be submitted by August 1 of the same year. The report for the second half of the calendar year must be submitted by February 1 of the following year. This is based on the requirements at 40 CFR 60.59b(g). [40 CFR 60.39b(d)] & [40 CFR 62.14109(a)]</p>
128	<p>REPORTING/RECORDKEEPING:</p> <p>The facility shall maintain the following records for a period of at least five years:</p> <p>Identification of the calendar dates when any of the average emission concentrations, percent reductions, operating parameters or opacity levels are above applicable limits, with reasons for such exceedances and a description of corrective action taken. This is as stated at 40 CFR 60.59b(d)(3). [40 CFR 60.39b(d)] & [40 CFR 62.14109(a)]</p>	None.	<p>Other: Maintain records on paper copy or a computer readable format for a period of at least 5 years from the date of record. This is as stated at 40 CFR 60.59b(d) and 40 CFR 60.59b(k). [40 CFR 60.39b(d)] & [40 CFR 62.14109].</p>	None.
129	<p>REPORTING/RECORDKEEPING:</p> <p>The facility shall maintain the following records for a period of at least five years:</p> <p>Identification of the calendar dates for which the minimum number of hours of the data specified below have not been obtained and the reasons for not obtaining sufficient data and a description of the corrective action taken:</p> <ul style="list-style-type: none"> - Sulfur Dioxide emissions data - Nitrogen Oxides emissions data - Carbon Monoxide emissions data - Municipal waste combustor unit load data - Particulate matter control device temperature data <p>This is as stated at 40 CFR 60.59b(d)(6). [40 CFR 60.39b(d)] & [40 CFR 62.14109(a)]</p>	None.	<p>Other: Maintain records on paper copy or a computer readable format for a period of at least 5 years from the date of record. This is as stated at 40 CFR 60.59b(d) and 40 CFR 60.59b(k). [40 CFR 60.39b(d)] & [40 CFR 62.14109(a)].</p>	None.
130	<p>REPORTING/RECORDKEEPING:</p> <p>The facility shall maintain the following records for a period of at least five years:</p> <p>Identification of each occurrence that sulfur dioxide emissions data, nitrogen oxides emissions data or operational data (i.e. carbon monoxide emissions, unit load and particulate matter control device temperature) have been excluded from the calculation of average emission concentration or parameters, and the reasons for excluding the data. This is as stated at 40 CFR 60.59b(d)(7). [40 CFR 60.39b(d)] & [40 CFR 62.14109(a)]</p>	None.	<p>Other: Maintain records on paper copy or a computer readable format for a period of at least 5 years from the date of record. This is as stated at 40 CFR 60.59b(d) and 40 CFR 60.59b(k). [40 CFR 60.39b(d)] & [40 CFR 62.14109(a)].</p>	None.

New Jersey Department of Environmental Protection

Facility Specific Requirements

**U1 MWC #1, 2, 3 Municipal Waste Combustors (E1, E2, and E3)
OS SUMMARY**

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
131	<p>REPORTING/RECORDKEEPING: The facility shall maintain the following records for a period of at least five years: The results of daily drift test and quarterly accuracy determinations for sulfur dioxide, nitrogen oxides and carbon monoxide continuous emission monitoring systems as required under 40 CFR Part 60 Appendix F, Procedure 1. This is based on the requirements at 40 CFR 60.59b(d)(8). [40 CFR 60.39b(d)] & [40 CFR 62.14109(a)]</p>	None.	Other: Maintain records on paper copy or a computer readable format for a period of at least 5 years from the date of record. This is as stated at 40 CFR 60.59b(d) and 40 CFR 60.59b(k). [40 CFR 60.39b(d)] & [40 CFR 62.14109(a)].	None.
132	<p>REPORTING/RECORDKEEPING OF ANNUAL PERFORMANCE TESTS: The facility shall maintain the following records for a period of at least five years: The test reports documenting the results of all annual performance tests shall be recorded along with supporting calculations specifically as follows: - The results of all annual performance tests conducted to determine compliance with particulate matter, opacity, cadmium, lead, dioxin/furans, hydrogen chloride and fugitive ash emission limits. - The maximum demonstrated municipal waste combustor unit load and maximum demonstrated particulate matter control device temperature during dioxin/furan performance tests. This condition is based on the requirements at 40 CFR 60.59b(d)(9). [40 CFR 60.39b(d)] & [40 CFR 62.14109(a)]</p>	None.	Other: Maintain records for a period of at least 5 years from the date of record. [40 CFR 60.39b(d)] & [40 CFR 62.14109(a)].	None.

New Jersey Department of Environmental Protection

Facility Specific Requirements

U1 MWC #1, 2, 3 Municipal Waste Combustors (E1, E2, and E3)

OS2 Operation of MWC #1 under Malfunction conditions, OS4 Operation of MWC #2 under Malfunction conditions, OS6 Operation of MWC #3 under Malfunction conditions

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
1	<p>EMERGENCY MALFUNCTION: An emergency malfunction means any sudden and unavoidable failure to the equipment or control apparatus to operate in a normal manner. Malfunctions that are caused entirely or in part by improperly designed equipment, lack of preventative maintenance, careless or improper operation, operator error, or any preventable upset condition or preventable equipment or control apparatus breakdown shall not be considered emergency malfunctions. In any enforcement proceeding the Permittee seeking to establish the occurrence of an emergency malfunction has the burden of proof. [N.J.A.C. 7:27-22.16(e)]</p>	None.	None.	<p>Submit a report: As per the approved schedule. For a permittee to claim an emission limit exceedance is due to an emergency malfunction the Permittee must submit a written preliminary notice to the Department by 5:00 pm of the second full working day following the incident.</p> <p>This preliminary notice must include: A description of the malfunction and how it resulted in a contravention. A description of the measures taken to correct the conditions causing the contravention. A description of the measures taken to minimize the excess emissions including curtailment or shutdown of the combustor.</p> <p>This provision does not relieve the Permittee from immediately notifying the Department of any release of air contaminants in a quantity or concentration which poses a potential threat to public health, wealth, or the environment, or which might result in citizen complaints, pursuant to N.J.S.A. 26:2C-19(e). [N.J.A.C. 7:27-22.16(e)]</p>
2	<p>EMERGENCY MALFUNCTION: The Department will review the Emergency Malfunction asserted by the facility. If the Department deems that any Emergency Malfunction was asserted incorrectly, the Department will reject the claim and take appropriate enforcement action. [N.J.A.C. 7:27-22.16(a)]</p>	None.	None.	None.
3	<p>EMERGENCY MALFUNCTION: To obtain malfunction allowances, the facility must:</p> <ol style="list-style-type: none"> a. Maintain the equipment; b. Operate the equipment properly; c. Take steps to minimize emissions during malfunction periods; d. Identify and take steps to prevent malfunctions from occurring in future; and e. Report malfunctions in accordance with the reporting requirements of this permit. [N.J.A.C. 7:27-22.16(e)] 	None.	None.	None.

New Jersey Department of Environmental Protection

Facility Specific Requirements

U1 MWC #1, 2, 3 Municipal Waste Combustors (E1, E2, and E3)

OS2 Operation of MWC #1 under Malfunction conditions, OS4 Operation of MWC #2 under Malfunction conditions, OS6 Operation of MWC #3 under Malfunction conditions

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement												
4	<p>EMERGENCY MALFUNCTION: Within thirty days of an emergency malfunction, the Permittee shall submit to the Department certified information which identifies the contravention and includes the following: Copies of relevant operating data including but not limited to continuous monitoring data or portions of logbooks that show the malfunction to be sudden and unavoidable. Relevant data shall include at a minimum data recorded one hour before, during, and one hour after the malfunction. List of the actions taken to prevent the potential for the malfunction from occurring in the future. Certification in accordance with N.J.A.C. 7:27-1.39 that the malfunction did not occur as a result of: improperly designed equipment, lack of preventative maintenance, careless or improper operation, or operator error, and certification that the information contained in the preliminary notice is correct. If the information submitted in the preliminary notice is inaccurate, a certified revision of the notice shall be submitted. [N.J.A.C. 7:27-22.16(e)]</p>	None.	None.	None.												
5	<p>EMERGENCY MALFUNCTION: The duration of emission excursions caused by malfunctions shall not exceed the following limits per occurrence and percent of operating time:</p> <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 15%;">SO2</td> <td style="width: 25%;">180min.</td> <td style="width: 15%;">2%</td> <td style="width: 45%;"></td> </tr> <tr> <td>CO</td> <td>60min</td> <td>0.2%</td> <td></td> </tr> <tr> <td>NOx</td> <td>180min</td> <td>2%</td> <td></td> </tr> </table> <p>[N.J.A.C. 7:27-22.16(e)]</p>	SO2	180min.	2%		CO	60min	0.2%		NOx	180min	2%		Monitored by continuous emission monitor upon occurrence of event (and hour time monitor). [N.J.A.C. 7:27-22.16(e)]	Recordkeeping by data acquisition system (DAS) / electronic data storage upon occurrence of event. Data may be periodically printed and maintained reliably in a log book on site. [N.J.A.C. 7:27-22.16(o)]	None.
SO2	180min.	2%														
CO	60min	0.2%														
NOx	180min	2%														
6	<p>EMERGENCY MALFUNCTION: The duration of operating requirement excursions caused by malfunctions shall not exceed the following limits per occurrence and percent of operating time:</p> <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 15%;">Temperature</td> <td style="width: 25%;">60min.</td> <td style="width: 15%;">0.1%</td> <td style="width: 45%;">[N.J.A.C. 7:27-22.16(e)]</td> </tr> </table>	Temperature	60min.	0.1%	[N.J.A.C. 7:27-22.16(e)]	Monitored by parametric monitoring system upon occurrence of event (temperature monitor and hour time monitor). [N.J.A.C. 7:27-22.16(e)]	Recordkeeping by data acquisition system (DAS) / electronic data storage upon occurrence of event. Data may be periodically printed and maintained reliably in a log book on site. [N.J.A.C. 7:27-22.16(o)]	None.								
Temperature	60min.	0.1%	[N.J.A.C. 7:27-22.16(e)]													
7	<p>EMERGENCY MALFUNCTION: Neither the time, nor the emissions, during the periods of emergency malfunctions meeting the above criteria shall be used in the calculation of emission levels for comparison to allowable emission limits. [N.J.A.C. 7:27-22.16(e)]</p>	None.	None.	None.												
8	<p>EMERGENCY MALFUNCTION: Malfunctions resulting in an excursion of an emission limit with an averaging time of less than or equal to one hour shall be deemed to have occurred during the entire applicable averaging time of that emission limit. Malfunction resulting in an excursion of an emission limit with an averaging time of greater than one hour shall be deemed to have occurred only during the hours of the malfunction. [N.J.A.C. 7:27-22.16(e)]</p>	None.	None.	None.												

New Jersey Department of Environmental Protection

Facility Specific Requirements

U1 MWC #1, 2, 3 Municipal Waste Combustors (E1, E2, and E3)

OS2 Operation of MWC #1 under Malfunction conditions, OS4 Operation of MWC #2 under Malfunction conditions, OS6 Operation of MWC #3 under Malfunction conditions

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
9	EMERGENCY MALFUNCTION: Any visible emission caused by a malfunction shall not exceed an average of 10% opacity in any 6 minute block period, as determined by the continuous emission monitoring equipment or USEPA Reference Method 9. [N.J.A.C. 7:27-22.16(e)]	Monitored by continuous opacity monitor upon occurrence of event, based on 6 minute blocks. [N.J.A.C. 7:27-22.16(e)]	Recordkeeping by data acquisition system (DAS) / electronic data storage continuously. [N.J.A.C. 7:27-22.16(e)]	None.

New Jersey Department of Environmental Protection

Facility Specific Requirements

U1 MWC #1, 2, 3 Municipal Waste Combustors (E1, E2, and E3)

OS10 Operation of MWC #1 at Maximum Input (423 MMBtu/hr) with Baghouse, OS11 Operation of MWC #2 at Maximum Input (423 MMBtu/hr) with Baghouse, OS12 Operation of MWC #3 at Maximum Input (423 MMBtu/hr) with Baghouse

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
1	<p>Unless otherwise specified, the emission limits specified under this operating scenario shall apply at all times, except for start-up and shutdown periods.</p> <p>Requirements in this operating scenario are applicable after installation of the baghouse controlling this emission unit (MWC) [From modification BOP090003, Construction period 2014 to 2016.] [N.J.A.C. 7:27-22.16 (a)]</p>	None.	None.	Submit the required air permit application(s): Upon occurrence of event (i.e., after installation of baghouse for this emission unit.) Application shall request removal of conditions in the operating scenarios for which use of ESPs is required and removal of all inventory data related to them. From modification BOP090003. [N.J.A.C. 7:27-22.16(o)]
2	Maximum emission rate of Non-Methane Hydrocarbons as Methane, Non-Methane Hydrocarbons <= 6.3 lb/hr. [N.J.A.C. 7:27-22.16(a)]	Non-Methane Hydrocarbons: Monitored by stack emission testing prior to permit expiration date, based on the average of three Department validated stack test runs. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	Non-Methane Hydrocarbons: Recordkeeping by stack test results upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	Stack Test - Submit protocol, conduct test and submit results: Upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(e)]
3	Maximum concentration of Non-Methane Hydrocarbons as Methane, VOC (Total) <= 66 ppmvd @ 7% O ₂ . [N.J.A.C. 7:27-22.16(e)]	VOC (Total): Monitored by stack emission testing prior to permit expiration date, based on the average of three Department validated stack test runs. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	VOC (Total): Recordkeeping by stack test results upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	Stack Test - Submit protocol, conduct test and submit results: Upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]
4	NO _x (Total) <= 95 lb/hr from preconstruction permit. The emission limitations shall apply at all times when MSW is being combusted, except during start-up and shutdown as defined in this operating permit. [N.J.A.C. 7:27-22.16 (e)]	NO _x (Total): Monitored by stack emission testing prior to permit expiration date, based on the average of three 1-hour tests. Three test runs must be conducted on each unit, with ammonia injection, to determine compliance. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	NO _x (Total): Recordkeeping by stack test results prior to permit expiration date. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	Stack Test - Submit protocol, conduct test and submit results: Upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]
5	NO _x (Total) <= 300 ppmvd @ 7% O ₂ . The emission limitation shall apply at all times when MSW is being combusted, except during start-up and shutdown as defined in this operating permit. [N.J.A.C. 7:27-22.16(e)]	NO _x (Total): Monitored by continuous emission monitoring system continuously, based on a 1 hour block average, beginning and ending on the hour. [N.J.A.C. 7:27-22.16(o)]	NO _x (Total): Recordkeeping by strip chart or data acquisition (DAS) system continuously. [N.J.A.C. 7:27-22.16(o)]	Submit an Excess Emissions and Monitoring Systems Performance Report (EEMPR): On or before every April 30, July 30, October 30, and January 30 for the preceding quarter year (the quarter years begin on January 1, April 1, July 1, and October 1) electronically through the NJDEP online EEMPR web portal. [N.J.A.C. 7:27-22.16(o)]
6	NO _x (Total) <= 155 ppmvd @ 7% O ₂ . The emission limitation shall apply at all times when MSW is being combusted, except during start-up and shutdown as defined in this operating permit. [N.J.A.C. 7:27-22.16(e)]	NO _x (Total): Monitored by continuous emission monitoring system continuously, based on a 24 hour period block, beginning and ending at midnight. [N.J.A.C. 7:27-22.16(o)]	NO _x (Total): Recordkeeping by strip chart or data acquisition (DAS) system continuously. [N.J.A.C. 7:27-22.16(o)]	Submit an Excess Emissions and Monitoring Systems Performance Report (EEMPR): On or before every April 30, July 30, October 30, and January 30 for the preceding quarter year (the quarter years begin on January 1, April 1, July 1, and October 1) electronically through the NJDEP online EEMPR web portal. [N.J.A.C. 7:27-22.16(o)]
7	NO _x (Total) <= 150 ppmvd @ 7% O ₂ . The owner or operator of a MSW incinerator of any size shall cause it to emit NO _x at a maximum allowable emission concentration of 150 ppmvd at seven percent oxygen based on a calendar day average. [N.J.A.C. 7:27-19.12 (a)1]	NO _x (Total): Monitored by continuous emission monitoring system continuously, based on one calendar day based on 1-hour block averages. The owner or operator shall install a NO _x continuous emissions monitoring (CEM) system on the MSW incinerator satisfying the requirements of N.J.A.C. 7:27-19.18 and shall demonstrate compliance using the NO _x CEM. [N.J.A.C. 7:27-19.12(c)]	NO _x (Total): Recordkeeping by strip chart or data acquisition (DAS) system continuously and calculating the average each calendar day. [N.J.A.C. 7:27-22.16(o)]	Submit an Excess Emissions and Monitoring Systems Performance Report (EEMPR): On or before every April 30, July 30, October 30, and January 30 for the preceding quarter year (the quarter years begin on January 1, April 1, July 1, and October 1) electronically through the NJDEP online EEMPR web portal. [N.J.A.C. 7:27-22.16(o)]

New Jersey Department of Environmental Protection

Facility Specific Requirements

U1 MWC #1, 2, 3 Municipal Waste Combustors (E1, E2, and E3)

OS10 Operation of MWC #1 at Maximum Input (423 MMBtu/hr) with Baghouse, OS11 Operation of MWC #2 at Maximum Input (423 MMBtu/hr) with Baghouse, OS12 Operation of MWC #3 at Maximum Input (423 MMBtu/hr) with Baghouse

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
8	CO <= 126 lb/hr from preconstruction permit. The emission limitations shall apply at all times when MSW is being combusted, except during start-up and shutdown as defined in this operating permit. [N.J.A.C. 7:27-22.16(e)]	CO: Monitored by stack emission testing prior to permit expiration date, based on each of three Department validated stack test runs. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	CO: Recordkeeping by stack test results upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	Stack Test - Submit protocol, conduct test and submit results: Upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]
9	CO <= 400 ppmvd @ 7% O2. The emission limitation shall apply at all times when MSW is being combusted, except during start-up and shutdown as defined in this operating permit. [N.J.A.C. 7:27-22.16(e)]	CO: Monitored by continuous emission monitoring system continuously, based on a 1 hour block average, beginning and ending on the hour. [N.J.A.C. 7:27-22.16(o)]	CO: Recordkeeping by strip chart or data acquisition (DAS) system continuously. [N.J.A.C. 7:27-22.16(o)]	Submit an Excess Emissions and Monitoring Systems Performance Report (EEMPR): On or before every April 30, July 30, October 30, and January 30 for the preceding quarter year (the quarter years begin on January 1, April 1, July 1, and October 1) electronically through the NJDEP online EEMPR web portal. [N.J.A.C. 7:27-22.16(o)]
10	CO <= 100 ppmvd @ 7% O2. The emission limitation shall apply at all times when MSW is being combusted, except during start-up and shutdown as defined in this operating permit. [N.J.A.C. 7:27-22.16(e)]	CO: Monitored by continuous emission monitoring system continuously, based on a 96 hour rolling average based on a 1 hour block average beginning and ending on the hour. [N.J.A.C. 7:27-22.16(o)]	CO: Recordkeeping by strip chart or data acquisition (DAS) system continuously. [N.J.A.C. 7:27-22.16(o)]	Submit an Excess Emissions and Monitoring Systems Performance Report (EEMPR): On or before every April 30, July 30, October 30, and January 30 for the preceding quarter year (the quarter years begin on January 1, April 1, July 1, and October 1) electronically through the NJDEP online EEMPR web portal. [N.J.A.C. 7:27-22.16(o)]
11	The CO and NOx emission limits specified in permit condition, for normal steady state operation shall not apply during periods, including warm-up periods, when no waste is burned and fossil fuel is being combusted. Only auxiliary fuel (fuel oil) shall be combusted during warm-up periods, and no municipal solid waste shall be combusted. The warm-up period begins upon initiation of auxiliary fuel (fuel oil) combustion in the furnace. The duration of exemption from emission limits during these periods shall not exceed 10 consecutive hours per warm-up period. [N.J.A.C. 7:27-22.16(e)]	None.	None.	None.
12	SO2 <= 75.8 lb/hr. [N.J.A.C. 7:27-22.16(e)]	SO2: Monitored by stack emission testing prior to permit expiration date, based on the average of three Department validated stack test runs. See stack testing requirements in U1 OS Summary. [From BOP080001]. [N.J.A.C. 7:27-22.16(o)]	SO2: Recordkeeping by stack test results upon occurrence of event. See stack testing requirements in U1 OS Summary. [From BOP080001]. [N.J.A.C. 7:27-22.16(o)]	Stack Test - Submit protocol, conduct test and submit results: Upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]
13	SO3 and H2SO4, as converted and expressed as H2SO4 <= 4 lb/hr. [N.J.A.C. 7:27-22.16(e)]	SO3 and H2SO4, as converted and expressed as H2SO4: Monitored by stack emission testing prior to permit expiration date, based on the average of three Department validated stack test runs. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	SO3 and H2SO4, as converted and expressed as H2SO4: Recordkeeping by stack test results upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	Stack Test - Submit protocol, conduct test and submit results: Upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]
14	TSP <= 4.4 lb/hr from modification application BOP120003. The emission limitations shall apply at all times when MSW is being combusted, except during start-up and shutdown as defined in this operating permit. [N.J.A.C. 7:27-22.16(a)]	TSP: Monitored by stack emission testing annually, based on the average of three Department validated stack test runs. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	TSP: Recordkeeping by stack test results upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	Stack Test - Submit protocol, conduct test and submit results: Upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]

New Jersey Department of Environmental Protection

Facility Specific Requirements

U1 MWC #1, 2, 3 Municipal Waste Combustors (E1, E2, and E3)

OS10 Operation of MWC #1 at Maximum Input (423 MMBtu/hr) with Baghouse, OS11 Operation of MWC #2 at Maximum Input (423 MMBtu/hr) with Baghouse, OS12 Operation of MWC #3 at Maximum Input (423 MMBtu/hr) with Baghouse

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
15	Particulate Emissions <= 12 mg/dscm @ 7% O2. [From modification BOP090003]. [N.J.A.C. 7:27-22.16(a)]	Particulate Emissions: Monitored by stack emission testing annually, based on the average of three Department validated stack test runs. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	Particulate Emissions: Recordkeeping by stack test results upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	Stack Test - Submit protocol, conduct test and submit results: Upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]
16	Particulate Emissions <= 12 mg/dscm @ 7% O2 for average of 3 individual test runs when including a test run during which soot blowing is performed. [From modification BOP090003]. [N.J.A.C. 7:27-22.16(a)]	Particulate Emissions: Monitored by stack emission testing annually, based on the average of three Department validated stack test runs. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	Particulate Emissions: Recordkeeping by stack test results upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	Stack Test - Submit protocol, conduct test and submit results: Upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]
17	PM-10 (Total) <= 17 lb/hr. [From modification BOP090003]. [N.J.A.C. 7:27-22.16(a)]	PM-10 (Total): Monitored by stack emission testing annually, based on the average of three Department validated stack test runs. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	PM-10 (Total): Recordkeeping by stack test results upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	Stack Test - Submit protocol, conduct test and submit results: Upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]
18	PM-2.5 (Total) <= 17 lb/hr. [From modification BOP090003]. [N.J.A.C. 7:27-22.16(a)]	PM-2.5 (Total): Monitored by stack emission testing annually, based on the average of three Department validated stack test runs. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	PM-2.5 (Total): Recordkeeping by stack test results upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	Stack Test - Submit protocol, conduct test and submit results: Upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]
19	Any visible emissions shall not exceed an average Opacity <= 10 %. [N.J.A.C. 7:27-22.16(e)]	Opacity: Monitored by continuous opacity monitoring system continuously, based on 6 minute blocks. The discrete block average will begin on the hour. [N.J.A.C. 7:27-22.16(e)]	Opacity: Recordkeeping by strip chart or data acquisition (DAS) system continuously. [N.J.A.C. 7:27-22.16(e)]	Submit an Excess Emissions and Monitoring Systems Performance Report (EEMPR): On or before every April 30, July 30, October 30, and January 30 for the preceding quarter year (the quarter years begin on January 1, April 1, July 1, and October 1) electronically through the NJDEP online EEMPR web portal. Any non-compliance shall be reported. [N.J.A.C. 7:27-22.16(o)]
20	Arsenic compounds <= 0.0037 lb/hr. [From modification BOP090003]. [N.J.A.C. 7:27-22.16(a)]	Arsenic compounds: Monitored by stack emission testing prior to permit expiration date, based on the average of three Department validated stack test runs. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	Arsenic compounds: Recordkeeping by stack test results upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	Stack Test - Submit protocol, conduct test and submit results: Upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]
21	Beryllium compounds <= 0.00025 lb/hr. [N.J.A.C. 7:27-22.16(a)]	Beryllium compounds: Monitored by stack emission testing prior to permit expiration date, based on the average of three Department validated stack test runs. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	Beryllium compounds: Recordkeeping by stack test results upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	Stack Test - Submit protocol, conduct test and submit results: Upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]
22	Cadmium compounds <= 0.0037 lb/hr. [From modification BOP090003]. [N.J.A.C. 7:27-22.16(a)]	Cadmium compounds: Monitored by stack emission testing annually, based on the average of three Department validated stack test runs. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	Cadmium compounds: Recordkeeping by stack test results upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	Stack Test - Submit protocol, conduct test and submit results: Upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]
23	Chromium compounds <= 0.012 lb/hr. [N.J.A.C. 7:27-22.16(a)]	Chromium compounds: Monitored by stack emission testing prior to permit expiration date, based on the average of three Department validated stack test runs. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	Chromium compounds: Recordkeeping by stack test results upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	Stack Test - Submit protocol, conduct test and submit results: Upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]

New Jersey Department of Environmental Protection

Facility Specific Requirements

U1 MWC #1, 2, 3 Municipal Waste Combustors (E1, E2, and E3)

OS10 Operation of MWC #1 at Maximum Input (423 MMBtu/hr) with Baghouse, OS11 Operation of MWC #2 at Maximum Input (423 MMBtu/hr) with Baghouse, OS12 Operation of MWC #3 at Maximum Input (423 MMBtu/hr) with Baghouse

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
24	HCl Emissions <= 21.6 lb/hr. [N.J.A.C. 7:27-22.16(e)]	HCl Emissions: Monitored by stack emission testing annually, based on each of three Department validated stack test runs. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	HCl Emissions: Recordkeeping by stack test results upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	Stack Test - Submit protocol, conduct test and submit results: Upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]
25	Hydrogen fluoride <= 0.82 lb/hr. [N.J.A.C. 7:27-22.16(e)]	Hydrogen fluoride: Monitored by stack emission testing prior to permit expiration date, based on each of three Department validated stack test runs. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	Hydrogen fluoride: Recordkeeping by stack test results upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	Stack Test - Submit protocol, conduct test and submit results: Upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]
26	Lead compounds <= 0.037 lb/hr. [From modification BOP090003]. [N.J.A.C. 7:27-22.16(a)]	Lead compounds: Monitored by stack emission testing annually, based on the average of three Department validated stack test runs. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	Lead compounds: Recordkeeping by stack test results upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	Stack Test - Submit protocol, conduct test and submit results: Upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]
27	Mercury compounds <= 0.01 lb/hr based on concentration limit of 28 ugms/dscm. [From modification BOP090003]. [N.J.A.C. 7:27-22.16(a)]	Mercury compounds: Monitored by stack emission testing annually, based on the average of three Department validated stack test runs. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	Mercury compounds: Recordkeeping by stack test results upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	Stack Test - Submit protocol, conduct test and submit results: Upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]
28	Nickel compounds <= 0.0033 lb/hr. [N.J.A.C. 7:27-22.16(a)]	Nickel compounds: Monitored by stack emission testing prior to permit expiration date, based on the average of three Department validated stack test runs. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	Nickel compounds: Recordkeeping by stack test results upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	Stack Test - Submit protocol, conduct test and submit results: Upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]
29	Dioxins/Furans (Total) <= 0.000011 lb/hr from modification BOP090003, based on federal concentration limit of 30 ng/dscm @ 7% O ₂ . [N.J.A.C. 7:27-22.16(a)]	Dioxins/Furans (Total): Monitored by stack emission testing annually, based on the average of three Department validated stack test runs. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	Dioxins/Furans (Total): Recordkeeping by stack test results upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	Stack Test - Submit protocol, conduct test and submit results: Upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]
30	TCDD Emissions (2,3,7,8-) <= 0.00001 lb/hr. [N.J.A.C. 7:27-22.16(e)]	TCDD Emissions (2,3,7,8-): Monitored by stack emission testing annually, based on the average of three Department validated stack test runs. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	TCDD Emissions (2,3,7,8-): Recordkeeping by stack test results upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	Stack Test - Submit protocol, conduct test and submit results: Upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]
31	Polycyclic aromatic hydrocarbons, or Polycyclic organic matter <= 0.29 lb/hr. [N.J.A.C. 7:27-22.16(a)]	Polycyclic organic matter: Monitored by stack emission testing prior to permit expiration date, based on the average of three Department validated stack test runs. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	Polycyclic organic matter: Recordkeeping by stack test results upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	Stack Test - Submit protocol, conduct test and submit results: Upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]
32	Emissions of benzo(a) pyrene, carbon tetrachloride, formaldehyde, perchloroethylene (tetrachloroethylene), trichloroethylene and vinyl chloride shall be below the reporting threshold of N.J.A.C. 7:27-22, Tables A & B and must be measured using methods approved by DEP. [N.J.A.C. 7:27-22.16(e)]	Monitored by stack emission testing prior to permit expiration date, based on the average of three Department validated stack test runs. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	Recordkeeping by stack test results upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	Stack Test - Submit protocol, conduct test and submit results: Upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]

New Jersey Department of Environmental Protection

Facility Specific Requirements

U1 MWC #1, 2, 3 Municipal Waste Combustors (E1, E2, and E3)

OS10 Operation of MWC #1 at Maximum Input (423 MMBtu/hr) with Baghouse, OS11 Operation of MWC #2 at Maximum Input (423 MMBtu/hr) with Baghouse, OS12 Operation of MWC #3 at Maximum Input (423 MMBtu/hr) with Baghouse

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
33	Ammonia <= 10.1 lb/hr. [N.J.A.C. 7:27-22.16(e)]	Ammonia: Monitored by stack emission testing prior to permit expiration date, based on each of three Department validated stack test runs. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	Ammonia: Recordkeeping by stack test results upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	Stack Test - Submit protocol, conduct test and submit results: Upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]
34	Operating Control Efficiency >= 70 % control. Permittee shall equip and operate the facility with a vapor control system that reduces the total acid gas emissions to the outdoor atmosphere by no less than 70 percent by weight. This equipment shall be in operation at any time waste is being charged to the combustor. [N.J.A.C. 7:27-22.16(e)]	Operating Control Efficiency: Monitored by stack emission testing upon request of the Department, based on the average of three 1-hour tests. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	Operating Control Efficiency: Recordkeeping by stack test results upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]	Stack Test - Submit protocol, conduct test and submit results: Upon occurrence of event. See stack testing requirements in U1 OS Summary. [N.J.A.C. 7:27-22.16(o)]
35	Scrubbing Medium Inlet Pressure <= 3,600 inches. [N.J.A.C. 7:27-22.16(a)]	Scrubbing Medium Inlet Pressure: Monitored by pressure measurement device daily when in operation. [N.J.A.C. 7:27-22.16(o)]	Scrubbing Medium Inlet Pressure: Recordkeeping by manual logging of parameter or storing data in a computer data system daily. Records shall be kept in a logbook or in readily available computer files. [N.J.A.C. 7:27-22.16(o)]	None.
36	SO2: monitor shall assure that acid gas absorber system is operating correctly. [N.J.A.C. 7:27-22.16(a)]	SO2: Monitored by continuous emission monitoring system continuously. [N.J.A.C. 7:27-22.16(o)]	SO2: Recordkeeping by manual logging of parameter or storing data in a computer data system each week during operation. [N.J.A.C. 7:27-22.16(o)]	Submit an Excess Emissions and Monitoring Systems Performance Report (EEMPR): On or before every April 30, July 30, October 30, and January 30 for the preceding quarter year (the quarter years begin on January 1, April 1, July 1, and October 1) electronically through the NJDEP online EEMPR web portal. [N.J.A.C. 7:27-22.16(o)]
37	Particulate Emissions: Continuous opacity monitor shall assure that the baghouse is operating correctly. [N.J.A.C. 7:27-22.16(a)]	Particulate Emissions: Monitored by continuous opacity monitoring system continuously. [N.J.A.C. 7:27-22.16(o)]	Particulate Emissions: Recordkeeping by manual logging of parameter or storing data in a computer data system each week during operation. [N.J.A.C. 7:27-22.16(o)]	Submit an Excess Emissions and Monitoring Systems Performance Report (EEMPR): On or before every April 30, July 30, October 30, and January 30 for the preceding quarter year (the quarter years begin on January 1, April 1, July 1, and October 1) electronically through the NJDEP online EEMPR web portal. [N.J.A.C. 7:27-22.16(o)]

New Jersey Department of Environmental Protection

Facility Specific Requirements

U6 Lime Storage Silo A (E4), U7 Lime Storage Silo B (E5), U8 Lime Storage Silo C (E6)

OS SUMMARY

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
1	Maximum allowable particulate emission rate from PT4 based on 0.02 grains per SCF. Particulate Emissions <= 0.5 lb/hr. [N.J.A.C. 7:27- 6.2(a)]	None.	None.	None.
2	The owner or operator shall not use this emission unit in a manner which will cause visible emissions greater than 20 percent opacity, exclusive of condensed water vapor, for a period longer than three minutes in any consecutive 30-minute period. [N.J.A.C. 7:27-6.2(d)] and [N.J.A.C. 7:27- 6.2(e)]	None.	None.	None.
3	The permittee shall not use the equipment in a manner which will cause visible emissions, exclusive of condensed water vapor. [N.J.A.C. 7:27-22.16(e)]	None.	None.	None.
4	Annual emission limit from the preconstruction permit. TSP <= 0.876 tons/yr. [N.J.A.C. 7:27-22.16(e)]	None.	None.	None.
5	Annual emission limit from the operating permit application. PM-10 (Total) <= 0.876 tons/yr. [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.
6	Maximum emission rate imposed from preconstruction permit. TSP <= 0.2 lb/hr. [N.J.A.C. 7:27-22.16(e)]	None.	None.	None.
7	PM-10 (Total) <= 0.2 lb/hr Maximum emission rate from operating permit application. [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.
8	All particulate emissions from each emission unit shall be exhausted through a dust collector (CD1013, CD1014, or CD1015, as appropriate.) [N.J.A.C. 7:27-22.16(e)]	None.	None.	None.
9	The owner or operator shall inspect and maintain the dust collector and replace the filter media on a schedule necessary to achieve the required particulate control efficiency as specified by the manufacturer. [N.J.A.C. 7:27-22.16(a)]	Monitored by visual determination once every 2 weeks. [N.J.A.C. 7:27-22.16(o)]	Recordkeeping by data acquisition system (DAS) / electronic data storage upon occurrence of event , or manually in a permanently bound logbook. Record each inspection and maintenance event in a permanently bound logbook or readily accessible computer memory. [N.J.A.C. 7:27-22.16(o)]	None.

New Jersey Department of Environmental Protection

Facility Specific Requirements

U9 Lime Slaker Vent A (E9), U10 Lime Slaker Vent B (E10)

OS SUMMARY

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
1	Maximum allowable particulate emission rate from PT9 based on 0.02 grains per SCF. Particulate Emissions <= 0.5 lb/hr. [N.J.A.C. 7:27- 6.2(a)]	None.	None.	None.
2	The owner or operator shall not use this emission unit in a manner which will cause visible emissions greater than 20 percent opacity, exclusive of condensed water vapor, for a period longer than three minutes in any consecutive 30-minute period. [N.J.A.C. 7:27-6.2(d)] and [N.J.A.C. 7:27- 6.2(e)]	None.	None.	None.
3	The permittee shall not use the equipment in a manner which will cause visible emissions, exclusive of condensed water vapor. [N.J.A.C. 7:27-22.16(e)]	None.	None.	None.
4	Annual emission limit from the preconstruction permit. TSP <= 0.027 tons/yr. [N.J.A.C. 7:27-22.16(e)]	None.	None.	None.
5	Annual emission limit from the operating permit. application. PM-10 (Total) <= 0.027 tons/yr. [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.
6	Maximum emission rate imposed from preconstruction permit. Particulate Emissions <= 0.0063 lb/hr. [N.J.A.C. 7:27-22.16(e)]	None.	None.	None.
7	PM-10 (Total) <= 0.0063 lb/hr Maximum emission rate from operating permit application. [N.J.A.C. 7:27-22.16 (a)]	None.	None.	None.

New Jersey Department of Environmental Protection

Facility Specific Requirements

**U11 Activated Carbon Storage Silo (E14)
OS SUMMARY**

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
1	Particulate Emissions <= 0.5 lb/hr. Maximum allowable particulate emission rate from source emission point based on 99% efficiency of collection or based on 0.02 grains per SCF of stack gas flow as determined in the Table at N.J.A.C. 7:27-6.2(a). [N.J.A.C. 7:27- 6.2(a)]	None.	None.	None.
2	The owner or operator shall not use this emission unit in a manner which will cause visible emissions greater than 20 percent opacity, exclusive of condensed water vapor, for a period longer than three minutes in any consecutive 30-minute period. [N.J.A.C. 7:27-6.2(d)] and [N.J.A.C. 7:27- 6.2(e)]	None.	None.	None.
3	The permittee shall not use the equipment in a manner which will cause visible emissions, exclusive of condensed water vapor. [N.J.A.C. 7:27-22.16(e)]	None.	None.	None.
4	Annual emission limit from the preconstruction permit. TSP <= 0.9 tons/yr. [N.J.A.C. 7:27-22.16(e)]	None.	None.	None.
5	Annual emission limit from the operating permit application. PM-10 (Total) <= 0.9 tons/yr. [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.
6	Maximum emission rate imposed from preconstruction permit. TSP <= 0.2 lb/hr. [N.J.A.C. 7:27-22.16(e)]	None.	None.	None.
7	Maximum emission rate from operating permit application. PM-10 (Total) <= 0.2 lb/hr. [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.
8	All particulate emissions from this emission unit shall be exhausted through a dust collector (CD1020). [N.J.A.C. 7:27-22.16(e)]	None.	None.	None.
9	The owner or operator shall inspect and maintain the dust collector and replace the filter media on a schedule necessary to achieve the required particulate control efficiency as specified by the manufacturer. [N.J.A.C. 7:27-22.16(a)]	Monitored by visual determination once every 2 weeks. [N.J.A.C. 7:27-22.16(o)]	Recordkeeping by data acquisition system (DAS) / electronic data storage upon occurrence of event , or manually in a permanently bound logbook. Record each inspection and maintenance event. [N.J.A.C. 7:27-22.16(o)]	None.

New Jersey Department of Environmental Protection

Facility Specific Requirements

**U12 Flyash Conditioning Room (E12,E13)
OS SUMMARY**

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
1	Maximum allowable particulate emission rate from source emission point based on 99% efficiency of collection or based on 0.02 grains per SCF of stack gas flow as determined in the Table at N.J.A.C. 7:27-6.2(a). Particulate Emissions <= 0.5 lb/hr. [N.J.A.C. 7:27- 6.2(a)]	None.	None.	None.
2	The owner or operator shall not use this emission unit in a manner which will cause visible emissions greater than 20 percent opacity, exclusive of condensed water vapor, for a period longer than three minutes in any consecutive 30-minute period. [N.J.A.C. 7:27-6.2(d)] and [N.J.A.C. 7:27- 6.2(e)]	None.	None.	None.
3	Annual emission limit from the preconstruction permit. TSP <= 0.131 tons/yr. [N.J.A.C. 7:27-22.16(e)]	None.	None.	None.
4	Annual emission limit from the operating permit application. PM-10 (Total) <= 0.15 tons/yr. [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.
5	Maximum emission rate imposed from preconstruction permit. Particulate Emissions <= 0.015 lb/hr. [N.J.A.C. 7:27-22.16(e)]	None.	None.	None.
6	PM-10 (Total) <= 0.015 lb/hr Maximum emission rate from operating permit application. [N.J.A.C. 7:27-22.16 (a)]	None.	None.	None.
7	All particulate emissions from this emission unit shall be exhausted through dust collectors CD1017 or CD1018 and then exhaust the building through CD1019. [N.J.A.C. 7:27-22.16(e)]	None.	None.	None.
8	The owner or operator shall inspect and maintain the dust collectors and replace the filter media on a schedule necessary to achieve the required particulate control efficiency as specified by the manufacturer. [N.J.A.C. 7:27-22.16(a)]	Monitored by visual determination once every 2 weeks. [N.J.A.C. 7:27-22.16(o)]	Recordkeeping by manual logging of parameter upon occurrence of event. Record each inspection and maintenance event in a permanently bound logbook or readily accessible computer memory. [N.J.A.C. 7:27-22.16(o)]	None.

New Jersey Department of Environmental Protection

Facility Specific Requirements

U13 7.4 MMBtu/hr, 740 KW Diesel Engine-Driven Emergency Generator (E7)

OS SUMMARY

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
1	Opacity <= 20 % , exclusive of visible condensed water vapor, except for a period of not longer than 10 consecutive seconds. [N.J.A.C. 7:27- 3.5]	None.	None.	None.
2	Particulate Emissions <= 4.2 lb/hr. Particulate emission limit from the combustion of fuel based on rated heat input of source. [N.J.A.C. 7:27- 4.2(a)]	None.	None.	None.
3	Sulfur Content in Fuel <= 2,000 ppmw (0.2 % by weight) for Zone 4 (Essex County). Effective through June 30, 2014. [N.J.A.C. 7:27- 9.2(b)]	Sulfur Content in Fuel: Monitored by review of fuel delivery records per delivery showing fuel sulfur content. [N.J.A.C. 7:27-22.16(o)]	Sulfur Content in Fuel: Recordkeeping by invoices / bills of lading / certificate of analysis per delivery showing fuel sulfur content. [N.J.A.C. 7:27-22.16(o)]	None.
4	Sulfur Content in Fuel <= 500 ppmw (0.05% by weight). Effective July 1, 2014 through June 30, 2016. [N.J.A.C. 7:27- 9.2(b)]	Sulfur Content in Fuel: Monitored by review of fuel delivery records per delivery showing fuel sulfur content. [N.J.A.C. 7:27-22.16(o)]	Sulfur Content in Fuel: Recordkeeping by invoices / bills of lading / certificate of analysis per delivery showing fuel sulfur content. [N.J.A.C. 7:27-22.16(o)]	None.
5	Sulfur Content in Fuel <= 15 ppmw (0.0015% by weight). Effective July 1, 2016. [N.J.A.C. 7:27- 9.2(b)]	Sulfur Content in Fuel: Monitored by review of fuel delivery records per delivery showing fuel sulfur content. [N.J.A.C. 7:27-22.16(o)]	Sulfur Content in Fuel: Recordkeeping by invoices / bills of lading / certificate of analysis per delivery showing fuel sulfur content. [N.J.A.C. 7:27-22.16(o)]	None.
6	Fuel stored in New Jersey that met the applicable maximum sulfur content standard of Tables 1A or 1B of N.J.A.C. 7:27-9.2 at the time it was stored in New Jersey may be used in New Jersey after the operative date of the applicable standard in Table 1B. [N.J.A.C. 7:27- 9.2 (b)]	None.	None.	None.
7	Generator fuel limited to natural gas, # 2 fuel oil or diesel fuel. [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.

New Jersey Department of Environmental Protection

Facility Specific Requirements

U13 7.4 MMBtu/hr, 740 KW Diesel Engine-Driven Emergency Generator (E7) OS SUMMARY

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
8	<p>Each emergency generator shall be located at the facility and produce mechanical or thermal energy, or electrical power exclusively for use at the facility. Each emergency generator shall be operated only:</p> <ol style="list-style-type: none"> 1. During the performance of normal testing and maintenance procedures, as recommended in writing by the manufacturer and/or as required in writing by a Federal or State law or regulation, 2. When there is power outage or the primary source of mechanical or thermal energy fails because of an emergency, or 3. When there is a voltage reduction issued by PJM and posted on the PJM internet website (www.pjm.com) under the "emergency procedures" menu. [N.J.A.C. 7:27-19.1] 	<p>Monitored by hour/time monitor continuously. [N.J.A.C. 7:27-22.16(o)]</p>	<p>Recordkeeping by manual logging of parameter or storing data in a computer data system at the approved frequency. The owner or operator shall maintain on site and record in a logbook or computer data system, the following information:</p> <ol style="list-style-type: none"> 1. Once per month, the total operating time from the generator's hour meter. 2. For each time the emergency generator is specifically operated for testing or maintenance: <ol style="list-style-type: none"> i. The reason for its operation; ii. The date(s) of operation and the start up and shut down time; iii. The total operating time for testing or maintenance based on the generator's hour meter; and iv. The name of the operator; and 3. If a voltage reduction is the reason for the use of the emergency generator, a copy of the voltage reduction notification from PJM or other documentation of the voltage reduction. <p>The owner or operator of an emergency generator shall maintain the above records for a period no less than five years after the record was made and shall make the records readily available to the Department or the EPA upon request. [N.J.A.C. 7:27-19.11(a)] and [N.J.A.C. 7:27-19.11(b)]</p>	<p>None.</p>
9	<p>This emergency generator shall not be used:</p> <ol style="list-style-type: none"> 1. For normal testing and maintenance on days when the Department forecasts air quality anywhere in New Jersey to be "unhealthy for sensitive groups," "unhealthy," or "very unhealthy" as defined in the EPA's Air Quality Index at http://airnow.gov/, as supplemented or amended and incorporated herein by reference, unless required in writing by a Federal or State law or regulation. Procedures for determining the air quality forecasts for New Jersey are available at the Department's air quality permitting web site at http://www.state.nj.us/dep/aqpp/aqforecast; and 2. As a source of energy or power after the primary energy or power source has become operable again. If the primary energy or power source is under the control of the owner or operator of the emergency generator, the owner or operator shall make a reasonable, timely effort to repair the primary energy or power source. [N.J.A.C. 7:27-19.2(d)] 	<p>None.</p>	<p>None.</p>	<p>None.</p>

New Jersey Department of Environmental Protection

Facility Specific Requirements

U13 7.4 MMBtu/hr, 740 KW Diesel Engine-Driven Emergency Generator (E7) OS SUMMARY

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
10	Hours of Operation <= 100 hr/yr for testing and maintenance. The limit on the allowable hours for testing and maintenance in accordance with the documentation from manufacturer, the vendor, or the insurance company associated with the engine. [N.J.A.C. 7:27-22.16(a)]	Hours of Operation: Monitored by hour/time monitor continuously. [N.J.A.C. 7:27-22.16(o)]	Hours of Operation: Recordkeeping by manual logging of parameter or storing data in a computer data system each month during operation. The owner or operator shall maintain onsite and record in a logbook or computer data system the total operating time for testing and maintenance from the generator's hour meter. The total hours of operation limit shall be for purposes of establishing potential to emit. [N.J.A.C. 7:27-19.11]	None.
11	Hours of Operation <= 400 hr/yr for emergency operation only. [N.J.A.C. 7:27-22.16(a)]	Hours of Operation: Monitored by hour/time monitor continuously. [N.J.A.C. 7:27-22.16(o)]	Hours of Operation: Recordkeeping by manual logging of parameter or storing data in a computer data system each month during operation. The owner or operator shall calculate hours for emergency operation by deducting hours for testing and maintenance from the total operating time from the generator's hour meter. The total hours of operation limit shall be for purposes of establishing potential to emit. [N.J.A.C. 7:27-19.11]	Submit notification: Upon occurrence of event. The Permittee shall contact the Regional Enforcement Office (REO) if the actual hours of emergency operation exceed the total time allowed for emergencies under this permit. The Permittee shall call the appropriate REO within 24 hours of the occurrence of excess emergency operation and submit written notification of the excess emergency operation within 72 hours of the occurrence and may request additional operational hours for situations meeting the definition of an emergency as defined at N.J.A.C. 7:27-22. [N.J.A.C. 7:27-22.16(o)]
12	Maximum Gross Heat Input <= 7.4 MMBTU/hr (HHV). [N.J.A.C. 7:27-22.16(a)]	Other: Engine Rated Capacity. [N.J.A.C. 7:27-22.16(o)].	None.	None.
13	VOC (Total) <= 0.183 tons/yr. Annual emission limit based on total permitted hours per year of operation. [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.
14	NOx (Total) <= 6.53 tons/yr. Annual emission limit based on total permitted hours per year of operation. [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.
15	CO <= 1.7 tons/yr. Annual emission limit based on total permitted hours per year of operation. [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.
16	SO2 <= 0.392 tons/yr. Annual emission limit based on total permitted hours per year of operation. [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.
17	TSP <= 0.653 tons/yr. Annual emission limit based on total permitted hours per year of operation. [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.
18	PM-10 (Total) <= 0.653 tons/yr. Annual emission limit based on total permitted hours per year of operation. [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.

New Jersey Department of Environmental Protection

Facility Specific Requirements

**U14 1.59 MMBtu/hr Emergency Diesel Engine-Driven Fire Pump (E8)
OS SUMMARY**

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
1	Opacity <= 20 % , exclusive of visible condensed water vapor, except for a period of not longer than 10 consecutive seconds. [N.J.A.C. 7:27- 3.5]	None.	None.	None.
2	Particulate Emissions <= 4.2 lb/hr. Particulate emission limit from the combustion of fuel based on rated heat input of source. [N.J.A.C. 7:27- 4.2(a)]	None.	None.	None.
3	Sulfur Content in Fuel <= 2,000 ppmw (0.2 % by weight) for Zone 4 (Essex County). Effective through June 30, 2014. [N.J.A.C. 7:27- 9.2(b)]	Sulfur Content in Fuel: Monitored by review of fuel delivery records per delivery showing fuel sulfur content. [N.J.A.C. 7:27-22.16(o)]	Sulfur Content in Fuel: Recordkeeping by invoices / bills of lading / certificate of analysis per delivery showing fuel sulfur content. [N.J.A.C. 7:27-22.16(o)]	None.
4	Sulfur Content in Fuel <= 500 ppmw (0.05% by weight). Effective July 1, 2014 through June 30, 2016. [N.J.A.C. 7:27- 9.2(b)]	Sulfur Content in Fuel: Monitored by review of fuel delivery records per delivery showing fuel sulfur content. [N.J.A.C. 7:27-22.16(o)]	Sulfur Content in Fuel: Recordkeeping by invoices / bills of lading / certificate of analysis per delivery showing fuel sulfur content. [N.J.A.C. 7:27-22.16(o)]	None.
5	Sulfur Content in Fuel <= 15 ppmw (0.0015% by weight). Effective July 1, 2016. [N.J.A.C. 7:27- 9.2(b)]	Sulfur Content in Fuel: Monitored by review of fuel delivery records per delivery showing fuel sulfur content. [N.J.A.C. 7:27-22.16(o)]	Sulfur Content in Fuel: Recordkeeping by invoices / bills of lading / certificate of analysis per delivery showing fuel sulfur content. [N.J.A.C. 7:27-22.16(o)]	None.
6	Fuel stored in New Jersey that met the applicable maximum sulfur content standard of Tables 1A or 1B of N.J.A.C. 7:27-9.2 at the time it was stored in New Jersey may be used in New Jersey after the operative date of the applicable standard in Table 1B. [N.J.A.C. 7:27- 9.2 (b)]	None.	None.	None.
7	Generator fuel limited to natural gas, # 2 fuel oil or diesel fuel. [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.

New Jersey Department of Environmental Protection

Facility Specific Requirements

**U14 1.59 MMBtu/hr Emergency Diesel Engine-Driven Fire Pump (E8)
OS SUMMARY**

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
8	<p>Each emergency generator shall be located at the facility and produce mechanical or thermal energy, or electrical power exclusively for use at the facility. Each emergency generator shall be operated only:</p> <ol style="list-style-type: none"> 1. During the performance of normal testing and maintenance procedures, including other fire protection equipment, as recommended in writing by the fire pump or fire protection system manufacturer and/or as required in writing by a Federal or State law or regulation, 2. When there is power outage or the primary source of mechanical or thermal energy fails because of an emergency, or 3. When there is a voltage reduction issued by PJM and posted on the PJM internet website (www.pjm.com) under the "emergency procedures" menu. [N.J.A.C. 7:27-22.16(a)] and [N.J.A.C. 7:27-19.1] 	<p>Monitored by hour/time monitor continuously. [N.J.A.C. 7:27-22.16(o)]</p>	<p>Recordkeeping by manual logging of parameter or storing data in a computer data system at the approved frequency. The owner or operator shall maintain on site and record in a logbook or computer data system, the following information:</p> <ol style="list-style-type: none"> 1. Once per month, the total operating time from the generator's hour meter. 2. For each time the emergency generator is specifically operated for testing or maintenance: <ol style="list-style-type: none"> i. The reason for its operation; ii. The date(s) of operation and the start up and shut down time; iii. The total operating time for testing or maintenance based on the generator's hour meter; and iv. The name of the operator; and 3. If a voltage reduction is the reason for the use of the emergency generator, a copy of the voltage reduction notification from PJM or other documentation of the voltage reduction. <p>The owner or operator of an emergency generator shall maintain the above records for a period no less than five years after the record was made and shall make the records readily available to the Department or the EPA upon request. [N.J.A.C. 7:27-19.11(a)] and [N.J.A.C. 7:27-19.11(b)]</p>	<p>None.</p>
9	<p>This emergency generator shall not be used:</p> <ol style="list-style-type: none"> 1. For normal testing and maintenance on days when the Department forecasts air quality anywhere in New Jersey to be "unhealthy for sensitive groups," "unhealthy," or "very unhealthy" as defined in the EPA's Air Quality Index at http://airnow.gov/, as supplemented or amended and incorporated herein by reference, unless required in writing by a Federal or State law or regulation. Procedures for determining the air quality forecasts for New Jersey are available at the Department's air quality permitting web site at http://www.state.nj.us/dep/aqpp/aqforecast; and 2. As a source of energy or power after the primary energy or power source has become operable again. If the primary energy or power source is under the control of the owner or operator of the emergency generator, the owner or operator shall make a reasonable, timely effort to repair the primary energy or power source. [N.J.A.C. 7:27-19.2(d)] 	<p>None.</p>	<p>None.</p>	<p>None.</p>

New Jersey Department of Environmental Protection

Facility Specific Requirements

U14 1.59 MMBtu/hr Emergency Diesel Engine-Driven Fire Pump (E8) OS SUMMARY

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
10	Hours of Operation <= 50 hr/yr for testing and maintenance. The limit on the allowable hours for testing and maintenance in accordance with the documentation from manufacturer, the vendor, or the insurance company associated with the engine. [N.J.A.C. 7:27-22.16(a)]	Hours of Operation: Monitored by hour/time monitor continuously. [N.J.A.C. 7:27-22.16(o)]	Hours of Operation: Recordkeeping by manual logging of parameter or storing data in a computer data system each month during operation. The owner or operator shall maintain onsite and record in a logbook or computer data system the total operating time for testing and maintenance from the generator's hour meter. The total hours of operation limit shall be for purposes of establishing potential to emit. [N.J.A.C. 7:27-19.11]	None.
11	Hours of Operation <= 450 hr/yr for emergency operation only. [N.J.A.C. 7:27-22.16(a)]	Hours of Operation: Monitored by hour/time monitor continuously. [N.J.A.C. 7:27-22.16(o)]	Hours of Operation: Recordkeeping by manual logging of parameter or storing data in a computer data system each month during operation. The owner or operator shall calculate hours for emergency operation by deducting hours for testing and maintenance from the total operating time from the generator's hour meter. The total hours of operation limit shall be for purposes of establishing potential to emit. [N.J.A.C. 7:27-19.11]	Submit notification: Upon occurrence of event. The Permittee shall contact the Regional Enforcement Office (REO) if the actual hours of emergency operation exceed the total time allowed for emergencies under this permit. The Permittee shall call the appropriate REO within 24 hours of the occurrence of excess emergency operation and submit written notification of the excess emergency operation within 72 hours of the occurrence and may request additional operational hours for situations meeting the definition of an emergency as defined at N.J.A.C. 7:27-22. [N.J.A.C. 7:27-22.16(o)]
12	Maximum Gross Heat Input <= 1.59 MMBTU/hr (HHV). [N.J.A.C. 7:27-22.16(a)]	Other: Engine Rated Capacity. [N.J.A.C. 7:27-22.16(o)].	None.	None.
13	VOC (Total) <= 0.105 tons/yr. Annual emission limit based on total permitted hours per year of operation. [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.
14	NOx (Total) <= 1.3 tons/yr. Annual emission limit based on total permitted hours per year of operation. [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.
15	CO <= 0.286 tons/yr. Annual emission limit based on total permitted hours per year of operation. [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.
16	SO2 <= 0.087 tons/yr. Annual emission limit based on total permitted hours per year of operation. [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.
17	TSP <= 0.094 tons/yr. Annual emission limit based on total permitted hours per year of operation. [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.
18	PM-10 (Total) <= 0.094 tons/yr. Annual emission limit based on total permitted hours per year of operation. [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.

New Jersey Department of Environmental Protection

Facility Specific Requirements

**U15 Ash and Metals Recovery System (E16, E17, E21-E30)
OS SUMMARY**

Ref.#	Applicable Requirement	Monitoring Requirement	Record Keeping Requirement	Submittal/Action Requirement
1	Summary of Federal Rules applicable to this Emission Unit: NSPS 40 CFR Part 60 Subpart A (See GR1) NSPS 40 CFR Part 62 Subpart FFF [40 CFR Federal Rules Summary]	None.	None.	None.
2	TSP < 0.5 lb/hr. [N.J.A.C. 7:27- 6.2(a)]	None.	None.	None.
3	Opacity <= 20 % exclusive of condensed water vapor except for a period of longer than three minutes in any consecutive 30-minute period. [N.J.A.C. 7:27-6.2(d)] and. [N.J.A.C. 7:27- 6.2(e)]	None.	None.	None.
4	The permittee shall not use the equipment in a manner which will cause visible emissions, exclusive of condensed water vapor. [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.
5	Total Material Transferred <= 25.5 tons/hr. (Design capacity of bottom ash to metals recovery). [N.J.A.C. 7:27-22.16(a)]	Total Material Transferred: Monitored by documentation of construction once initially. [N.J.A.C. 7:27-22.16(o)]	Total Material Transferred: Recordkeeping by manual logging of parameter or storing data in a computer data system once initially. [N.J.A.C. 7:27-22.16(o)]	None.
6	Total Material Transferred <= 31 tons/hr (Design capacity for both fly ash and bottom ash). [N.J.A.C. 7:27-22.16(a)]	Total Material Transferred: Monitored by documentation of construction once initially. [N.J.A.C. 7:27-22.16(o)]	Total Material Transferred: Recordkeeping by manual logging of parameter or storing data in a computer data system once initially. [N.J.A.C. 7:27-22.16(o)]	None.
7	All particulate emissions from this emission unit shall be exhausted through dust collector CD1022. [N.J.A.C. 7:27-22.16(a)]	None.	None.	None.
8	The owner or operator shall inspect and maintain the dust collectors and replace the filter media on a schedule necessary to achieve the required particulate control efficiency as specified by the manufacturer. [N.J.A.C. 7:27-22.16(a)]	None.	Recordkeeping by manual logging of parameter or storing data in a computer data system upon occurrence of event. Record each inspection and maintenance event. [N.J.A.C. 7:27-22.16(o)]	None.
9	Pressure Drop >= 1 and Pressure Drop <= 6 inches w.c. (across the filter.). [N.J.A.C. 7:27-22.16(a)]	Pressure Drop: Monitored by pressure drop instrument continuously. [N.J.A.C. 7:27-22.16(o)]	Pressure Drop: Recordkeeping by manual logging of parameter or storing data in a computer data system once every 2 weeks. [N.J.A.C. 7:27-22.16(o)]	None.
10	The permittee must not cause visible emissions of combustion ash to the atmosphere from buildings or enclosures of the ash conveying systems (including conveyor transfer points) in excess of 5 percent of the observation period (i.e., 9-minutes per 3-hour period), except during maintenance and repair of ash conveying systems. [40 CFR 62.14106]	Monitored by visual determination annually in accordance with 40 CFR 60.58b(k). [40 CFR 62.14106(a)]	Recordkeeping by manual logging of parameter or storing data in a computer data system annually. The permittee shall maintain records of performance tests for a period of at least 5 years. [40 CFR 62.14109(a)]	None.

New Jersey Department of Environmental Protection

Facility Specific Requirements

BOP260001

New Jersey Department of Environmental Protection

Facility Profile (General)

Facility Information

Facility Name:	Reworld Essex Company
Street Address:	183 RAYMOND BLVD NEWARK NJ 07105 NEWARK, NJ 07105
Mailing Address:	183 RAYMOND BLVD NEWARK NJ 07105 NEWARK, NJ 07105
County:	Essex
Location Description	Municipal Waste Combustion using mass-burn waterwall furnace and boiler that generates electricity.

X-Coordinate	574
Y-Coordinate	4510
Units	UTM Zone 18N - Meters
Datum	Unknown
Coord Source Org	Other/Unknown
Coord Source Type	Other/Unknown
Primary SIC	4953
Secondary SIC	4939
NAICS	562213

BOP260001

New Jersey Department of Environmental Protection Facility Profile (General)

Contact Type: Air Permit Information Contact

Organization	Reworld Essex Company
Name	Patricia Earls
Title	NJ Regional Environmental Manager
Phone	(973) 817-7322
Fax Number	(973) 344-4999
E-mail Address	pearls@reworldwaste.com

Organization Type	Partnership
NJ EIN	75611300000

Mailing Address
183 Raymond Boulevard Newark, NJ 07105

Contact Type: BOP - Operating Permits

Organization	Covanta Essex Company
Name	Patricia Earls
Title	NJ Regional Environmental Manager
Phone	(973) 817-7322
Fax Number	(973) 344-4999
E-mail Address	pearls@covanta.com

Organization Type	Partnership
NJ EIN	75611300000

Mailing Address
183 Raymond Boulevard Newark, NJ 07105

Contact Type: Environmental Officer

Organization	Reworld Essex Company
Name	Patricia Earls
Title	NJ Regional Environmental Manager
Phone	(973) 817-7322
Fax Number	(973) 344-4999
E-mail Address	pearls@reworldwaste.com

Organization Type	Partnership
NJ EIN	75611300000

Mailing Address
183 Raymond Boulevard Newark, NJ 07105

BOP260001

New Jersey Department of Environmental Protection Facility Profile (General)

Contact Type: Fees/Billing Contact

Organization	Reworld Essex Company
Name	Patricia Earls
Title	NJ Regional Environmental Manager
Phone	(973) 817-7322
Fax Number	() -
E-mail Address	pearls@reworldwaste.com

Organization Type	Corporation
NJ EIN	75611300000

Mailing Address
183 Raymond Blvd Newark, NJ 071054798

Contact Type: General Contact

Organization	Reworld Essex Company
Name	Patricia Earls
Title	NJ Regional Environmental Manager
Phone	(973) 817-7322
Fax Number	(973) 344-4999
E-mail Address	pearls@reworldwaste.com

Organization Type	Partnership
NJ EIN	75611300000

Mailing Address
183 Raymond Boulevard Newark, NJ 07105

Contact Type: On-Site Manager

Organization	Reworld Essex Company
Name	Richard Merker
Title	Facility Manager
Phone	(973) 817-7228
Fax Number	(973) 344-4999
E-mail Address	rmerker@reworldwaste.com

Organization Type	Partnership
NJ EIN	75611300000

Mailing Address
183 Raymond Boulevard Newark, NJ 07105

BOP260001

New Jersey Department of Environmental Protection

Facility Profile (General)

Contact Type: Operator

Organization	Reworld Essex Company
Name	Reworld Essex Company
Title	NA
Phone	(973) 344-0900
Fax Number	(973) 344-4999
E-mail Address	pearls@reworldwaste.com

Organization Type	Partnership
NJ EIN	75611300000

Mailing Address
183 Raymond Blvd Newark, NJ 071054798

Contact Type: Owner (Current Primary)

Organization	Reworld Essex Company
Name	Reworld Essex Company
Title	NA
Phone	(973) 344-0900
Fax Number	(973) 344-4999
E-mail Address	pearls@reworldwaste.com

Organization Type	Partnership
NJ EIN	75611300000

Mailing Address
183 Raymond Blvd Newark, NJ 071054798

Contact Type: Responsible Official

Organization	Reworld Essex Company
Name	Richard Merker
Title	Facility Manager
Phone	(973) 817-7228
Fax Number	(973) 344-4999
E-mail Address	rmerker@reworldwaste.com

Organization Type	Partnership
NJ EIN	75611300000

Mailing Address
183 Raymond Boulevard Newark, NJ 07105

New Jersey Department of Environmental Protection

Non-Source Fugitive Emissions

FG NJID	Description of Activity	Location	VOC	NOx	CO	SO2	TSP	PM-10	Pb	HAPS (Total)	Other (Total)
		Total:	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000

New Jersey Department of Environmental Protection
Insignificant Source Emission

IS NJID	Source/Group	Equipment Type	Location	Estimate of Emissions (tpy)									
				VOC Total	NOx	CO	SO2	TSP	PM-10I	Pb	HAPS Total	Other Total	
IS1	No. 2 Fuel Oil Tanks (<10,000 Gallons Capacity)	Storage Vessel											
IS2	Fuel Oil Tank (>10,000 Gallons Capacity)	Storage Vessel											
Total:				0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

New Jersey Department of Environmental Protection

Equipment Inventory

NJID	Facility Designation	Equipment Description	Equipment Type	Certification Number	Installation Date	Grand Fathered	Last Mod. (Since 1968)	Equip. Set NJID
E1	1	MSW Boiler #1	Incinerator	PCP960005	11/3/1990	No	7/29/1997	
E2	2	MSW Boiler #2	Incinerator	PCP960005	11/26/1990	No	7/29/1997	
E3	3	MSW Boiler #3	Incinerator	PCP960005	12/17/1990	No	7/29/1997	
E4	4	Lime Silo A	Manufacturing and Materials Handling Equipment	PCP960001	11/1/1990	No		
E5	5	Lime Silo B	Manufacturing and Materials Handling Equipment	PCP960002	11/1/1990	No		
E6	6	Lime Silo C	Manufacturing and Materials Handling Equipment	PCP960003	11/1/1990	No		
E7	7	Diesel Generator	Emergency Generator	PCP960006	11/1/1990	No		
E8	8	Diesel Fire Pump	Emergency Generator	PCP960007	11/1/1990	No		
E9	9	Lime Slaker Vent A	Manufacturing and Materials Handling Equipment	PCP960010	11/11/1991	No		
E10	10	Lime Slaker Vent B	Manufacturing and Materials Handling Equipment	PCP960013	11/11/1991	No		
E12	12	Flyash Silo 1	Manufacturing and Materials Handling Equipment	PCP960012	11/11/1991	No		
E13	13	Flyash Silo 2	Manufacturing and Materials Handling Equipment	PCP960012	11/11/1991	No		
E14	14	Carbon Silo	Manufacturing and Materials Handling Equipment	PCP960005	12/1/1995	No		

BOP260001

New Jersey Department of Environmental Protection

Equipment Inventory

NJID	Facility Designation	Equipment Description	Equipment Type	Certification Number	Installation Date	Grand Fathered	Last Mod. (Since 1968)	Equip. Set NJID
E16	16	Ash Conveyance Line "A"	Manufacturing and Materials Handling Equipment	PCP960009	11/1/1990	No	11/1/1994	
E17	17	Ash Conveyance Line "B"	Manufacturing and Materials Handling Equipment	PCP960009	11/1/1990	No	11/1/1994	
E21	RH-136-CV	Vibratory Conveyor	Manufacturing and Materials Handling Equipment	BOP120001	10/1/2012	No		
E22	RH-150-SC	Grizzly Scalper	Manufacturing and Materials Handling Equipment	BOP120001	10/1/2012	No		
E23	RH-170-CV	Feeder	Manufacturing and Materials Handling Equipment	BOP120001	10/1/2012	No		
E24	FE-200-MAG	Ferrous Magnet	Manufacturing and Materials Handling Equipment	BOP120001	10/1/2012	No		
E25	RH-160-FD	Vibratory Conveyor	Manufacturing and Materials Handling Equipment	BOP120001	10/1/2012	No		
E26	NF-230-SC	Screen	Manufacturing and Materials Handling Equipment	BOP120001	10/1/2012	No	12/1/2018	
E27	NF-300-ECS	Eddy Current Separator (+3/8)	Manufacturing and Materials Handling Equipment	BOP120001	10/1/2012	No		
E28	NF-400-MSB	Feeder Conveyor	Manufacturing and Materials Handling Equipment	BOP120001	10/1/2012	No	12/1/2018	
E29	NF-410-ECS	Eddy Current Separator (-3/8)	Manufacturing and Materials Handling Equipment	BOP120001	10/1/2012	No		

New Jersey Department of Environmental Protection
Equipment Inventory

NJID	Facility Designation	Equipment Description	Equipment Type	Certification Number	Installation Date	Grand Fathered	Last Mod. (Since 1968)	Equip. Set NJID
E30	E30	Conveyors	Manufacturing and Materials Handling Equipment	BOP120001	10/1/2012	No		

▼ **Incinerator Details**

Make:	<input type="text"/>
Manufacturer:	Foster Wheeler
Model:	<input type="text"/>
Unit Type:	Mass Burn Waterwall ▼
Description:	<input type="text"/>
Maximum Waste Processing Capacity:	<input type="text"/>
Units:	<input type="text"/> ▼
Physical State of Waste being Incinerated:	Solid ▼
Description:	<input type="text"/>
Primary Chamber Maximum Gross Heat Input from Fuel (MMBtu/hr, HHV):	423.00
Primary Chamber Maximum Primary Air (acfm):	109,000.0
Primary Chamber Maximum Gas Flow Rate (acfm):	505,350.0
Primary Chamber Volume (ft ³):	<input type="text"/>
Primary Chamber Minimum Design Operation Temperature (°F):	<input type="text"/>
Primary Chamber Minimum Gas Residence Time (sec):	<input type="text"/>
Secondary Chamber Maximum Gross Heat Input from Fuel (MMBtu/hr, HHV):	<input type="text"/>
Secondary Chamber Maximum Primary Air (acfm):	<input type="text"/>
Secondary Chamber Maximum Gas Flow Rate (acfm):	<input type="text"/>
Secondary Chamber Volume (ft ³):	<input type="text"/>
Secondary Chamber Minimum Design Operation Temperature (°F):	<input type="text"/>
Secondary Chamber Minimum Gas Residence Time (sec):	<input type="text"/>
Secondary Chamber Maximum Outlet Air Flow Rate (acfm):	<input type="text"/>
Secondary Chamber Minimum Outlet Temperature (°F):	<input type="text"/>

Type of Plume Supression:

Do you have a bypass Stack?

 ▾

Have you attached a diagram showing the location and/or the configuration of this equipment?

 ▾

Have you attached any manuf.'s data or specifications to aid the Dept. in its review of this application?

 ▾

Comments:

▼ **Incinerator Details**

Make:	<input type="text"/>
Manufacturer:	Foster Wheeler
Model:	<input type="text"/>
Unit Type:	Mass Burn Waterwall ▼
Description:	<input type="text"/>
Maximum Waste Processing Capacity:	<input type="text"/>
Units:	<input type="text"/> ▼
Physical State of Waste being Incinerated:	Solid ▼
Description:	<input type="text"/>
Primary Chamber Maximum Gross Heat Input from Fuel (MMBtu/hr, HHV):	423.00
Primary Chamber Maximum Primary Air (acfm):	109,000.0
Primary Chamber Maximum Gas Flow Rate (acfm):	505,350.0
Primary Chamber Volume (ft ³):	<input type="text"/>
Primary Chamber Minimum Design Operation Temperature (°F):	<input type="text"/>
Primary Chamber Minimum Gas Residence Time (sec):	<input type="text"/>
Secondary Chamber Maximum Gross Heat Input from Fuel (MMBtu/hr, HHV):	<input type="text"/>
Secondary Chamber Maximum Primary Air (acfm):	<input type="text"/>
Secondary Chamber Maximum Gas Flow Rate (acfm):	<input type="text"/>
Secondary Chamber Volume (ft ³):	<input type="text"/>
Secondary Chamber Minimum Design Operation Temperature (°F):	<input type="text"/>
Secondary Chamber Minimum Gas Residence Time (sec):	<input type="text"/>
Secondary Chamber Maximum Outlet Air Flow Rate (acfm):	<input type="text"/>
Secondary Chamber Minimum Outlet Temperature (°F):	<input type="text"/>

Type of Plume Supression:

Do you have a bypass Stack?

 ▾

Have you attached a diagram showing the location and/or the configuration of this equipment?

 ▾

Have you attached any manuf.'s data or specifications to aid the Dept. in its review of this application?

 ▾

Comments:

▼ Incinerator Details

Make:	<input type="text"/>
Manufacturer:	Foster Wheeler
Model:	<input type="text"/>
Unit Type:	Mass Burn Waterwall ▼
Description:	<input type="text"/>
Maximum Waste Processing Capacity:	<input type="text"/>
Units:	<input type="text"/> ▼
Physical State of Waste being Incinerated:	Solid ▼
Description:	<input type="text"/>
Primary Chamber Maximum Gross Heat Input from Fuel (MMbtu/hr, HHV):	423.00
Primary Chamber Maximum Primary Air (acfm):	109,000.0
Primary Chamber Maximum Gas Flow Rate (acfm):	505,350.0
Primary Chamber Volume (ft ³):	<input type="text"/>
Primary Chamber Minimum Design Operation Temperature (°F):	<input type="text"/>
Primary Chamber Minimum Gas Residence Time (sec):	<input type="text"/>
Secondary Chamber Maximum Gross Heat Input from Fuel (MMBtu/hr, HHV):	<input type="text"/>
Secondary Chamber Maximum Primary Air (acfm):	<input type="text"/>
Secondary Chamber Maximum Gas Flow Rate (acfm):	<input type="text"/>
Secondary Chamber Volume (ft ³):	<input type="text"/>
Secondary Chamber Minimum Design Operation Temperature (°F):	<input type="text"/>
Secondary Chamber Minimum Gas Residence Time (sec):	<input type="text"/>
Secondary Chamber Maximum Outlet Air Flow Rate (acfm):	<input type="text"/>
Secondary Chamber Minimum Outlet Temperature (°F):	<input type="text"/>

Type of Plume Supression:

Do you have a bypass Stack?

 ▾

Have you attached a diagram showing the location and/or the configuration of this equipment?

 ▾

Have you attached any manuf.'s data or specifications to aid the Dept. in its review of this application?

 ▾

Comments:

∨ **Manufacturing and Material Handling Details**

Make :	<input type="text" value="Steel Lime Storage Silo"/>
Manufacturer :	<input type="text"/>
Model :	<input type="text"/>
Type of Manufacturing and Materials Handling Equipment :	<input type="text" value="Lime Storage"/>
Capacity :	<input type="text" value="6,000.0000000000"/>
Units :	<input type="text" value="ft^3"/> ∨
Description (If Other):	<input type="text"/>
Have you attached a diagram showing the location and/or the configuration of this equipment?	<input type="text" value="∨"/>
Have you attached any manuf.'s data or specifications to aid the Dept. in it review of this application?	<input type="text" value="∨"/>
Comments :	<input type="text"/>

∨ **Manufacturing and Material Handling Details**

Make :	<input type="text" value="Steel Lime Storage Silo"/>
Manufacturer :	<input type="text"/>
Model :	<input type="text"/>
Type of Manufacturing and Materials Handling Equipment :	<input type="text" value="Lime Storage"/>
Capacity :	<input type="text" value="6,000.0000000000"/>
Units :	<input type="text" value="ft^3"/> ∨
Description (If Other):	<input type="text"/>
Have you attached a diagram showing the location and/or the configuration of this equipment?	<input type="text" value="∨"/>
Have you attached any manuf.'s data or specifications to aid the Dept. in it review of this application?	<input type="text" value="∨"/>
Comments :	<input type="text"/>

▼ Manufacturing and Material Handling Details	
Make :	<input type="text" value="Steel Lime Storage Silo"/>
Manufacturer :	<input type="text"/>
Model :	<input type="text"/>
Type of Manufacturing and Materials Handling Equipment :	<input type="text" value="Lime Storage"/>
Capacity :	<input type="text" value="6,000.0000000000"/>
Units :	<input style="text-align: right; border-bottom: none; border-right: none; border-left: none; border-top: none; width: 100%;" type="text" value="ft^3"/> ▼
Description (If Other):	<input type="text"/>
Have you attached a diagram showing the location and/or the configuration of this equipment?	<input style="text-align: center; border-bottom: none; border-right: none; border-left: none; border-top: none; width: 100%;" type="text"/> ▼
Have you attached any manuf.'s data or specifications to aid the Dept. in it review of this application?	<input style="text-align: center; border-bottom: none; border-right: none; border-left: none; border-top: none; width: 100%;" type="text"/> ▼
Comments :	<input type="text"/>

∨ **Emergency Generator Details**

Make:

Manufacturer:

Model:

Maximum rated Gross Heat Input (MMBtu/hr-HHV):

Will the equipment be used in excess of 500 hours per year?

Have you attached a diagram showing the location and/or the configuration of this equipment?

Have you attached a diagram showing the location and/or the configuration of this equipment?

Comments:

∨ **Emergency Generator Details**

Make:

Manufacturer:

Model:

Maximum rated Gross Heat Input (MMBtu/hr-HHV):

Will the equipment be used in excess of 500 hours per year?

Have you attached a diagram showing the location and/or the configuration of this equipment?

Have you attached a diagram showing the location and/or the configuration of this equipment?

Comments:

∨ **Manufacturing and Material Handling Details**

Make :	<input type="text"/>
Manufacturer :	<input type="text"/>
Model :	<input type="text"/>
Type of Manufacturing and Materials Handling Equipment :	<input type="text" value="Lime Slaker Vent A"/>
Capacity :	<input type="text"/>
Units :	<input type="text" value="∨"/>
Description (If Other):	<input type="text"/>
Have you attached a diagram showing the location and/or the configuration of this equipment?	<input type="text" value="∨"/>
Have you attached any manuf.'s data or specifications to aid the Dept. in it review of this application?	<input type="text" value="∨"/>
Comments :	<input type="text"/>

∨ **Manufacturing and Material Handling Details**

Make :	<input type="text"/>
Manufacturer :	<input type="text"/>
Model :	<input type="text"/>
Type of Manufacturing and Materials Handling Equipment :	<input type="text" value="Lime Slaker Vent B"/>
Capacity :	<input type="text"/>
Units :	<input type="text" value="∨"/>
Description (If Other):	<input type="text"/>
Have you attached a diagram showing the location and/or the configuration of this equipment?	<input type="text" value="∨"/>
Have you attached any manuf.'s data or specifications to aid the Dept. in it review of this application?	<input type="text" value="∨"/>
Comments :	<input type="text"/>

∨ **Manufacturing and Material Handling Details**

Make :	<input type="text"/>
Manufacturer :	<input type="text"/>
Model :	<input type="text"/>
Type of Manufacturing and Materials Handling Equipment :	<input type="text" value="Flyash System A"/>
Capacity :	<input type="text"/>
Units :	<input type="text" value="∨"/>
Description (If Other):	<input type="text"/>
Have you attached a diagram showing the location and/or the configuration of this equipment?	<input type="text" value="∨"/>
Have you attached any manuf.'s data or specifications to aid the Dept. in it review of this application?	<input type="text" value="∨"/>
Comments :	<input type="text"/>

∨ **Manufacturing and Material Handling Details**

Make :	<input type="text"/>
Manufacturer :	<input type="text"/>
Model :	<input type="text"/>
Type of Manufacturing and Materials Handling Equipment :	<input type="text" value="Flyash System B"/>
Capacity :	<input type="text"/>
Units :	<input type="text" value="∨"/>
Description (If Other):	<input type="text"/>
Have you attached a diagram showing the location and/or the configuration of this equipment?	<input type="text" value="∨"/>
Have you attached any manuf.'s data or specifications to aid the Dept. in it review of this application?	<input type="text" value="∨"/>
Comments :	<input type="text"/>

∨ **Manufacturing and Material Handling Details**

Make :	<input type="text"/>
Manufacturer :	<input type="text"/>
Model :	<input type="text"/>
Type of Manufacturing and Materials Handling Equipment :	<input type="text" value="Steel Activated Carbon Storage Silo"/>
Capacity :	<input type="text" value="2,700.0000000000"/>
Units :	<input type="text" value="ft^3"/> ∨
Description (If Other):	<input type="text"/>
Have you attached a diagram showing the location and/or the configuration of this equipment?	<input type="text" value="∨"/>
Have you attached any manuf.'s data or specifications to aid the Dept. in it review of this application?	<input type="text" value="∨"/>
Comments :	<input type="text"/>

▼ Manufacturing and Material Handling Details	
Make :	<input type="text"/>
Manufacturer :	<input type="text"/>
Model :	<input type="text"/>
Type of Manufacturing and Materials Handling Equipment :	Flyash Building Baghouse & Flyash System A Baghouse
Capacity :	8,500.0000000000
Units :	other units ▼
Description (If Other):	lb/hr
Have you attached a diagram showing the location and/or the configuration of this equipment?	▼
Have you attached any manuf.'s data or specifications to aid the Dept. in it review of this application?	▼
Comments :	<input type="text"/>

∨ **Manufacturing and Material Handling Details**

Make :	<input type="text"/>
Manufacturer :	<input type="text"/>
Model :	<input type="text"/>
Type of Manufacturing and Materials Handling Equipment :	<input type="text" value="Flyash Building Baghouse & Flyash System B Baghouse"/>
Capacity :	<input type="text"/>
Units :	<input type="text" value="∨"/>
Description (If Other):	<input type="text"/>
Have you attached a diagram showing the location and/or the configuration of this equipment?	<input type="text" value="∨"/>
Have you attached any manuf.'s data or specifications to aid the Dept. in it review of this application?	<input type="text" value="∨"/>
Comments :	<input type="text"/>

▼ Manufacturing and Material Handling Details	
Make :	<input type="text"/>
Manufacturer :	<input type="text"/>
Model :	<input type="text"/>
Type of Manufacturing and Materials Handling Equipment :	<input type="text" value="Conveyor"/>
Capacity :	<input type="text" value="22.5000000000"/>
Units :	<input style="text-align: right; border-bottom: none; border-right: none; border-left: none; border-top: none; padding-right: 5px;" type="text" value="other units"/> ▼
Description (If Other):	<input type="text" value="tons/hour"/>
Have you attached a diagram showing the location and/or the configuration of this equipment?	<input type="text" value="▼"/>
Have you attached any manuf.'s data or specifications to aid the Dept. in it review of this application?	<input type="text" value="▼"/>
Comments :	<input type="text" value="Located in current ash/ferrous area"/>

▼ Manufacturing and Material Handling Details	
Make :	<input type="text"/>
Manufacturer :	<input type="text"/>
Model :	<input type="text"/>
Type of Manufacturing and Materials Handling Equipment :	<input type="text" value="Grizzly Scalper"/>
Capacity :	<input type="text" value="22.5000000000"/>
Units :	<input style="text-align: right; border-bottom: none; border-right: none; border-left: none; border-top: none; padding-right: 5px; vertical-align: bottom;" type="text" value="other units"/> ▼
Description (If Other):	<input type="text" value="tons/hour"/>
Have you attached a diagram showing the location and/or the configuration of this equipment?	<input type="text" value="▼"/>
Have you attached any manuf.'s data or specifications to aid the Dept. in it review of this application?	<input type="text" value="▼"/>
Comments :	<input type="text" value="Located in current ash/ferrous area"/>

▼ Manufacturing and Material Handling Details	
Make :	<input type="text"/>
Manufacturer :	<input type="text"/>
Model :	<input type="text"/>
Type of Manufacturing and Materials Handling Equipment :	<input type="text" value="Feeder"/>
Capacity :	<input type="text" value="20.1000000000"/>
Units :	<input style="text-align: right; border-bottom: none; border-right: none; border-left: none; border-top: none; padding-right: 5px;" type="text" value="other units"/> ▼
Description (If Other):	<input type="text" value="tons/hour"/>
Have you attached a diagram showing the location and/or the configuration of this equipment?	<input type="text" value="▼"/>
Have you attached any manuf.'s data or specifications to aid the Dept. in it review of this application?	<input type="text" value="▼"/>
Comments :	<input type="text" value="Located in current ash/ferrous area"/>

▼ Manufacturing and Material Handling Details	
Make :	<input type="text"/>
Manufacturer :	<input type="text"/>
Model :	<input type="text"/>
Type of Manufacturing and Materials Handling Equipment :	<input type="text" value="Ferrous Magnet"/>
Capacity :	<input type="text" value="3.6800000000"/>
Units :	<input style="text-align: right; font-size: small; vertical-align: bottom; padding-right: 5px;" type="text" value="other units"/> ▼
Description (If Other):	<input type="text" value="tons/hour"/>
Have you attached a diagram showing the location and/or the configuration of this equipment?	<input type="text" value="▼"/>
Have you attached any manuf.'s data or specifications to aid the Dept. in it review of this application?	<input type="text" value="▼"/>
Comments :	<input type="text" value="Located in current ash/ferrous area"/>

▼ Manufacturing and Material Handling Details	
Make :	<input type="text"/>
Manufacturer :	<input type="text"/>
Model :	<input type="text"/>
Type of Manufacturing and Materials Handling Equipment :	<input type="text" value="Conveyor"/>
Capacity :	<input type="text" value="2.4000000000"/>
Units :	<input style="text-align: right; border-bottom: none; border-right: none; border-left: none; border-top: none; padding-right: 5px;" type="text" value="other units"/> ▼
Description (If Other):	<input type="text" value="tons/hour"/>
Have you attached a diagram showing the location and/or the configuration of this equipment?	<input type="text" value="▼"/>
Have you attached any manuf.'s data or specifications to aid the Dept. in it review of this application?	<input type="text" value="▼"/>
Comments :	<input type="text" value="Located in current ash/ferrous area."/>

▼ Manufacturing and Material Handling Details	
Make :	<input type="text"/>
Manufacturer :	<input type="text"/>
Model :	<input type="text"/>
Type of Manufacturing and Materials Handling Equipment :	<input type="text" value="Screen"/>
Capacity :	<input type="text" value="16.4000000000"/>
Units :	<input style="text-align: right; border-bottom: none; border-right: none; border-left: none; border-top: none; padding-right: 5px;" type="text" value="other units"/> ▼
Description (If Other):	<input type="text" value="tons/hour"/>
Have you attached a diagram showing the location and/or the configuration of this equipment?	<input type="text" value="▼"/>
Have you attached any manuf.'s data or specifications to aid the Dept. in it review of this application?	<input type="text" value="▼"/>
Comments :	<input type="text" value="Located in current ash/ferrous area."/>

▼ Manufacturing and Material Handling Details	
Make :	<input type="text"/>
Manufacturer :	<input type="text" value="Steinert or equivalent"/>
Model :	<input type="text" value="NES 150-220-5009 or equivalent"/>
Type of Manufacturing and Materials Handling Equipment :	<input type="text" value="Eddy Current Separator"/>
Capacity :	<input type="text" value="6.5900000000"/>
Units :	<input style="text-align: right; border-bottom: none; border-right: none; border-left: none; border-top: none; padding-right: 5px; vertical-align: bottom;" type="text" value="other units"/> ▼
Description (If Other):	<input type="text" value="tons/hour"/>
Have you attached a diagram showing the location and/or the configuration of this equipment?	<input type="text" value="▼"/>
Have you attached any manuf.'s data or specifications to aid the Dept. in it review of this application?	<input type="text" value="▼"/>
Comments :	<input type="text" value="Located in current ash/ferrous area."/>

▼ Manufacturing and Material Handling Details	
Make :	<input type="text"/>
Manufacturer :	<input type="text" value="Joest"/>
Model :	<input type="text"/>
Type of Manufacturing and Materials Handling Equipment :	<input type="text" value="Feeder"/>
Capacity :	<input type="text" value="9.8300000000"/>
Units :	<input style="text-align: right; border-bottom: none; border-right: none; border-left: none; border-top: none; padding-right: 5px;" type="text" value="other units"/> ▼
Description (If Other):	<input type="text" value="tons/hour"/>
Have you attached a diagram showing the location and/or the configuration of this equipment?	<input type="text" value="▼"/>
Have you attached any manuf.'s data or specifications to aid the Dept. in it review of this application?	<input type="text" value="▼"/>
Comments :	<input type="text" value="Located in current ash/ferrous area."/>

▼ Manufacturing and Material Handling Details	
Make :	<input type="text"/>
Manufacturer :	<input type="text" value="Steinert or equivalent"/>
Model :	<input type="text" value="NES 150-210-E6119 or equivalent"/>
Type of Manufacturing and Materials Handling Equipment :	<input type="text" value="Eddy Current Separator"/>
Capacity :	<input type="text" value="9.8300000000"/>
Units :	<input style="text-align: right; border-bottom: none; border-right: none; border-left: none; border-top: none; padding-right: 5px;" type="text" value="other units"/> ▼
Description (If Other):	<input type="text" value="tons/hour"/>
Have you attached a diagram showing the location and/or the configuration of this equipment?	<input type="text" value="▼"/>
Have you attached any manuf.'s data or specifications to aid the Dept. in it review of this application?	<input type="text" value="▼"/>
Comments :	<input type="text" value="Located in current ash/ferrous area."/>

▼ Manufacturing and Material Handling Details	
Make :	<input type="text"/>
Manufacturer :	<input type="text"/>
Model :	<input type="text"/>
Type of Manufacturing and Materials Handling Equipment :	Conveyors
Capacity :	28.0000000000
Units :	other units ▼
Description (If Other):	tons/hour
Have you attached a diagram showing the location and/or the configuration of this equipment?	▼
Have you attached any manuf.'s data or specifications to aid the Dept. in it review of this application?	▼
Comments :	Located in current ash/ferrous area.

BOP260001

New Jersey Department of Environmental Protection

Control Device Inventory

NJID	Facility Designation	Description	CD Type	Install Date	Grand-Fathered	Last Mod. (Since 1968)	Control Device Set NJID
CD1001	1001	Scrubber - Boiler #1	Scrubber (Other)	11/1/1990	No		
CD1002	1002	Scrubber - Boiler #2	Scrubber (Other)	11/1/1990	No		
CD1003	1003	Scrubber - Boiler #3	Scrubber (Other)	11/1/1990	No		
CD1007	1007	Thermal DeNOx - Boiler #1	Selective Non-Catalytic Reduction	11/1/1994	No	7/29/97	
CD1008	1008	Thermal DeNOx - Boiler #2	Selective Non-Catalytic Reduction	11/1/1994	No	7/29/97	
CD1009	1009	Thermal DeNOx - Boiler #3	Selective Non-Catalytic Reduction	11/1/1994	No	7/29/97	
CD1010	1010	Carbon Injection - Boiler #1	Adsorber	12/1/1995	No	6/21/96	
CD1011	1011	Carbon Injection - Boiler #2	Adsorber	12/1/1995	No	6/21/96	
CD1012	1012	Carbon Injection - Boiler #3	Adsorber	12/1/1995	No	6/21/96	
CD1013	1013	Lime Silo A Baghouse	Particulate Filter (Baghouse)	11/1/1990	No		
CD1014	1014	Lime Silo B Baghouse	Particulate Filter (Baghouse)	11/1/1990	No		
CD1015	1015	Lime Silo C Baghouse	Particulate Filter (Baghouse)	11/1/1990	No		
CD1017	1017	Flyash Silo A Baghouse	Particulate Filter (Baghouse)	11/11/1991	No		
CD1018	1018	Flyash Silo B Baghouse	Particulate Filter (Baghouse)	11/11/1991	No		
CD1019	1019	Flyash Building Baghouse	Particulate Filter (Baghouse)	11/11/1991	No	3/29/19	
CD1020	1020	Carbon Silo Baghouse	Particulate Filter (Baghouse)	12/1/1995	No		
CD1022	Ash Area Ven	Ash Area Vent Filter	Particulate Filter (Cartridge)	10/1/2012	No		
CD1023	1023	Baghouse - Boiler #1	Particulate Filter (Baghouse)	11/6/2016	No		
CD1024	1024	Baghouse - Boiler #2	Particulate Filter (Baghouse)	5/24/2016	No		
CD1025	1025	Baghouse - Boiler #3	Particulate Filter (Baghouse)	11/1/2015	No		

▼ Scrubber (Other) Details

Make:

Manufacturer:

Model:

Scrubber Type:

Description:

Is the Scrubber used for Particulate Control?

Is the Scrubber used for Gas Control?

Is the Scrubber Equipped with a Mist Eliminator?

Minimum Pump Discharge Pressure (in. H2O):

Maximum Pump Discharge Pressure (in. H2O):

Method of Monitoring Pump Discharge Pressure:

Minimum Pump Current (amps):

Maximum Pump Current (amps):

Method of Monitoring Pump Current:

Minimum Scrubber Medium Inlet Pressure (in. H2O):

Minimum Operating Liquid Flow Rate (gpm):

Maximum Operating Liquid Flow Rate (gpm):

Method of Monitoring Liquid Flow Rate:

Minimum Operating Gas Flow Rate (acfm):

Maximum Operating Gas Flow Rate (acfm):

Method of Monitoring Gas Flow Rate:

Minimum Operating Pressure Drop (in. H₂O):

Maximum Operating Pressure Drop (in. H₂O):

Method of Monitoring Pressure Drop:

Relative Direction of the Gas-Liquid Flow:

Number of Plates:

Type of Plates:

Spacing Between Plates (in.):

Maximum Inlet Gas Temperature (deg F):

Maximum Outlet Gas Temperature (deg F):

Inlet Particle Grain Loading (gr/dscf):

Maximum Number of Sources Using this Apparatus as a Control Device (Include Permitted and Non-permitted Sources):

1

Alternative Method to Demonstrate Control Apparatus is Operating Properly:

SO2 monitor

Have you attached data from recent performance testing?

No

Have you attached any manufacturer's data or specifications in support of the feasibility and/or effectiveness of this control apparatus?

no

Have you attached a diagram showing the location and/or configuration of this control apparatus?

No

Comments:

--

▼ Scrubber (Other) Details

Make:

Manufacturer:

Model:

Scrubber Type:

Description:

Is the Scrubber used for Particulate Control?

Is the Scrubber used for Gas Control?

Is the Scrubber Equipped with a Mist Eliminator?

Minimum Pump Discharge Pressure (in. H2O):

Maximum Pump Discharge Pressure (in. H2O):

Method of Monitoring Pump Discharge Pressure:

Minimum Pump Current (amps):

Maximum Pump Current (amps):

Method of Monitoring Pump Current:

Minimum Scrubber Medium Inlet Pressure (in. H2O):

Minimum Operating Liquid Flow Rate (gpm):

Maximum Operating Liquid Flow Rate (gpm):

Method of Monitoring Liquid Flow Rate:

Minimum Operating Gas Flow Rate (acfm):

Maximum Operating Gas Flow Rate (acfm):

Method of Monitoring Gas Flow Rate:

Minimum Operating Pressure Drop (in. H₂O):

Maximum Operating Pressure Drop (in. H₂O):

Method of Monitoring Pressure Drop:

Relative Direction of the Gas-Liquid Flow:

Number of Plates:

Type of Plates:

Spacing Between Plates (in.):

Maximum Inlet Gas Temperature (deg F):

Maximum Outlet Gas Temperature (deg F):

Inlet Particle Grain Loading (gr/dscf):

Maximum Number of Sources Using this Apparatus as a Control Device (Include Permitted and Non-permitted Sources):

1

Alternative Method to Demonstrate Control Apparatus is Operating Properly:

SO2 monitor

Have you attached data from recent performance testing?

No

Have you attached any manufacturer's data or specifications in support of the feasibility and/or effectiveness of this control apparatus?

no

Have you attached a diagram showing the location and/or configuration of this control apparatus?

No

Comments:

--

▼ Scrubber (Other) Details

Make:

Manufacturer:

Model:

Scrubber Type:

Description:

Is the Scrubber used for Particulate Control?

Is the Scrubber used for Gas Control?

Is the Scrubber Equipped with a Mist Eliminator?

Minimum Pump Discharge Pressure (in. H2O):

Maximum Pump Discharge Pressure (in. H2O):

Method of Monitoring Pump Discharge Pressure:

Minimum Pump Current (amps):

Maximum Pump Current (amps):

Method of Monitoring Pump Current:

Minimum Scrubber Medium Inlet Pressure (in. H2O):

Minimum Operating Liquid Flow Rate (gpm):

Maximum Operating Liquid Flow Rate (gpm):

Method of Monitoring Liquid Flow Rate:

Minimum Operating Gas Flow Rate (acfm):

Maximum Operating Gas Flow Rate (acfm):

Method of Monitoring Gas Flow Rate:

Minimum Operating Pressure Drop (in. H₂O):

Maximum Operating Pressure Drop (in. H₂O):

Method of Monitoring Pressure Drop:

Relative Direction of the Gas-Liquid Flow:

Number of Plates:

Type of Plates:

Spacing Between Plates (in.):

Maximum Inlet Gas Temperature (deg F):

Maximum Outlet Gas Temperature (deg F):

Inlet Particle Grain Loading (gr/dscf):

Maximum Number of Sources Using this Apparatus as a Control Device (Include Permitted and Non-permitted Sources):

1

Alternative Method to Demonstrate Control Apparatus is Operating Properly:

SO2 monitor

Have you attached data from recent performance testing?

No

Have you attached any manufacturer's data or specifications in support of the feasibility and/or effectiveness of this control apparatus?

no

Have you attached a diagram showing the location and/or configuration of this control apparatus?

No

Comments:

--

▼ Selective Non-Catalytic Reduction Details

Make:	Sierra Environmental
Manufacturer:	Sierra Environmental
Model:	
Minimum Temperature at Reagent Injection Point (deg F):	1600-1700 F
Maximum Temperature at Reagent Injection Point (deg F):	1800-1900 F
Type of Reagent:	Ammonium Hydroxide
Description:	
Minimum Concentration of Reagent in Solution (% Volume):	19
Minimum Reagent Charge Rate (gpm):	0.2
Maximum Reagent Charge Rate (gpm):	7
Maximum NOx to Reagent Mole Ratio:	0.8
Number of Reagent Injectors:	54
Location of Reagent Injectors:	First Pass of Boiler (Injection nozzles located at 84', 95' and 113')
Reagent Injection Method:	Injection Nozzles (18 per boiler level)
Maximum Anticipated Ammonia Slip (ppm):	Less than 50 ppm

Description of Feedback System which Controls the Amount of Reagent Charged to the Control Apparatus:

NOx monitor

Maximum Number of Sources Using this Apparatus as a Control Device (Include Permitted and Non-permitted Sources):

1

Alternative Method to Demonstrate Control Apparatus is Operating Properly:

Have you attached any manufacturer's data or specifications in support of the feasibility and/or effectiveness of this control apparatus?

No

Have you attached a diagram showing the location and/or configuration of this control apparatus?

No

Comments:

Control Device Design Efficiency Table

Pollutant Category	Design Efficiency (%)
PM-10	
TSP	
VOC	
NOx	50
SO2	
CO	
Pb	
HAPs (Total)	
Other (Total)	
Individual HAPs/Other	
(speciate below)	

∨ Selective Non-Catalytic Reduction Details

Make:	Sierra Environmental
Manufacturer:	Sierra Environmental
Model:	
Minimum Temperature at Reagent Injection Point (deg F):	1600-1700 F
Maximum Temperature at Reagent Injection Point (deg F):	1800-1900 F
Type of Reagent:	Ammonium Hydroxide
Description:	
Minimum Concentration of Reagent in Solution (% Volume):	19
Minimum Reagent Charge Rate (gpm):	0.2
Maximum Reagent Charge Rate (gpm):	7
Maximum NOx to Reagent Mole Ratio:	0.8
Number of Reagent Injectors:	54
Location of Reagent Injectors:	First Pass of Boiler (Injection nozzles located at 84', 95' and 113')
Reagent Injection Method:	Injection Nozzles (18 per boiler level)
Maximum Anticipated Ammonia Slip (ppm):	Less than 50 ppm

Description of Feedback System which Controls the Amount of Reagent Charged to the Control Apparatus:

NOx monitor

Maximum Number of Sources Using this Apparatus as a Control Device (Include Permitted and Non-permitted Sources):

1

Alternative Method to Demonstrate Control Apparatus is Operating Properly:

Have you attached any manufacturer's data or specifications in support of the feasibility and/or effectiveness of this control apparatus?

No

Have you attached a diagram showing the location and/or configuration of this control apparatus?

No

Comments:

▼ Selective Non-Catalytic Reduction Details

Make:	Sierra Environmental
Manufacturer:	Sierra Environmental
Model:	
Minimum Temperature at Reagent Injection Point (deg F):	1600-1700 F
Maximum Temperature at Reagent Injection Point (deg F):	1800-1900 F
Type of Reagent:	Ammonium Hydroxide
Description:	
Minimum Concentration of Reagent in Solution (% Volume):	19
Minimum Reagent Charge Rate (gpm):	0.2
Maximum Reagent Charge Rate (gpm):	7
Maximum NOx to Reagent Mole Ratio:	0.8
Number of Reagent Injectors:	54
Location of Reagent Injectors:	First Pass of Boiler (Injection nozzles located at 84', 95' and 113')
Reagent Injection Method:	Injection Nozzles (18 per boiler level)
Maximum Anticipated Ammonia Slip (ppm):	Less than 50 ppm

Description of Feedback System which Controls the Amount of Reagent Charged to the Control Apparatus:

NOx monitor

Maximum Number of Sources Using this Apparatus as a Control Device (Include Permitted and Non-permitted Sources):

1

Alternative Method to Demonstrate Control Apparatus is Operating Properly:

Have you attached any manufacturer's data or specifications in support of the feasibility and/or effectiveness of this control apparatus?

No

Have you attached a diagram showing the location and/or configuration of this control apparatus?

No

Comments:

Control Device Design Efficiency Table

Pollutant Category	Design Efficiency (%)
PM-10	
TSP	
VOC	
NOx	50
SO2	
CO	
Pb	
HAPs (Total)	
Other (Total)	
Individual HAPs/Other	
(speciate below)	

∨ Adsorber Details

Make:	
Manufacturer:	Norit Americas, Inc.
Model:	
Adsorber Type:	Carbon Injection
Description:	Mercury removal by adsorption onto carbon
Maximum Gas Flow Rate to Adsorber (acfm):	
Maximum Temperature of Vapor Stream to Adsorber (deg F):	491
Minimum Temperature of Vapor Stream to Adsorber (deg F):	
Minimum Moisture Content of Vapor Stream to Adsorber (%):	15 to 20%
Type of Adsorbant:	Carbon (Lignite, DARCO FGD, or equiv.)
Bed Height:	NA
Bed Length:	NA
Bed Width:	NA
Units:	Injection rate: 0 - 100 pounds per hour
Other Bed Dimension:	
Value:	
Units:	
Minimum Pressure Drop Across Adsorber (In H2O):	NA

Maximum Pressure Drop Across Adsorber (In H2O):

Total Weight of Adsorbant (lbs):

Total Weight of Adsorbant When Saturated (lbs):

Maximum Adsorbant Capacity (lbs Adsorbate/lbs Adsorbant):

Minimum Adsorbant Capacity (lbs Adsorbate/lbs Adsorbant):

Set-up Type:

Method of Determining Breakthrough:

Continuous Emissions Monitor (CEM)

Replacement By Weight

Periodic Testing

Sampling Frequency

Sampling Device

Other

Description:

Minimum Concentration at Breakthrough (ppmvd):

Handling Method of Saturated Adsorbant:

Method of Regeneration:

Maximum Number of Sources Using this Apparatus as a Control Device (Include Permitted and Non-permitted Sources):

Alternative Method to Demonstrate Control Apparatus is Operating Properly:

Have you attached data from recent performance testing?

Have you attached any manufacturer's data or specifications in support of the feasibility and/or effectiveness of this control apparatus?

Have you attached a diagram showing the location and/or configuration of this control apparatus?

Comments:

∨ Adsorber Details

Make:	
Manufacturer:	Norit Americas, Inc.
Model:	
Adsorber Type:	Carbon Injection
Description:	Mercury removal by adsorption onto carbon
Maximum Gas Flow Rate to Adsorber (acfm):	
Maximum Temperature of Vapor Stream to Adsorber (dea F):	491
Minimum Temperature of Vapor Stream to Adsorber (dea F):	
Minimum Moisture Content of Vapor Stream to Adsorber (%):	15 to 20%
Type of Adsorbant:	Carbon (Lignite, DARCO FGD, or equiv.)
Bed Height:	NA
Bed Length:	NA
Bed Width:	NA
Units:	Injection rate: 0 - 100 pounds per hour
Other Bed Dimension:	
Value:	
Units:	
Minimum Pressure Drop Across Adsorber (In H2O):	NA

Maximum Pressure Drop Across Adsorber (In H₂O):

Total Weight of Adsorbant (lbs):

Total Weight of Adsorbant When Saturated (lbs):

Maximum Adsorbant Capacity (lbs Adsorbate/lbs Adsorbant):

Minimum Adsorbant Capacity (lbs Adsorbate/lbs Adsorbant):

Set-up Type:

Method of Determining Breakthrough:

Continuous Emissions Monitor (CEM)

Replacement By Weight

Periodic Testing

Sampling Frequency

Sampling Device

Other

Description:

Minimum Concentration at Breakthrough (ppmvd):

Handling Method of Saturated Adsorbant:

Method of Regeneration:

Maximum Number of Sources Using this Apparatus as a Control Device (Include Permitted and Non-permitted Sources):

Alternative Method to Demonstrate Control Apparatus is Operating Properly:

Have you attached data from recent performance testing?

Have you attached any manufacturer's data or specifications in support of the feasibility and/or effectiveness of this control apparatus?

Have you attached a diagram showing the location and/or configuration of this control apparatus?

Comments:

∨ Adsorber Details

Make:	
Manufacturer:	Norit Americas, Inc.
Model:	
Adsorber Type:	Carbon Injection
Description:	Mercury removal by adsorption onto carbon
Maximum Gas Flow Rate to Adsorber (acfm):	
Maximum Temperature of Vapor Stream to Adsorber (dea F):	491
Minimum Temperature of Vapor Stream to Adsorber (dea F):	
Minimum Moisture Content of Vapor Stream to Adsorber (%):	15 to 20%
Type of Adsorbant:	Carbon (Lignite, DARCO FGD, or equiv.)
Bed Height:	NA
Bed Length:	NA
Bed Width:	NA
Units:	Injection rate: 0 - 100 pounds per hour
Other Bed Dimension:	
Value:	
Units:	
Minimum Pressure Drop Across Adsorber (In H2O):	NA

Maximum Pressure Drop Across Adsorber (In H2O):

Total Weight of Adsorbant (lbs):

Total Weight of Adsorbant When Saturated (lbs):

Maximum Adsorbant Capacity (lbs Adsorbate/lbs Adsorbant):

Minimum Adsorbant Capacity (lbs Adsorbate/lbs Adsorbant):

Set-up Type:

Method of Determining Breakthrough:

Continuous Emissions Monitor (CEM)

Replacement By Weight

Periodic Testing

Sampling Frequency

Sampling Device

Other

Description:

Minimum Concentration at Breakthrough (ppmvd):

Handling Method of Saturated Adsorbant:

Method of Regeneration:

Maximum Number of Sources Using this Apparatus as a Control Device (Include Permitted and Non-permitted Sources):

Alternative Method to Demonstrate Control Apparatus is Operating Properly:

Have you attached data from recent performance testing?

Have you attached any manufacturer's data or specifications in support of the feasibility and/or effectiveness of this control apparatus?

Have you attached a diagram showing the location and/or configuration of this control apparatus?

Comments:

∨ Particulate Filter (Baghouse) Details

Make:	
Manufacturer:	Griffen
Model:	DF44
Number of Bags:	54
Size of Bags (ft2):	7.8
Total Bag Area (ft2):	375
Bag Fabric:	Polypropylene
Fabric Weight (oz/ft):	16 oz/ sq yd.
Fabric Weave:	non - woven
Fabric Finish:	plain
Maximum Design Temperature Capability (deg F):	250
Maximum Design Air Flow Rate (acfm):	1300
Draft Type:	
Maximum Air Flow Rate to Cloth Area Ratio:	5.28:1 @ 340 ACFM
Minimum Operating Pressure Drop (in. H2O):	4
Maximum Operating Pressure Drop (in. H2O):	6
Method of Monitoring Pressure Drop:	

Maximum Inlet Temperature (deg F):

Minimum Inlet Temperature (deg F):

Dew Point of Gas Stream (deg F):

Maximum Operating Exhaust Gas Flow Rate (acfm): 800

Maximum Inlet Gas Stream Moisture Content (%):

Method for Determining When Bag Replacement is Required: Replacement is Done on a Preventative Maintenance Schedule.

Method for Determining When Cleaning is Required:

Method of Bag Cleaning: Mechanical shaking

Is Bag Cleaning Conducted On-Line?

Maximum Number of Sources Using this Apparatus as a Control Device (Include Permitted and Non-permitted Sources):

Alternative Method to Demonstrate Control Apparatus is Operating Properly:

Have you attached a Particle Size Distribution Analysis? No

Have you attached data from recent performance testing?

No

Have you attached any manufacturer's data or specifications in support of the feasibility and/or effectiveness of this control apparatus?

No

Have you attached a diagram showing the location and/or configuration of this control apparatus?

Comments:

∨ Particulate Filter (Baghouse) Details

Make:	<input type="text"/>
Manufacturer:	<input type="text" value="Griffen"/>
Model:	<input type="text" value="DF44"/>
Number of Bags:	<input type="text" value="54"/>
Size of Bags (ft2):	<input type="text" value="7.8"/>
Total Bag Area (ft2):	<input type="text" value="375"/>
Bag Fabric:	<input type="text" value="Polypropylene"/>
Fabric Weight (oz/ft):	<input type="text" value="16 oz/ sq yd."/>
Fabric Weave:	<input type="text" value="non - woven"/>
Fabric Finish:	<input type="text" value="plain"/>
Maximum Design Temperature Capability (deg F):	<input type="text" value="250"/>
Maximum Design Air Flow Rate (acfm):	<input type="text" value="1300"/>
Draft Type:	<input type="text"/>
Maximum Air Flow Rate to Cloth Area Ratio:	<input type="text" value="5.28:1 @ 340 ACFM"/>
Minimum Operating Pressure Drop (in. H2O):	<input type="text" value="4"/>
Maximum Operating Pressure Drop (in. H2O):	<input type="text" value="8"/>
Method of Monitoring Pressure Drop:	<input type="text"/>
Maximum Inlet Temperature (deg F):	<input type="text"/>

Minimum Inlet Temperature (deg F):

Dew Point of Gas Stream (deg F):

Maximum Operating Exhaust Gas Flow Rate (acfm):

Maximum Inlet Gas Stream Moisture Content (%):

Method for Determining When Bag Replacement is Required:

Method for Determining When Cleaning is Required:

Method of Bag Cleaning:

Is Bag Cleaning Conducted On-Line?

Maximum Number of Sources Using this Apparatus as a Control Device (Include Permitted and Non-permitted Sources):

Alternative Method to Demonstrate Control Apparatus is Operating Properly:

Have you attached a Particle Size Distribution Analysis?

Have you attached data from recent performance testing?

Have you attached any manufacturer's data or specifications in support of the feasibility and/or effectiveness of this control measure?

No

Have you attached a diagram showing the location and/or configuration of this control measure?

Comments:

∨ Particulate Filter (Baghouse) Details

Make:	<input type="text"/>
Manufacturer:	<input type="text" value="Griffen"/>
Model:	<input type="text" value="DF44"/>
Number of Bags:	<input type="text" value="54"/>
Size of Bags (ft2):	<input type="text" value="7.8"/>
Total Bag Area (ft2):	<input type="text" value="375"/>
Bag Fabric:	<input type="text" value="Polypropylene"/>
Fabric Weight (oz/ft):	<input type="text" value="16 oz/ sq yd."/>
Fabric Weave:	<input type="text" value="non - woven"/>
Fabric Finish:	<input type="text" value="plain"/>
Maximum Design Temperature Capability (deg F):	<input type="text" value="250"/>
Maximum Design Air Flow Rate (acfm):	<input type="text" value="1300"/>
Draft Type:	<input type="text"/>
Maximum Air Flow Rate to Cloth Area Ratio:	<input type="text" value="5.28:1 @ 340 ACFM"/>
Minimum Operating Pressure Drop (in. H2O):	<input type="text" value="4"/>
Maximum Operating Pressure Drop (in. H2O):	<input type="text" value="8"/>
Method of Monitoring Pressure Drop:	<input type="text"/>
Maximum Inlet Temperature (deg F):	<input type="text"/>

Minimum Inlet Temperature (deg F):

Dew Point of Gas Stream (deg F):

Maximum Operating Exhaust Gas Flow Rate (acfm):

Maximum Inlet Gas Stream Moisture Content (%):

Method for Determining When Bag Replacement is Required:

Method for Determining When Cleaning is Required:

Method of Bag Cleaning:

Is Bag Cleaning Conducted On-Line?

Maximum Number of Sources Using this Apparatus as a Control Device (Include Permitted and Non-permitted Sources):

Alternative Method to Demonstrate Control Apparatus is Operating Properly:

Have you attached a Particle Size Distribution Analysis?

Have you attached data from recent performance testing?

Have you attached any manufacturer's data or specifications in support of the feasibility and/or effectiveness of this control measure?

No

Have you attached a diagram showing the location and/or configuration of this control measure?

Comments:

∨ Particulate Filter (Baghouse) Details

Make:	<input type="text"/>
Manufacturer:	<input type="text"/>
Model:	<input type="text"/>
Number of Bags:	<input type="text" value="9"/>
Size of Bags (ft2):	<input type="text" value="7.2"/>
Total Bag Area (ft2):	<input type="text" value="65"/>
Bag Fabric:	<input type="text" value="Polyester Felt"/>
Fabric Weight (oz/ft):	<input type="text" value="16"/>
Fabric Weave:	<input type="text" value="Non - Woven"/>
Fabric Finish:	<input type="text" value="Plain"/>
Maximum Design Temperature Capability (deg F):	<input type="text" value="250"/>
Maximum Design Air Flow Rate (acfm):	<input type="text" value="400"/>
Draft Type:	<input type="text"/>
Maximum Air Flow Rate to Cloth Area Ratio:	<input type="text" value="5.2:1 @ 340 acfm"/>
Minimum Operating Pressure Drop (in. H2O):	<input type="text" value="3"/>
Maximum Operating Pressure Drop (in. H2O):	<input type="text" value="8"/>
Method of Monitoring Pressure Drop:	<input type="text"/>
Maximum Inlet Temperature (deg F):	<input type="text" value="190"/>

Minimum Inlet Temperature (deg F):

Dew Point of Gas Stream (deg F):

Maximum Operating Exhaust Gas Flow Rate (acfm):

Maximum Inlet Gas Stream Moisture Content (%):

Method for Determining When Bag Replacement is Required:

Method for Determining When Cleaning is Required:

Method of Bag Cleaning:

Is Bag Cleaning Conducted On-Line?

Maximum Number of Sources Using this Apparatus as a Control Device (Include Permitted and Non-permitted Sources):

Alternative Method to Demonstrate Control Apparatus is Operating Properly:

Have you attached a Particle Size Distribution Analysis?

Have you attached data from recent performance testing?

Have you attached any manufacturer's data or specifications in support of the feasibility and/or effectiveness of this control measure?

No

Have you attached a diagram showing the location and/or configuration of this control measure?

Comments:

Control Device Design Efficiency Table

Pollutant Category	Design Efficiency (%)
PM-10	99.8
TSP	
VOC	
NOx	
SO2	
CO	
Pb	
HAPs (Total)	
Other (Total)	
Individual HAPs/Other	
(speciate below)	

∨ Particulate Filter (Baghouse) Details

Make:	<input type="text"/>
Manufacturer:	<input type="text"/>
Model:	<input type="text"/>
Number of Bags:	<input type="text" value="9"/>
Size of Bags (ft2):	<input type="text" value="7.2"/>
Total Bag Area (ft2):	<input type="text" value="65"/>
Bag Fabric:	<input type="text" value="Polyester Felt"/>
Fabric Weight (oz/ft):	<input type="text" value="16"/>
Fabric Weave:	<input type="text" value="Non - Woven"/>
Fabric Finish:	<input type="text" value="Plain"/>
Maximum Design Temperature Capability (deg F):	<input type="text" value="250"/>
Maximum Design Air Flow Rate (acfm):	<input type="text" value="400"/>
Draft Type:	<input type="text"/>
Maximum Air Flow Rate to Cloth Area Ratio:	<input type="text" value="5.2:1 @ 340 acfm"/>
Minimum Operating Pressure Drop (in. H2O):	<input type="text" value="3"/>
Maximum Operating Pressure Drop (in. H2O):	<input type="text" value="6"/>
Method of Monitoring Pressure Drop:	<input type="text"/>
Maximum Inlet Temperature (deg F):	<input type="text" value="190"/>

Minimum Inlet Temperature (deg F):

Dew Point of Gas Stream (deg F):

Maximum Operating Exhaust Gas Flow Rate (acfm):

Maximum Inlet Gas Stream Moisture Content (%):

Method for Determining When Bag Replacement is Required:

Method for Determining When Cleaning is Required:

Method of Bag Cleaning:

Is Bag Cleaning Conducted On-Line?

Maximum Number of Sources Using this Apparatus as a Control Device (Include Permitted and Non-permitted Sources):

Alternative Method to Demonstrate Control Apparatus is Operating Properly:

Have you attached a Particle Size Distribution Analysis?

Have you attached data from recent performance testing?

Have you attached any manufacturer's data or specifications in support of the feasibility and/or effectiveness of this control measure?

No

Have you attached a diagram showing the location and/or configuration of this control measure?

Comments:

∨ Particulate Filter (Baghouse) Details

Make:	<input type="text"/>
Manufacturer:	<input type="text"/>
Model:	<input type="text"/>
Number of Bags:	<input type="text" value="38"/>
Size of Bags (ft ²):	<input type="text" value="10.8"/>
Total Bag Area (ft ²):	<input type="text" value="382"/>
Bag Fabric:	<input type="text" value="Polypropylene"/>
Fabric Weight (oz/ft):	<input type="text" value="16"/>
Fabric Weave:	<input type="text" value="Felt"/>
Fabric Finish:	<input type="text" value="Plain"/>
Maximum Design Temperature Capability (deg F):	<input type="text" value="180"/>
Maximum Design Air Flow Rate (acfm):	<input type="text" value="2000"/>
Draft Type:	<input type="text"/>
Maximum Air Flow Rate to Cloth Area Ratio:	<input type="text" value="5.24:1 @ 2000 ACFM"/>
Minimum Operating Pressure Drop (in. H ₂ O):	<input type="text" value="3"/>
Maximum Operating Pressure Drop (in. H ₂ O):	<input type="text" value="8"/>
Method of Monitoring Pressure Drop:	<input type="text"/>
Maximum Inlet Temperature (deg F):	<input type="text" value="110"/>

Minimum Inlet Temperature (deg F):

Dew Point of Gas Stream (deg F):

Maximum Operating Exhaust Gas Flow Rate (acfm):

Maximum Inlet Gas Stream Moisture Content (%):

Method for Determining When Bag Replacement is Required:

Method for Determining When Cleaning is Required:

Method of Bag Cleaning:

Is Bag Cleaning Conducted On-Line?

Maximum Number of Sources Using this Apparatus as a Control Device (Include Permitted and Non-permitted Sources):

Alternative Method to Demonstrate Control Apparatus is Operating Properly:

Have you attached a Particle Size Distribution Analysis?

Have you attached data from recent performance testing?

Have you attached any manufacturer's data or specifications in support of the feasibility and/or effectiveness of this control measure?

No

Have you attached a diagram showing the location and/or configuration of this control measure?

Comments:

∨ Particulate Filter (Baghouse) Details

Make:	<input type="text"/>
Manufacturer:	<input type="text"/>
Model:	<input type="text"/>
Number of Bags:	<input type="text" value="25"/>
Size of Bags (ft ²):	<input type="text" value="10.8"/>
Total Bag Area (ft ²):	<input type="text" value="265"/>
Bag Fabric:	<input type="text" value="Polyester felt"/>
Fabric Weight (oz/ft):	<input type="text" value="16"/>
Fabric Weave:	<input type="text" value="Felt"/>
Fabric Finish:	<input type="text" value="Plain"/>
Maximum Design Temperature Capability (deg F):	<input type="text" value="250"/>
Maximum Design Air Flow Rate (acfm):	<input type="text" value="1000"/>
Draft Type:	<input type="text"/>
Maximum Air Flow Rate to Cloth Area Ratio:	<input type="text" value="1:01"/>
Minimum Operating Pressure Drop (in. H ₂ O):	<input type="text" value="4"/>
Maximum Operating Pressure Drop (in. H ₂ O):	<input type="text" value="8"/>
Method of Monitoring Pressure Drop:	<input type="text"/>
Maximum Inlet Temperature (deg F):	<input type="text"/>

Minimum Inlet Temperature (deg F):

Dew Point of Gas Stream (deg F):

Maximum Operating Exhaust Gas Flow Rate (acfm):

Maximum Inlet Gas Stream Moisture Content (%):

Method for Determining When Bag Replacement is Required:

Method for Determining When Cleaning is Required:

Method of Bag Cleaning:

Is Bag Cleaning Conducted On-Line?

Maximum Number of Sources Using this Apparatus as a Control Device (Include Permitted and Non-permitted Sources):

Alternative Method to Demonstrate Control Apparatus is Operating Properly:

Have you attached a Particle Size Distribution Analysis?

Have you attached data from recent performance testing?

Have you attached any manufacturer's data or specifications in support of the feasibility and/or effectiveness of this control measure?

No

Have you attached a diagram showing the location and/or configuration of this control measure?

Yes

Comments:

▼ Particulate Filter (Cartridge) Details

Make:	Donaldson DownFlo OVAL
Manufacturer:	Donaldson Company, Inc.
Model:	DFO 4-16
Number of Cartridges:	16
Size of Cartridges(ft ²):	190
Total Cartridge Area(ft ²):	3040
Maximum Design Temperature Capability(°F):	150
Maximum Design Air Flow Rate(acfm):	10000
Maximum Air Flow Rate To Filter Area Ratio:	3.28
Minimum Operating Pressure Drop(in. H ₂ O):	0.4
Maximum Operating Pressure Drop(in. H ₂ O):	6
Maximum Inlet Temperature(°F):	150
Maximum Operating Exhaust Gas Flow Rate(acfm):	10000
Method for Determining When Cartridge Replacement is Required:	Preventative maintenance schedule based on manufacturer's recommendations.
Maximum Number of Sources Using this Apparatus as a Control Device(include permitted and Non - Permitted Sources):	
Alternative Method to Demonstrate Control Apparatus is Operating Properly:	
Have you attached a Particle Size Distribution Analysis?	<input type="radio"/> Yes <input type="radio"/> No
Have you attached data from recent performance testing?	<input type="radio"/> Yes <input type="radio"/> No
Have you attached any manufacturer's data or specifications in support of the feasibility and / or effectiveness of this control apparatus?	<input type="radio"/> Yes <input type="radio"/> No
Have you attached a diagram showing the location and/or configuration of this control apparatus?	<input type="radio"/> Yes <input type="radio"/> No
Comments:	Minimum 99% control efficiency (MERV 13 rating)

▼ **Particulate Filter (Baghouse) Details**

Make:

TBD

Manufacturer:

TBD

Model:

TBD

Number of Bags:

Size of Bags(ft²):

Total Bag Area(ft²)

0

Bag Fabric:

PPS

Fabric Weight(oz/ft²):

Fabric Weave:

Felt

Fabric Finish:

PTFE

Maximum Design Temperature Capability(°F):

375

Maximum Design Air Flow Rate(acfm):

240000

Draft Type:

Balanced



Maximum Air Flow Rate To Cloth Area Ratio

2.7

Minimum Operating Pressure Drop(in. H₂O):

2

Maximum Operating Pressure Drop(in. H₂O):

12

Method of Monitoring Pressure Drop:

Pressure Drop Transmitter

Maximum Inlet Temperature(°F):

375

Minimum Inlet Temperature(°F):

290

Dew Point of Gas Stream Maximum Inlet Temperature(°F)

262

Maximum Operating Exhaust Gas Flow Rate(acfm):

234000

Maximum Inlet Gas Stream Moisture Content(%):

21

Method for Determining When Bag Replacement is Required:

A change in opacity level signifies that bag replacement is required.

Method for Determining When Cleaning is Required:

Cleaning cycle is initiated based upon differential pressure across the baghouse and operating time.

Method of Bag Cleaning

Pulse Jet ▼

Description:

Is Bag Cleaning Conducted On-Line?

Yes No

Maximum Number of Sources Using this Apparatus as a Control Device(include permitted and Non - Permitted Sources):

1

Alternative Method to Demonstrate Control Apparatus is Operating Properly:

Continuous opacity monitoring and annual emissions testing are used to demonstrate that the control apparatus is functioning properly.

Have you attached a Particle Size Distribution Analysis?

Yes No

Have you attached data from recent performance testing?

Yes No

Have you attached any manufacturer's data or specifications in support of the feasibility and / or effectiveness of this control apparatus?

Yes

No

Have you attached a diagram showing the location and/or configuration of this control apparatus?

Yes

No

Comments:

Number of bags, size of bags, total bag area, and fabric weight will be provided upon vendor selection. Total bag area is listed as 0.0 due to a RADIUS error. Maximum Air Flow Rate to Cloth Area Ratio is 2.4 at MCR and 2.7 at 110% MCR.

▼ **Particulate Filter (Baghouse) Details**

Make:

TBD

Manufacturer:

TBD

Model:

TBD

Number of Bags:

Size of Bags(ft²):

Total Bag Area(ft²)

0

Bag Fabric:

PPS

Fabric Weight(oz/ft²):

Fabric Weave:

Felt

Fabric Finish:

PTFE

Maximum Design Temperature Capability(°F):

375

Maximum Design Air Flow Rate(acfm):

240000

Draft Type:

Balanced



Maximum Air Flow Rate To Cloth Area Ratio

2.7

Minimum Operating Pressure Drop(in. H₂O):

2

Maximum Operating Pressure Drop(in. H₂O):

12

Method of Monitoring Pressure Drop:

Pressure Drop Transmitter

Maximum Inlet Temperature(°F):

375

Minimum Inlet Temperature(°F):

290

Dew Point of Gas Stream Maximum Inlet Temperature(°F)

262

Maximum Operating Exhaust Gas Flow Rate(acfm):

234000

Maximum Inlet Gas Stream Moisture Content(%):

21

Method for Determining When Bag Replacement is Required:

A change in opacity level signifies that bag replacement is required.

Method for Determining When Cleaning is Required:

Cleaning cycle is initiated based upon differential pressure across the baghouse and operating time.

Method of Bag Cleaning

Pulse Jet ▼

Description:

Is Bag Cleaning Conducted On-Line?

Yes No

Maximum Number of Sources Using this Apparatus as a Control Device(include permitted and Non - Permitted Sources):

1

Alternative Method to Demonstrate Control Apparatus is Operating Properly:

Continuous opacity monitoring and annual emissions testing are used to demonstrate that the control apparatus is functioning properly.

Have you attached a Particle Size Distribution Analysis?

Yes No

Have you attached data from recent performance testing?

Yes No

Have you attached any manufacturer's data or specifications in support of the feasibility and / or effectiveness of this control apparatus?

Yes

No

Have you attached a diagram showing the location and/or configuration of this control apparatus?

Yes

No

Comments:

Number of bags, size of bags, total bag area, and fabric weight will be provided upon vendor selection. Total bag area is listed as 0.0 due to a RADIUS error. Maximum Air Flow Rate to Cloth Area Ratio is 2.4 at MCR and 2.7 at 110% MCR.

▼ **Particulate Filter (Baghouse) Details**

Make:

TBD

Manufacturer:

TBD

Model:

TBD

Number of Bags:

Size of Bags(ft²):

Total Bag Area(ft²)

0

Bag Fabric:

PPS

Fabric Weight(oz/ft²):

Fabric Weave:

Felt

Fabric Finish:

PTFE

Maximum Design Temperature Capability(°F):

375

Maximum Design Air Flow Rate(acfm):

240000

Draft Type:

Balanced



Maximum Air Flow Rate To Cloth Area Ratio

2.7

Minimum Operating Pressure Drop(in. H₂O):

2

Maximum Operating Pressure Drop(in. H₂O):

12

Method of Monitoring Pressure Drop:

Pressure Drop Transmitter

Maximum Inlet Temperature(°F):

375

Minimum Inlet Temperature(°F):

290

Dew Point of Gas Stream Maximum Inlet Temperature(°F)

262

Maximum Operating Exhaust Gas Flow Rate(acfm):

234000

Maximum Inlet Gas Stream Moisture Content(%):

21

Method for Determining When Bag Replacement is Required:

A change in opacity level signifies that bag replacement is required.

Method for Determining When Cleaning is Required:

Cleaning cycle is initiated based upon differential pressure across the baghouse and operating time.

Method of Bag Cleaning

Pulse Jet ▼

Description:

Is Bag Cleaning Conducted On-Line?

Yes No

Maximum Number of Sources Using this Apparatus as a Control Device(include permitted and Non - Permitted Sources):

1

Alternative Method to Demonstrate Control Apparatus is Operating Properly:

Continuous opacity monitoring and annual emissions testing are used to demonstrate that the control apparatus is functioning properly.

Have you attached a Particle Size Distribution Analysis?

Yes No

Have you attached data from recent performance testing?

Yes No

Have you attached any manufacturer's data or specifications in support of the feasibility and / or effectiveness of this control apparatus?

Yes

No

Have you attached a diagram showing the location and/or configuration of this control apparatus?

Yes

No

Comments:

Number of bags, size of bags, total bag area, and fabric weight will be provided upon vendor selection. Total bag area is listed as 0.0 due to a RADIUS error. Maximum Air Flow Rate to Cloth Area Ratio is 2.4 at MCR and 2.7 at 110% MCR.

BOP260001

New Jersey Department of Environmental Protection

Emission Points Inventory

PT NJID	Facility's Designation	Description	Config.	Equiv. Diam (in.)	Height (ft.)	Property Line Distance (ft.)	Exhaust Temp. (deg F.)			Exhaust Vol. (acfm)			Discharge Direction	PT Set ID
							Avg.	Min	Max	Avg	Min	Max		
PT1	U0001	MSW BOILER #1	Round	91	279	230	285.0	200.0	300.0	181000.0	140000.0	220000.0	Up	
PT2	U0002	MSW BOILER #2	Round	91	279	230	285.0	200.0	300.0	181000.0	140000.0	220000.0	Up	
PT3	U0003	MSW BOILER #3	Round	91	279	230	285.0	200.0	300.0	181000.0	140000.0	220000.0	Up	
PT4	U0006	LIME SILO A	Rectangle	12	72	375	60.0	-10.0	100.0	1176.0	1176.0	1176.0	Horizontal	
PT5	U0007	LIME SILO B	Rectangle	12	72	375	60.0	-10.0	100.0	1176.0	1176.0	1176.0	Horizontal	
PT6	U0008	LIME SILO C	Rectangle	12	72	375	60.0	-10.0	100.0	1176.0	1176.0	1176.0	Horizontal	
PT7	U0013	DIESEL GENERATOR	Round	12	43	360	915.0	915.0	915.0	6915.0	6915.0	6915.0	Horizontal	
PT8	U0014	DIESEL FIRE PUMP	Round	8	39	125	983.0	982.0	982.0	1200.0	1200.0	1200.0	Horizontal	
PT9	U0009	LIME SLAKER VENT A	Round	6	20	250	85.0	60.0	140.0	37.0	37.0	37.0	Horizontal	
PT10	U0010	LIME SLAKER VENT B	Round	6	20	250	85.0	60.0	140.0	37.0	37.0	37.0	Horizontal	
PT12	U0012	FLY ASH CONDITIONING ROOM	Rectangle	8	71	376	80.0	40.0	110.0	2000.0	2000.0	2000.0	Horizontal	
PT13	U0004	#2 FUEL OIL STORAGE TANK	Round	3	3	100	60.0	-10.0	100.0	5.0	1.0	8.0	Down	
PT14	U0011	CARBON SILO	Round	12	35	375	60.0	-10.0	100.0	1200.0	100.0	1200.0	Horizontal	
PT15	U0015	ASH CONVEYANCE	Square	24	54	370	60.0	40.0	90.0	10000.0	0.0	10000.0	Up	
PT17	U0015	ASH CONVEYANCE	Square	42	8	376	60.0	40.0	90.0	6000.0	0.0	9600.0	Horizontal	

New Jersey Department of Environmental Protection

Batch Process Inventory

New Jersey Department of Environmental Protection
Emission Unit Inventory

U 1 MWC #1,#2,#3 MWC #1, 2, 3 Municipal Waste Combustors (E1, E2, and E3)

UOS NJID	Facility Desig.	UOS Description	Operation Type	Signif. Equip.	Control Device(s)	Emission Point(s)	All SCC per EU	Annual Oper. Hrs		VOC Range	Flow (acfm)		Temp (deg. F)	
								Min	Max		Min	Max	Min	Max
OS2	MWC 1	Operation of MWC #1 under Malfunction conditions	Malfunction	E1	CD1007 (P) CD1010 (S) CD1001 (T)	PT1	5-03-001-12	0.0	8760.0		140000.0	233500.0	200.0	300.0
OS4	MWC 2	Operation of MWC #2 under Malfunction conditions	Malfunction	E2	CD1008 (P) CD1011 (S) CD1002 (T)	PT2	5-03-001-12	0.0	8760.0		140000.0	233500.0	200.0	300.0
OS6	MWC 3	Operation of MWC #3 under Malfunction conditions	Malfunction	E3	CD1009 (P) CD1012 (S) CD1003 (T)	PT3	5-03-001-12	0.0	8760.0		140000.0	233500.0	200.0	300.0
OS10	MWC 1	Operation of MWC #1 at Maximum Input (423 MMBtu/hr) with Baghouse	Normal - Steady State	E1	CD1007 (P) CD1010 (S) CD1001 (T) CD1023 (T)	PT1	5-03-001-12	0.0	8760.0		140000.0	233500.0	200.0	300.0
OS11	MWC 2	Operation of MWC #2 at Maximum Input (423 MMBtu/hr) with Baghouse	Normal - Steady State	E2	CD1008 (P) CD1011 (S) CD1002 (T) CD1024 (T)	PT2	5-03-001-12	0.0	8760.0		140000.0	233500.0	200.0	300.0
OS12	MWC 3	Operation of MWC #3 at Maximum Input (423 MMBtu/hr) with Baghouse	Normal - Steady State	E3	CD1009 (P) CD1012 (S) CD1003 (T) CD1025 (T)	PT3	5-03-001-12	0.0	8760.0		140000.0	233500.0	200.0	300.0

New Jersey Department of Environmental Protection

Emission Unit Inventory

U 6 Silo A Lime Storage Silo A (E4)

UOS NJID	Facility Desig.	UOS Description	Operation Type	Signif. Equip.	Control Device(s)	Emission Point(s)	All SCC per EU	Annual Oper. Hrs		VOC Range	Flow (acfm)		Temp (deg. F)	
								Min	Max		Min	Max	Min	Max
OS1	Silo A	Silo A	Normal - Steady State	E4	CD1013 (P)	PT4		2920.0	8760.0		1176.0	1176.0	-10.0	110.0
OS6	Silo A	Lime Storage Silo - A	Normal - Steady State	E4	CD1013 (P)	PT4		2920.0	8760.0		1176.0	1176.0	-10.0	110.0

New Jersey Department of Environmental Protection

Emission Unit Inventory

U 7 Silo B Lime Storage Silo B (E5)

UOS NJID	Facility Desig.	UOS Description	Operation Type	Signif. Equip.	Control Device(s)	Emission Point(s)	All SCC per EU	Annual Oper. Hrs		VOC Range	Flow (acfm)		Temp (deg. F)	
								Min	Max		Min	Max	Min	Max
OS7	Silo B	Lime Storage Silo - B	Normal - Steady State	E5	CD1014 (P)	PT5		2920.0	8760.0		1176.0	1176.0	-10.0	110.0

New Jersey Department of Environmental Protection

Emission Unit Inventory

U 8 Silo C Lime Storage Silo C (E6)

UOS NJID	Facility Desig.	UOS Description	Operation Type	Signif. Equip.	Control Device(s)	Emission Point(s)	All SCC per EU	Annual Oper. Hrs		VOC Range	Flow (acfm)		Temp (deg. F)	
								Min	Max		Min	Max	Min	Max
OS8	Silo C	Lime Storage Silo - C	Normal - Steady State	E6	CD1015 (P)	PT6		2920.0	8760.0		1176.0	1176.0	-10.0	110.0

New Jersey Department of Environmental Protection

Emission Unit Inventory

U 9 Slaker A Lime Slaker Vent A (E9)

UOS NJID	Facility Desig.	UOS Description	Operation Type	Signif. Equip.	Control Device(s)	Emission Point(s)	All SCC per EU	Annual Oper. Hrs		VOC Range	Flow (acfm)		Temp (deg. F)	
								Min	Max		Min	Max	Min	Max
OS9	Slaker A	Lime Slaker Vent A	Normal - Steady State	E9		PT9		4380.0	8760.0		37.0	37.0	60.0	140.0

New Jersey Department of Environmental Protection

Emission Unit Inventory

U 10 Slaker B Lime Slaker Vent B (E10)

UOS NJID	Facility Desig.	UOS Description	Operation Type	Signif. Equip.	Control Device(s)	Emission Point(s)	All SCC per EU	Annual Oper. Hrs		VOC Range	Flow (acfm)		Temp (deg. F)	
								Min	Max		Min	Max	Min	Max
OS10	Slaker B	Lime Slaker Vent B	Normal - Steady State	E10		PT10		4380.0	8760.0		37.0	37.0	60.0	140.0

New Jersey Department of Environmental Protection

Emission Unit Inventory

U 11 Carbon Silo Activated Carbon Storage Silo (E14)

UOS NJID	Facility Desig.	UOS Description	Operation Type	Signif. Equip.	Control Device(s)	Emission Point(s)	All SCC per EU	Annual Oper. Hrs		VOC Range	Flow (acfm)		Temp (deg. F)	
								Min	Max		Min	Max	Min	Max
OS11	Carbon Silo	Activated Carbon Storage Silo	Normal - Steady State	E14	CD1020 (P)	PT14		8760.0	8760.0		1200.0	1200.0	-10.0	110.0

New Jersey Department of Environmental Protection

Emission Unit Inventory

U 12 Flyash Cond Flyash Conditioning Room (E12,E13)

UOS NJID	Facility Desig.	UOS Description	Operation Type	Signif. Equip.	Control Device(s)	Emission Point(s)	All SCC per EU	Annual Oper. Hrs		VOC Range	Flow (acfm)		Temp (deg. F)	
								Min	Max		Min	Max	Min	Max
OS12	Silo 1	Flyash storage in Silo 1	Normal - Steady State	E12	CD1017 (P) CD1019 (S)	PT12		8760.0	8760.0		2000.0	2000.0	40.0	110.0
OS15	Silo 2	Flyash storage in Silo 2	Normal - Steady State	E13	CD1018 (P) CD1019 (S)	PT12		8760.0	8760.0		2000.0	2000.0	40.0	110.0

New Jersey Department of Environmental Protection

Emission Unit Inventory

U 13 Em Generator 7.4 MMBtu/hr, 740 KW Diesel Engine-Driven Emergency Generator (E7)

UOS NJID	Facility Desig.	UOS Description	Operation Type	Signif. Equip.	Control Device(s)	Emission Point(s)	All SCC per EU	Annual Oper. Hrs		VOC Range	Flow (acfm)		Temp (deg. F)	
								Min	Max		Min	Max	Min	Max
OS13	Generator	Emergency Diesel Generator	Normal - Steady State	E7		PT7		0.0	500.0		6915.0	6915.0	915.0	915.0

New Jersey Department of Environmental Protection

Emission Unit Inventory

U 14 Em FW Pump 1.59 MMBtu/hr Emergency Diesel Engine-Driven Fire Pump (E8)

UOS NJID	Facility Desig.	UOS Description	Operation Type	Signif. Equip.	Control Device(s)	Emission Point(s)	All SCC per EU	Annual Oper. Hrs		VOC Range	Flow (acfm)		Temp (deg. F)	
								Min	Max		Min	Max	Min	Max
OS14	Fire Pump	Emergency Diesel Fire Pump	Normal - Steady State	E8		PT8		0.0	500.0		1200.0	1200.0	982.0	982.0

New Jersey Department of Environmental Protection
Emission Unit Inventory

U 15 Ash Convey Ash and Metals Recovery System (E16, E17, E21-E30)

UOS NJID	Facility Desig.	UOS Description	Operation Type	Signif. Equip.	Control Device(s)	Emission Point(s)	All SCC per EU	Annual Oper. Hrs		VOC Range	Flow (acfm)		Temp (deg. F)	
								Min	Max		Min	Max	Min	Max
OS16	Ash Convey A	Ash Conveyance Line A	Normal - Steady State	E16	CD1022 (P)	PT15		4380.0	8760.0		0.0	10000.0	40.0	110.0
OS17	Ash Convey B	Ash Conveyance Line B	Normal - Steady State	E17	CD1022 (P)	PT15		4380.0	8760.0		0.0	10000.0	40.0	110.0
OS21	RH-136-CV	Vibratory Conveyor E21 transporting ash to Grizzly Scalper	Normal - Steady State	E21	CD1022 (P)	PT15		4380.0	8760.0		0.0	10000.0	40.0	110.0
OS22	RH-150-SC	Grizzly Scalper E22 separating large pieces of ferrous metal for recovery	Normal - Steady State	E22	CD1022 (P)	PT15		4380.0	8760.0		0.0	10000.0	40.0	110.0
OS23	RH-160-FD	Vibratory Conveyor E25 transporting bulky ferrous to load out bunker	Normal - Steady State	E25	CD1022 (P)	PT15		4380.0	8760.0		0.0	10000.0	40.0	110.0
OS24	RH-170-CV	Feeder E23 transporting ash to ferrous recovery magnet	Normal - Steady State	E23	CD1022 (P)	PT15		4380.0	8760.0		0.0	10000.0	40.0	110.0
OS25	FE-200-MAG	Ferrous material separation by Drum Magnet E24	Normal - Steady State	E24	CD1022 (P)	PT15		4380.0	8760.0		0.0	10000.0	40.0	110.0
OS26	NF-230-SC	Screen E26 separating remainder of ash into large & small	Normal - Steady State	E26	CD1022 (P)	PT15		4380.0	8760.0		0.0	10000.0	40.0	110.0
OS27	NF-300-ECS	Eddy Current Separator (+3/8) E27 separating larger non-ferrous metal	Normal - Steady State	E27	CD1022 (P)	PT15		4380.0	8760.0		0.0	10000.0	40.0	110.0
OS28	NF-400-MSB	Conveyor E28 transporting smaller material -3/8 to E29	Normal - Steady State	E28	CD1022 (P)	PT15		4380.0	8760.0		0.0	10000.0	40.0	110.0
OS29	NF-410-ECS	Eddy Current Separator (-3/8) E29 separating smaller non-ferrous metal	Normal - Steady State	E29	CD1022 (P)	PT15		4380.0	8760.0		0.0	10000.0	40.0	110.0

New Jersey Department of Environmental Protection

Emission Unit Inventory

U 15 Ash Convey Ash and Metals Recovery System (E16, E17, E21-E30)

UOS NJID	Facility Desig.	UOS Description	Operation Type	Signif. Equip.	Control Device(s)	Emission Point(s)	All SCC per EU	Annual Oper. Hrs		VOC Range	Flow (acfm)		Temp (deg. F)	
								Min	Max		Min	Max	Min	Max
OS30	E30	Conveyors E30 trasnporting to and from metals recovery systems	Normal - Steady State	E30	CD1022 (P)	PT15		4380.0	8760.0		0.0	10000.0	40.0	110.0

New Jersey Department of Environmental Protection

Subject Item Group Inventory

GR1 NSPS Sub A

Type	ID	OS	Step
U	U 1	OS0 Summary	
	U 15	OS0 Summary	
Reason for Group/Cap:		Showing Subpart A requirements applicable to 2 emission units (U1 & U15)	
Condition/Requirements that will be complied with or are no longer			
Operating Circumstances:			